

Queensland Urban Utilities
 Kilcoy Drinking Water Quality July 2012-June 2013

Aesthetic water quality

Aesthetic test description	Units	No of tests	Minimum	Maximum	Average	Aesthetic guideline	Health limit	Scheme compliant with ADWG 2011
Aluminium	mg/L	12	0.01	0.088	0.03	0.2	ns	Yes
Chloride	mg/L	12	41	52	46.3	250	ns	Yes
Iron	mg/L	12	0.013	0.28	0.07	0.3	ns	Yes
pH	pH Unit	12	7.1	7.8	7.50	6.5-8.5	ns	Yes
Total Hardness	mg/L	12	85	110	93.8	200	ns	Yes
Turbidity	NTU	12	0.13	1.3	0.49	5	ns	Yes
Zinc	mg/L	12	0.003	0.0083	0.01	3	ns	Yes

Queensland Urban Utilities Kilcoy Drinking Water Quality July 2012-June 2013

Health-related water quality

Health related test description	Units	No of tests	Minimum	Maximum	Average	Aesthetic guideline	Health limit	Scheme compliant with ADWG 2011
Barium	mg/L	12	0.019	0.027	0.02	ns	2	Yes
Cadmium	mg/L	12	<LOR	<LOR	<LOR	ns	0.002	Yes
Chlorine (Total)	mg/L	52	0.55	3.4	1.9	ns	5	Yes
Chromium	mg/L	12	<LOR	<LOR	<LOR	ns	0.05	Yes
Copper	mg/L	12	0.0018	0.0035	0.00	1	2	Yes
Dichloroacetic Acid	ug/L	12	14	27	20.9	ns	100	Yes
Escherichia coli	CFU/100mL	51	n/a	n/a	n/a	ns	<1	Yes
Fluoride (as F)	mg/L	12	0.63	0.92	0.81	ns	1.5	Yes
Lead	mg/L	12	<LOR	<LOR	<LOR	ns	0.01	Yes
Manganese	mg/L	12	<LOR	0.018	0.01	0.1	0.5	Yes
Monochloroacetic Acid	ug/L	12	<LOR	<LOR	<LOR	ns	150	Yes
Nickel	mg/L	12	<LOR	<LOR	<LOR	ns	0.02	Yes
Nitrate (as N)	mg/L	12	<LOR	0.14	<LOR	ns	50	Yes
Nitrite (as N)	mg/L	12	<LOR	<LOR	<LOR	ns	3	Yes
Trichloroacetic Acid	ug/L	12	<LOR	13	<LOR	ns	100	Yes
Trihalomethanes (Total)	ug/L	12	37	75	51.1	ns	250	Yes

Queensland Urban Utilities Kilcoy Drinking Water Quality July 2012-June 2013

Other water quality

Test description	Units	No of tests	Minimum	Maximum	Average	Aesthetic guideline	Health limit	Scheme compliant with ADWG 2011
2-Methylisoborneol	ng/L	12	<LOR	8.6	4.9	ns	ns	n/a
Alkalinity	mg/L	12	77	100	86.4	ns	ns	n/a
Ammonia (Total, as N)	mg/L	12	<LOR	0.01	<LOR	ns	ns	n/a
Bromide	mg/L	12	0.011	0.64	0.08	ns	ns	n/a
Bromochloroacetic Acid	ug/L	12	<LOR	13	<LOR	ns	ns	n/a
Bromodichloromethane	ug/L	12	13	23	16.8	ns	ns	n/a
Bromoform	ug/L	12	<LOR	6.1	3.14	ns	ns	n/a
Calcium	mg/L	12	16	22	18.8	ns	ns	n/a
Chlorate	mg/L	12	<LOR	0.45	0.06	ns	ns	n/a
Chlorine (Combined)	mg/L	52	<LOR	1	0.4	ns	ns	n/a
Chlorine (Free)	mg/L	52	0.26	3.1	1.52	ns	ns	n/a
Chlorodibromomethane	ug/L	12	11	22	14.0	ns	ns	n/a
Chloroform	ug/L	12	10	24	17.3	ns	ns	n/a

Queensland Urban Utilities Kilcoy Drinking Water Quality July 2012-June 2013

Colour (True)	PCU	12	<LOR	0.6	<LOR	ns	ns	n/a
Conductivity	uS/cm	12	370	420	398	ns	ns	n/a
Dibromoacetic Acid	ug/L	12	<LOR	<LOR	<LOR	ns	ns	n/a
Geosmin	ng/L	12	<LOR	5.8	2.3	ns	ns	n/a
Haloacetic Acids (Total)	ug/L	12	<LOR	<LOR	<LOR	ns	ns	n/a
Magnesium	mg/L	12	10	13	11.4	ns	ns	n/a
Monobromoacetic Acid	ug/L	12	<LOR	<LOR	<LOR	ns	ns	n/a
Nitrite and Nitrate(as N)	mg/L	12	0.06	0.14	0.09	ns	ns	n/a
Potassium	mg/L	12	1.9	2.3	2.12	ns	ns	n/a
Silica	mg/L	12	12	18	15.2	ns	ns	n/a
Sodium	mg/L	12	42	53	46.9	ns	ns	n/a
Sulfate (as SO ₄)	mg/L	12	32	46	36.67	ns	ns	n/a
Temperature	deg C	34	16	30	24	ns	ns	n/a
Total Dissolved Salts	mg/L	12	240	270	254	ns	ns	n/a
Total Organic Carbon	mg/L	12	1.7	2.8	2.15	ns	ns	n/a

Queensland Urban Utilities Kilcoy Drinking Water Quality July 2012-June 2013

Definitions

n/a	not applicable
ns	not set

ADWG = Australian Drinking Water Guidelines 2011.

The ADWG 2011 have been developed by the National Health and Medical Research Council (NHMRC) in collaboration with the Natural Resource Management Ministerial Council (NRMMC). The ADWG incorporates the Framework for the Management of Drinking Water Quality and provides the Australian community and the water supply industry with guidance on what constitutes good quality drinking water.

To access the ADWG go to:

http://www.nhmrc.gov.au/_files_nhmrc/publications/attachments/eh52_aust_drinking_water_guidelines_update_120710_0.pdf

Bacteriological quality

Bacteriological quality is assessed by monitoring the water for the organism *Escherichia coli* as an indicator of contamination. A drinking water scheme is considered bacteriologically safe to drink if no *E. coli* are found in 98 % of samples analysed.

Chemical parameters

QUU reports yearly on a number of water quality parameters.

The performance for chemical parameters with a health value is assessed as recommended by the ADWG. Performance is deemed as satisfactory if the 95th percentile value is less than the ADWG health guideline value.

Performance for parameters with an aesthetic guideline value is assessed as recommended by the ADWG. Water is considered good quality if the mean value of an aesthetical parameter is measured at less than the recommended maximum criteria described in ADWG.