



DESCRIPTION:	Mechanical – Thickened sludge pump lube	FREQUENCY:	
LOCATION:	Various Locations	STANDARD JOB No.:	

Reference Mater	ial
Procedural Step	S S
Before isolating	any equipment where possible observe in running condition. Check for correct operation.
Minor Service	
Visually inspect D	isc Thickener Feed Pump gear unit.
Check the oil leve	
Intermediate Ser	vice
"Visually check D	isc Thickener Feed Pump for leaks from the stator &
shaft seal.	
Replace if require	d.
1	-

Doc Id:FOR1144Active Date:18/11/2021Revision 1OwnerSylvester HennessyPrinted:Page 1 of 1

Note: Printed copies of this document should be verified for currency against the published electronic copy.