

DESCRIPTION:	Civil – Inspection & Service - Reservoir Roof Membrane	FREQUENCY:	
LOCATION:	Various	STANDARD JOB No.:	

	MATERIAL / TOOLS
	Coating Thickness Measuring Gauge.
	QUALIFICATIONS
	QBCC licensed Certificate III in Construction Waterproofing CPC31420.
	SCOPE
	Inspect and report on condition of the reservoir roof membrane.
	MINOR SERVICE
	Visual inspect of roof membrane.
	Report defects on the corresponding roof map included in FOR1194 that matches the Work Order Asset.
	Document water/moisture entry and defects identified.
	Document coating thickness using a measuring gauge.
	Contractor to submit Inspection & Service Report.
	INTERMEDIATE SERVICE
	Roof washdown / remove ponding water.
	Visual inspect of roof membrane.
	Report defects on the corresponding roof map included in FOR1194 that matches the Work Order Asset.
	Document water/moisture entry and defects identified.
	Document coating thickness using a measuring gauge.
	Contractor to submit Inspection & Service Report.

DESCRIPTION:	Civil – Inspection & Service - Reservoir Roof Membrane	FREQUENCY:	
LOCATION:	Various	STANDARD JOB No.:	

WR076 – 0021 - R76 Reservoir Stuart St Goodna 1

