

<b>DESCRIPTION:</b>	Service SIME Boiler Model 1R 8 OF	<b>FREQUENCY:</b>	
<b>LOCATION:</b>	ST057 Beaudesert STP	<b>STANDARD JOB No.:</b>	

	<b>Reference Material</b>
	AS/NZS 3788:2006
	Inspection and recertification of Boiler to be carried out by a Competent Person in
	accordance with manufacture's specification and requirements of Australian Standard:
	AS/NZS 3788:2006
	<b>Major Service</b>
	<b>Boiler No.1 LPG/ BioGas</b>
	<b>External</b>
	Inspect overall condition of boiler.
	Identify any areas of concern.
	<b>Interior</b>
	Inspect overall condition of boiler.
	Remove burner from the boiler and check the alignment of the burner cones.
	Clean out any build-up of corrosion and carbon on the burner face plate.
	Clean any lint from the combustion air fan.
	Check that the burner plates are tight, and the flame sense pathway is clean.
	Inspect the signage to identify that Biogas is in use on the site.
	Check that the combustion air flow around the burner cone is even.
	Check the retaining bolt on the burner plate is secure and aligned.
	Identify any areas of concern not covered by tasks above.
	<b>Ignition Probe</b>
	Clean Ignition Probe from any build-up of carbon scale.
	<b>Documentation</b>
	Inspection Report & Certificate of Inspection to be issued.

<b>DESCRIPTION:</b>	Service SIME Boiler Model 1R 8 OF	<b>FREQUENCY:</b>	
<b>LOCATION:</b>	ST057 Beaudesert STP	<b>STANDARD JOB No.:</b>	

[illegible]