



DESCRIPTION:	Clean Static Mixer & Associated Pipe Work	FREQUENCY:	
LOCATION:	Various Locations	STANDARD JOB No.:	

Reference Material
Where possible check and record pressure (kPa) in line before commencement of work.
Remove Static Mixer from pipe work and undertake internal clean.
Check upstream and downstream pipelines from Static Mixer for possible blockages. Clear if any.
Check any connecting lines (extra to up or down stream) to Static Mixer for possible blockages. Clear if any.
Re-assemble Static Mixer and pipelines.
If pressure check was possible before commencement of work, recheck pressure (kPa) and record.
 ·

Doc Id:FOR444Active Date:01/10/2021Revision 1OwnerSylvester HennessyPrinted:Page 1 of 1

Note: Printed copies of this document should be verified for currency against the published electronic copy.