



DESCRIPTION:	Electrical - UV System Minor Service - Kooralbyn	FREQUENCY:	
LOCATION:	ST060 Kooralbyn STP	STANDARD JOB No.:	

Reference Material		
TROJANUVFIT Owner's Manual – Kooralbyn STP, AU Trojan Project No. 160120		
Procedural Steps		
Before isolating any equipment where possible observe in running condition. Check for correct operation.		
Minor Service		
UV Unit 1		
Clean UV Sensor.		
Replace the air filter/s located in UV electrical board.		
UV Unit 2		
Clean UV Sensor.		
Replace the air filter/s located in UV electrical board.		

Doc Id: FOR452 Active Date: 10/07/2023 Revision 1 Tyson Craig Printed: **Printed copies of this document should be verified for currency against the published electronic copy.** Owner Page 1 of 1

Note: