



DESCRIPTION:	Mechanical – Automatic Air Valve – Inspection and Service	FREQUENCY:	
LOCATION:		STANDARD JOB No.:	

MATERIALS
Silicone based O-ring grease
SCOPE
Inspect and service automatic air release valve.
MINOR SERVICE
Isolate the release valve
Release the pressure in the valve through the flush port
Once the pressure has released, remove the bolts and washers from the top flange
Slowly remove the float mechanism by carefully lifting the air release body vertically upwards
Clean the inside of the valve
Visually check condition of components
Replace the flange O-ring. Lubricate replacement O-ring
Check the float mechanism is operational and reassemble.

Doc Id: FOR465 Active Date: 19/10/22 Revision 2 Tyson Craig Printed: **Printed copies of this document should be verified for currency against the published electronic copy.** Owner Page 1 of 1

Note: