



DESCRIPTION:	Mechanical – Polymore Poly Dosing System – Inspection and Service	FREQUENCY:	
LOCATION:		STANDARD JOB No.:	

SCOPE
Complete inspection and service of Polymore Poly Dosing System as per relevant task list.
REQUIREMENTS
*Equivalents can be used but must be documented for future use.
MINOR SERVICE
Where possible, observe in running condition before isolating. Check for unusual noise or vibration.
Check pump and pipework for leaks
Remove flexible tubing of pump 1 and replace with new
Remove flexible tubing of pump 2 (where installed) and replace with new
*When stock is depleted, order replacement tubing to keep as a critical spare
Check pressure relief valve/s for signs of damage
Replace the injection nipple and O-rings

Doc Id: FOR582 Active Date: 8/05/2023 Revision 1 Tyson Craig Printed: **Printed copies of this document should be verified for currency against the published electronic copy.** Owner Page 1 of 1

Note: