

 DESCRIPTION:
 3 Monthly Zone 4 Lubrication Maintenance
 FREQUENCY:
 3 Monthly

 LOCATION:
 ST32 Gibson Island STP
 STD JOB ID:
 LTS062

Grease and Oils Required	Maintenance Group
Castrol AP3 Grease	Final Settling Tanks
Castrol EPL2 Grease	Service Water Pump Station
Castrol ALPHA SP220	·
Castrol Mollub Alloy 936SF Open Gear Grease	
, ,	
Reference	
Final Settling Tanks No,s 7,8,1A, 1B, 1C, 2A, 2B	& 2C.
Lubricate all wheel bearings (8 per tank) with 4 sho	
Lubricate centre column bearings with four shots of	
Greasing block located on the floor directly in front	of switchboard in the centre of the bridge.
Lubricate drive chain with Mollub Alloy 936SF Oper	n Gear Grease
Service Water Pumps	
Lubricate Service Water Pump Motors with 2 shots	of AP3 grease
Edonodic Cervice Water Fump Motors With 2 shots	or Ar o grodoc.

Doc Id:FOR705Active Date:15/3/2017Urban Utilities ConfidentialOwnerMatthew DellawayRevision:2Page 1 of 1

Note: Printed copies of this document should be verified for currency against the published electronic copy.