

 DESCRIPTION:
 6 Monthly Zone 2 Lubrication Maintenance
 FREQUENCY:
 6 Monthly

 LOCATION:
 ST012 Wynnum STP
 STD JOB ID:
 LTS014

Grease and Oils Required	Maintenance Group
Castrol Hyspin AWS68	MF Feed Pumps
Castrol ALPHA SP220	Degassing Towers
Castrol AP3 Grease	Product Water Pumps
	RO Feed Pumps
	MF CIP Pumps
	RO CIP Pumps
Reference	
Pumps: Suppliers Manual BWEA-VEN-R-660	03 Manual No: 26
MF Feed Pumps (2 of)	
Check Pump oil canisters. Check oil level and	d top up with Hyspin AWS68 if required
Lubricate motor bearings with 2 shots of AP3	
Degassing Towers (2 fans)	
Lubricate fan motors with 2 shots of AP3 grease.	
Lubricate fan bearings with 4 shots of AP3 gr	
9	
Product Water Pumps (3 of)	
Check Pump oil canisters. Check oil level and	d top up with Hyspin AWS68 if required.
Lubricate motor bearings with 2 shots of AP3	3 Grease.
RO Feed Pumps (3 of)	
Lubricate pumps bearings with 4 shots of AP3 Grease.	
Lubricate motor bearings with 2 shots of AP3	3 Grease.
MF CIP Pumps (2 of)	
Check Pump oil canisters. Check oil level and	d top up with Hyspin AWS68 if required.
Lubricate motor bearings with 2 shots of AP3	3 Grease.
RO CIP Pumps (2 of)	
Check Pump oil canisters. Check oil level and	
Lubricate motor bearings with 2 shots of AP3	3 Grease.

Doc Id:FOR756Active Date:13/3/2017Urban Utilities ConfidentialOwnerMatthew DellawayRevison:3Page 1 of 1

Note: Printed copies of this document should be verified for currency against the published electronic copy.