

| | | | |
|---------------------|--|--------------------------|--|
| DESCRIPTION: | Civil - SPS - Wet Well Airtight Seals Inspection | FREQUENCY: | |
| LOCATION: | | STANDARD JOB No.: | |

| |
|--|
| Equipment |
| Portable Gas Detector used for Confine Space Entry. |
| |
| Scope |
| To monitor the condition of seals on wet well entry points and covers. |
| The seals are to prevent foul air from wet well escaping into the atmosphere. |
| Inspection to be conducted on all entry points and covers to wet well fitted with seals. |
| Entry Points examples are, however not limited to, doors, access hinged covers, bolted down covers. |
| If condition of seal/covers/bolts is such replacement or repair is required, then create Work Request. |
| |
| |
| Wet Well Airtight Seals Inspection |
| |
| Bolted down covers. |
| Run gas detector around each cover for signs of escaping foul air. |
| Check condition of cover. |
| Check condition of bolts. |
| |
| |
| Access Points (doors, hinged covers, etc) |
| Run gas detector around each entry point for signs of escaping foul air. |
| Open each entry point and inspect condition of seals. |
| Check for deterioration. |
| Check for damage. |
| |
| |
| |
| |
| |
| |
| |
| |
| |