

DESCRIPTION:	SP10 Bi-Monthly Valve Exercise Program	FREQUENCY:	2 Weeks
LOCATION:	SP010 Eagle Farm and SP300 Serpentine Rd Pump Stations	STD JOB ID:	MSS059

Instructions
Operate valves through full range of motion to ensure proper operation.
Use CHE168 to submit results and report faults.
Use CHE168 to submit completion of work.
Valve Locations
Located on rising main at SP300 Serpentine Rd Sewage Pump Station:
VS37
VS38
Located at SP010 Eagle Farm Sewage Pump Station:
Rising Main Valves:
VS31
VS32
VS33
VS34
Inlet Penstocks:
PS1
PS2
Suction and Delivery Valves: (located at Sewer Pumps)
Pump 21
Pump 22
Pump 11
Pump 12
Pump 13
Pump Well Sump Pumps – Scour Valves.