



Dedicated to a better Brisbane

BRISBANE CITY COUNCIL BRISBANE WATER

SP306 – Coronation Drive Pump Station

Operation & Maintenance Manual Contract No. BW30079-02/03

Volume No. 4

BRISBANE CITY COUNCIL
Brisbane Water
SP306 Coronation Drive Pump Station

BCC Contract No. BW30079-02/03

Coronation Drive Pump Station - SP306 Operation & Maintenance Manual Table of Contents

Vol	Sect	Description	Pages
1		Table of Contents	5
		A complete electronic copy of the Operation & Maintenance Manual is available on CD Note: Click on the blue underlined Hyperlinks below to open the required document.	
1		Revision Control Coronation Drive O & M Manual	1
1		O&M Manual Changes Log	1
1	1	System Overview - Summary	
		HVAC Introduction and System Overview Including the following:- Introduction Description of Equipment and Process Design Details Design Criteria Process Design Operation Modes Modifications to Existing Plant	5
1	2	Pump Station Location	
		SP306 Location Map	1
1	3	Pump Station Equipment Operation	
		BW - Functional Specification (rev 1.01) for Coronation Drive Pump Station SP-306 (Note:- This is in addition to the standard functionality as described in Standard Functional Specification SPSV3)	14
		Including the following:- Introduction General Purpose Description Equipment Installed Control Philosophy Site Specific Values Non Standard Control	57
		HVAC-HPS Functional Specification	25

1.0 Introduction

1.1 Purpose

1.2 Scope

1.3 References

1.4 Abbreviations

1.5 Definitions

1.6 Assumptions

1.7 Constraints

1.8 Risks

1.9 Deliverables

1.10 Roles and Responsibilities

1.11 Approval

1.12 Revision History

1.13 Change Management

1.14 Document Control

1.15 Document History

1.16 Document Approval

1.17 Document Distribution

1.18 Document Archiving

1.19 Document Retention

1.20 Document Disposal

1.21 Document Access

1.22 Document Security

1.23 Document Integrity

1.24 Document Availability

1.25 Document Usability

1.26 Document Effectiveness

1.27 Document Efficiency

1.28 Document Economy

1.29 Document Sustainability

1.30 Document Compliance

1.31 Document Conformance

1.32 Document Consistency

1.33 Document Clarity

1.34 Document Conciseness

1.35 Document Coherence

1.36 Document Cohesion

1.37 Document Credibility

1.38 Document Reliability

1.39 Document Validity

1.40 Document Accuracy

1.41 Document Precision

1.42 Document Detail

1.43 Document Depth

1.44 Document Breadth

1.45 Document Length

1.46 Document Format

1.47 Document Style

1.48 Document Tone

1.49 Document Voice

1.50 Document Audience

1.51 Document Context

1.52 Document Purpose

1.53 Document Objectives

1.54 Document Outcomes

1.55 Document Impact

1.56 Document Value

1.57 Document Benefit

1.58 Document Cost

1.59 Document Risk

1.60 Document Opportunity

1.61 Document Challenge

1.62 Document Solution

1.63 Document Strategy

1.64 Document Plan

1.65 Document Action

1.66 Document Result

1.67 Document Feedback

1.68 Document Improvement

1.69 Document Innovation

1.70 Document Creativity

1.71 Document Originality

1.72 Document Uniqueness

1.73 Document Novelty

1.74 Document Freshness

1.75 Document Modernity

1.76 Document Relevance

1.77 Document Timeliness

1.78 Document Currency

1.79 Document Up-to-date

1.80 Document Current

1.81 Document Recent

1.82 Document Latest

1.83 Document Newest

1.84 Document Most recent

1.85 Document Latest version

1.86 Document Current version

1.87 Document Latest edition

1.88 Document Current edition

1.89 Document Latest release

1.90 Document Current release

1.91 Document Latest update

1.92 Document Current update

1.93 Document Latest revision

1.94 Document Current revision

1.95 Document Latest draft

1.96 Document Current draft

1.97 Document Latest working draft

1.98 Document Current working draft

1.99 Document Latest preliminary

1.100 Document Current preliminary

BRISBANE CITY COUNCIL
Brisbane Water
SP306 Coronation Drive Pump Station

BCC Contract No. BW30079-02/03

Coronation Drive Pump Station - SP306 Operation & Maintenance Manual Table of Contents

Vol	Sect	Description	Pages
2		Proprietary Equipment Manuals/Maintenance and Service	
2	1	Grundfos Pumps - Pump Testing ,Commissioning, Test Certificates OCT1 Oil Condition Transmitter, SAR12	
		Grundfos S2 Pump Operating Instructions	14
		Schedule C4 from Contract - Contractor Pump Guarantee	2
		Factory Acceptance Tests (FAT) - Pumps Including the following:-	
		<ul style="list-style-type: none"> • Workshop Tests Results • Pumps - Q&H Test Results - Workshop • Pumps - Operating Envelope • Pumps - Volute Casing Hydrostatic Test Reports • Electric Motors - Test Reports 	11
		OCT1 Oil Condition Transmitter Installation Instructions	4
		SARI 2 (Tritronics R.T.W.) Pump Insulation Resistance & Seal Oil Monitoring Device and Control Relay	2
		Pump Nameplate Details PDF Document or Word Document	1
2	2	GE Fanuc PLC Series 90™ - 30	
		GE Fanuc - PLC Series 90™ -30 Brochure	2
		GE Fanuc - PLC Series 90™ -30 Installation and Hardware Manual (Document Contained on CD-ROM Only)	445
		GE Fanuc - Series 90™ -30 Programmable Controller Troubleshooting Guide	18
		BW PLC Physical I/O List - Summary	3
		BW PLC Physical I/O List – Complete Excel Spreadsheet	18
		RTU Configuration / Settings	1
2	3	Cathodic Protection	
		Note: Cathodic Protection has not been installed at Coronation Drive Pump Station SP306	
2	4	Main Switchboard & Associated Equipment	
		Technical Manuals and Data Sheets	
		C191HM Powermeter and Harmonic Manager Installation & Operation Manual	60
		C191HM Powermeter and Harmonic Manager Modbus Communications Ref Guide	34
		Multitrode MTR Data Sheet	2
		Multitrode MTRA Data Sheet	2
		Multitrode MTR Wiring Diagrams	5
		Terasaki MCCB's and Contactors Technical Data Sheets	76
		Sprecher+Schuh / Terasaki & ACS Contactors Data Sheets	26
		Miniature Circuit Breakers - Earth Leakage Module Data Sheets	6
		Erico Surge Filter Installation Instructions	31
		Terasaki TemBreak Circuit Breaker BTS Schematic XMC Motor Operator	1
		Terasaki Transfer and Load Break Switches (Including Test Sheet and Schematic)	9
		Tyco Phase Fail Relay	2
		Sprecher+Schuh 22.5mm Pushbutton and Indicator Lights	5
		Eriflex Bus Bar Data Sheet / Brochure	12

Issue Date: May 2007 Rev 1

Page 2 of 5

29/05/07

G:\185 SEW_DRAIN\255 Des_Const\8890 Transport\S1 Luggage PT\SQSJ Redirect Heroes Ave (s1)\6
Implementation\Commissioning\O&MM Coronation Drive SP306\Table of Contents - SP306.doc

BRISBANE CITY COUNCIL
Brisbane Water
SP306 Coronation Drive Pump Station

BCC Contract No. BW30079-02/03

Coronation Drive Pump Station - SP306 Operation & Maintenance Manual Table of Contents

Vol	Sect	Description	Pages
		Matsushita NASI TH Hour Meter Data Sheet	1
		EMC Fans Data Sheet	2
		PowerHouse AC/DC Converter & API series DCDC Converter Data Sheets	2
		Vega Well 72 4-20mA Hart Pressure Transmitter Operating Instructions	48
		Vega Well 72 Pressure Transmitter Test Certificate	2
		Vega Vegadis 12 Adjustment Module for the Pressure Transmitter Operating Instructions	8
		Vega PLICSOM Indicating and Adjustment Module - Operating Instructions	19
		Vega Vegabar 64 4-20mA HART Pressure Sensor Operating Instructions	72
2	5	Variable Speed Drive Manuals and Parameter Settings	
		VFD Settings and Parameters	8
		Danfoss VFD (VLT® 6000 HVAC) Operating Instructions	170
		Danfoss VFD Instruction Manual Modbus RTU	33
2	6	ITP Procedure, Test Sheets and Factory Acceptance Tests	
		SAT - Switchboard Pre-Commissioning	13
		FAT - MPA Factory Acceptance Test - Switchboard - VSD Drives - Power Meter etc.	25
		Pump Pre-Commissioning Test Sheets	2
2	7	Valves	
		AVK Sluice Gate Valves	4
		Expert 600 Knife Gate Valve – Factory Test Certificate and Data Sheet	9
		Dobbie Dico Reflux Valves - Drawings	4
		TYCO RPZ-DCV 03 Maintenance Instructions	2
		TYCO RPZ-DCV 05 Maintenance Instructions	2
2	8	Pipes	
		TYCO Dismantling Joints - Data Sheets	5
		TYCO Flanged Fittings	7
		Uni-Flange Adapter Flange Series Catalogue	7
2	9	Wet Well Washer	
		McBerns Automatic Well Washer	3
2	10	Wet Well Lining System	
		Corrosion Protection Services (CPS) Sewerage Lining System.	10
2	11	Supplier Contact Details	
		Suppliers Index and Contact Information	3
2	12	Maintenance	
		Maintenance details as supplied by manufacturers / suppliers.	
		TYCO RPZ-DCV 03 Reduced Pressure Zone Double Check Valve Maintenance Instructions	2
		TYCO RPZ-DCV 05 Maintenance Instructions	2
		HVAC Operation and Maintenance Document	13

BRISBANE CITY COUNCIL
Brisbane Water
SP306 Coronation Drive Pump Station

BCC Contract No. BW30079-02/03

Coronation Drive Pump Station - SP306 Operation & Maintenance Manual Table of Contents

Vol	Sect	Description	Pages
3		Drawings	
		An electronic copy of all drawings is available on the CD-ROM.	
		As Constructed Drawings	
		<u>Electrical</u> – As supplied by the Contractor	17
		<u>Cable Schedule</u>	1
		<u>Civil</u> (Additional Pipework drawings 486/5/7-KJ025 to KJ028 available after registration)	3
4		Training / System Testing / Pre-Commissioning / Installation Method Statement / QA Records	
4	1	BW: Site Based Training	
		To be completed and added to manual	-
4	2	BW: System Integration Testing	
		<u>BW - Functional Specification (rev 1.01) for Coronation Drive Pump Station SP-306</u>	14
		<u>SAT - BW Site Acceptance Test Document NCS IDTS</u>	3
		<u>SAT - BW Site Acceptance Test Document NCS On-Site</u>	6
		<u>FAT - BW Factory Acceptance Tests IDTS NCS</u>	5
		<u>HVAC Pump Performance Testing Procedure</u>	3
		<u>HVAC-HPS Commissioning Plan - For Approval</u>	12
		<u>HVAC-HPS Switchboard Commissioning Functional Test Sheet - Incomplete</u>	2
		Stage 1 System Integration Testing Procedure	
		Redirection of Heroes Avenue Pump Station SP103	
		<u>Notes: Site Commissioning Work 19/20 & 21 February 2007</u>	36
		Stage 2 System Integration Testing Procedure	
		Coronation Drive Pump Station SP306 (New Rising Main) to North Quay Existing S1 Sewer Connection	
		<u>Notes: Site Commissioning Work Wednesday 14 March 2007</u>	35
		<u>Final Commissioning of SP306 carried out on Friday 27th April 2007</u>	2
4	3	Method Statements	
		<u>Method Statement</u> - HVAC-HPS - Procedure to carry out work	10
		<u>CPS Site Management Plan</u> - CPS Sewage Lining System	11
4	4	Installation QA Records / Test Reports	
		<u>HVAC/HPS Hydrostatic/Pneumatic Pressure Test Report- From pump base to valves</u>	2
		<u>HVAC-HPS Piping Checklist - Pre Hydro</u>	2
4	5	Certificates	
		<u>AS3000 Compliance Certificate</u> (Final Cert. Requested from HVAC - Gordon Waddell 20/04/07)	1
		<u>Vega Well72 Pressure Transmitter Test Certificates</u>	2
		<u>Vega BAR64 Pressure transmitter Test Certificate</u>	1
		<u>Grundfos Pump Hydrostatic and Motor Test Certificates</u>	4

BRISBANE CITY COUNCIL
Brisbane Water
SP306 Coronation Drive Pump Station

BCC Contract No. BW30079-02/03

Coronation Drive Pump Station - SP306 Operation & Maintenance Manual Table of Contents

Vol	Sect	Description	Pages
		Calibration Report for Pressure Gauge used during the HVAC/HPS Hydrostatic/Pneumatic Pressure Test	1
5		Appendices	
5	1	Extras	
		Manual covers for the printed version	5
		Manual spine labels for the printed version	2
		Operation & Maintenance Manual CD Cover	1
		Drawings CD Introduction Page	1

VOL 4 SECT 2

PASTEL
MANILLA
DIVIDERS
5 TAB A4



Ref. No. 37000
Made in China
Distributed by ACCO Australia



9 312311 370002

BRISBANE WATER
Network Control Systems

FUNTIONAL SPECIFICATION
SP306 Coronation Drive
Sewage Pumping Station
Submersible 2 Pumps With VSD
(Wet Weather Station)

Document Signoff

Approval

	Name	Role	Signature	Date
Manager Mechanical and Electrical Services <i>Engineering Design Services</i>	Rahim Janfadeh	Concur		
Manager <i>Water And Watewater Operations Manager</i>	Anu Atukorala	Concur		
Team Leader <i>Network Control Systems</i>	Peter Sherriff	Concur		
Manager <i>System Planning</i>	Peter Casey	Concur		
Project Manager	Andrew Bannink	Approve		

Distribution

Name	Role	Section

Revision Control

Revision Number	Date	Amendment Details	Responsible Officer
Version 0.00	16/08/2005	Original Draft – Developed from Connell Wagner SP306 Revised Functional Spec	Alex Witthoft
Version 0.01	25/7/06	Updated approval sheet, removed flowmeter reference.	Gerard Anderson
Version 0.02	2/8/06	Updated approval sheet, Pump kW, picture details.	Gerard Anderson
Version 0.03	21/8/06	Updated confirmed sewer surcharge level and surcharge imminent level for SP306 (Noel Ralph). Station changed to Stop/Start at 50Hz (RM). Added Gravity Sewer alarm level diagram. Set High Level setpoint to 0.4M above TWL. Set pump inhibit limits to 200 and 400mm below Surcharge Imminent	Gerard Anderson
Version 1.00	14/3/2007	Site commissioned. Added level ranges.	Gerard Anderson
Version 1.01	27/4/2007	Added Bump Pumps Functionality ie run pumps every 3 days for 30 seconds to prevent seizing.	Gerard Anderson

Document Consultation

Please review the attached document and add your comments where necessary. To ensure that the process is kept within reasonable timeframes, it would be appreciated if you could return this document by the **Requested Return Date** listed below.

Project Sponsor: Andy Moore

Officer Code: PM13BW

Location: T.C.B. Level 2

Author: Alex Witthoft/
Gerard Anderson

Officer Code: CTAMP12/
E2SBW

Location: Cullen Ave

Document Administrator: Gerard Anderson

Officer Code: E2SBW

Location: Cullen Ave

Version Number (1,2,3 etc)	Forwarded To: (Name / Officer Code)	Location (eg.TCB, Cullen Ave)	Date Sent	Requested Return Date	Date Returned	Comments Received (Y / N)	Comments Incorporated (Y / N)
PLEASE RETURN THIS DOCUMENT TO THE ABOVE DOCUMENT ADMINISTRATOR							
DO NOT SEND IT ANYWHERE ELSE!							

Table of Contents

1	INTRODUCTION.....	5
1.1	GENERAL PROCESS DESCRIPTION.....	6
2	EQUIPMENT INSTALLED	7
2.1	STANDARD EQUIPMENT.....	7
2.2	NON STANDARD EQUIPMENT	7
2.2.1	<i>Emergency Generator</i>	<i>7</i>
2.2.2	<i>Gravity Sewer Monitoring.....</i>	<i>7</i>
3	CONTROL PHILOSOPHY	8
3.1	SITE SPECIFIC VALUES	9
3.2	NON STANDARD MONITORING AND ALARMS.....	11
3.2.1	<i>Gravity Sewer Level</i>	<i>11</i>
	Invalid	12
	Low Alarm	12
	High Alarm.....	
3.3	NON STANDARD IDTS PICTURE.....	13
3.4	SEWER NETWORK OVERVIEW	13
4	REFERENCES.....	14

Table of Figures

Figure 1:	SP306 Location Map	5
Figure 2:	SP306 Process and Instrumentation Overview.....	6
Figure 3:	SP306 Station Level Set Points.....	8
Figure 4	SP306 Details Page.....	13

Table of Tables

Table 1:	Site Specific Constants defined in the PLC	9
Table 2:	Site Specific Constants defined in the RTU.....	9
Table 3:	Site Specific Variable defined in the RTU.....	9
Table 4:	Wet Well Level vs Volume Data.....	10

Definitions

BWTS	Brisbane Water Telemetry System
RTU	Remote Telemetry Unit
SCADA	Supervisory Control And Data Acquisition
MAHD	Metres above Australia Height Datum

1 INTRODUCTION

This document contains the site specific details and describes the non standard functional requirements for control, monitoring and telemetry at sewage pump station SP306 at Coronation Drive, Toowong, opposite Patricks Lane. The functional requirements described in the document are in addition to the standard functionality detailed in “SPSV3 SEWAGE PUMPING STATION SUBMERSIBLE 3 PUMPS WITH VFD”¹.

The standard specification was written for a 3 pump station, of which only 2 pumps are allowed to run at any given time. The functionality for SP306 Coronation Drive is identical, except the third pump is removed. The pumps are interlocked so that only one pump can operate at a time. All site specific values are detailed in this document. The site specific details and the non standard functional requirements in this document were derived from the functional specification written by Connell Wagner “PATRICK LANE FUNCTIONAL SPECIFICATION”².

SP306 Coronation Drive sewage pump station is required to relieve the surcharging in the Coronation Drive gravity sewer. Under wet weather flow conditions, the gravity sewer is susceptible to surcharge and overflows to the environment. . SP306 Coronation Drive is therefore wet weather sewage pump station only, incorporating two variable speed driven 65 kW submersible pumps operating in a one duty and one standby arrangement




Figure 1: SP306 Location Map

1.1 General Process Description

SP306 Coronation Drive pump station will be connected to the gravity sewer via a short inlet. During wet weather events the sewage will flow into the well. This sewage will then be pumped into the rising main. This will continue until the level in the gravity sewer has receded, at which point the pumps shall stop under level control.

The sewage Pumping Station is of underground configuration operating in wet weather conditions only, with a wet well operating volume (under surcharge) of approximately 10 kl. The pump station will operate as a surcharge pump station, only allowing flows into the wet well during periods of surcharge in the adjacent gravity sewer. The wet well will be free to drain back into the gravity sewer at the end of the surcharge event. The pump station will have two submersible type sewage pumps installed in the Pump Well operating as duty/standby units. The pumps are interlocked so that only one pump can operate at a time. The station output with one pump operating at maximum speed will be approximately 150 l/sec.

This pump station will operate as a stop/start station only, there will be no PID control at this site. Pump speed will be limited to 50Hz, this is designed to pump down the Wet Well as quickly as possible.




Figure 2: SP306 Process and Instrumentation Overview

2 EQUIPMENT INSTALLED

2.1 Standard Equipment

SP306 Coronation Drive pump station has the following standard equipment installed. The functionality for the control, monitoring and alarming for these items is fully described in the standard functional specification.

Pumps	Two Grundfoss submersible pumps with 65 kW four pole electric motors are installed in the wet well. Each pump is fitted with moisture probes in the oil chamber and thermistors in the stator windings.
Pump Starters	Two Danfoss Variable Frequency Drives (VFDs) are installed in the pump station switchboard. The VFDs will also provide soft starting functionality.
Level Sensors	One Vega hydrostatic level transmitter installed in the wet well. One Multitrode level probe (Surcharge imminent) installed in the wet well.
Pressure Transmitters	One Vega D84 pressure transmitters are installed on the discharge side of the pumps.

2.2 Non Standard Equipment

SP306 Coronation Drive pump station has the following non standard equipment installed. The functionality for the control, monitoring and telemetry for is described in the following sections as these items are NOT described in the standard specification. The pumps are interlocked so that only one pump can operate at a time.

Emergency Generator	The switchboard will have the facility for a generator to be connected. No generator will be installed on site.
Level Sensors	One Vega hydrostatic level transmitter installed in the gravity sewer One Multitrode level probe (Gravity Sewer High) installed in the gravity sewer
Reflux Limit Switches	Each pumps reflux valve has a reflux limit switch fitted. NB There is no flowmeter onsite.
Wet well washer solenoid	Well washer solenoid valve with flow switch installed in the wet well. Note that there is currently no water supply to the Wet well washer. The Wet Well washer will not be commissioned at this stage.

2.2.1 Emergency Generator

The emergency generator is designed to the standard functionality as described by "DIESEL STANDBY GENERATOR LOCAL CONTROL PANEL FUNCTIONAL DESCRIPTION".³ The generator is supplied with the PLC fully configured and loaded with the standard program. The RTU (Logica MD3311) will programmed with the standard interface program that will provide the monitoring, control and telemetry to the BWTS master station.

2.2.2 Gravity Sewer Monitoring

The gravity sewer will also have monitoring in the form of a vega hydrostatic level transmitter as well as a gravity high multitrode electrode.

3 CONTROL PHILOSOPHY

The station will operate according to the control philosophy detailed in the standard functional specification (SPSV3).

The initialisation block will be configured with the site specific set points listed in the tables in the next sections.

Surcharge Occurring & Surcharge Imminent mAHD will be the same levels as the gravity main setup (confirmed with Noel Ralph). There is no physical surcharge pipe at SP306. Inlet level of pipe from gravity main to wet well is IL - 3.790.




Figure 3: SP306 Station Level Set Points

3.1 Site Specific Values

Table 1: Site Specific Constants defined in the PLC

Tag Name	Description	Type	Value	Units
Sewerage Pumping Station				
Stn01grSurchPumpingTime	Surcharge pumping duration ³	Integer	60	Sec
Delivery pressure				
Pre01txRange	Delivery pressure - Range	Real	5000	mmAHD/10
Pre01txZero	Delivery pressure – Elevation of the transducer	Real	273	mmAHD/10
Pump Blockage				
Stn01grPmpBlockFlowKneeSP	Flow blocked limit for flow/level PID control (knee)	Integer	N/A	l/s x 100
Stn01grPmpBlockSpeedKneeSP	VFD speed blocked limit for flow/level PID control (knee)	Integer	N/A	Hz x 100
Stn01grPmpBlockSpeedMinSP	VFD speed blocked limit for minimum flow PID control	Integer	N/A	Hz x 100
Wet well level				
Wwl01txRange	Wet well level range	Integer	10	mmAHD
Wwl01txSurchImmLevelSP	Wet well surcharge imminent level (300mm below Overflow #330 Coronation Drive "Oxleys on the River" Surcharge point of 0.070 MAHD)	Integer	-0.230	mmAHD
Wwl01grInhStartLevelSP	Wet well inhibit mode start level	Integer	-0.430	mmAHD
Wwl01grInhStopLevelSP	Wet well inhibit mode stop level	Integer	-0.630	mmAHD
Wwl01grRunatMaxLvISP	Wet well run at maximum speed level	Integer	N/A	mmAHD
Wwl01txDtyBStartLevelSP	Wet well duty B pump start level	Integer	N/A	mmAHD
Wwl01txPIDLevelSP	Wet well PID set point	Integer	-2200	mmAHD
Wwl01txDtyAStartLevelSP	Wet well duty A pump start level	Integer	-2500	mmAHD
Wwl01txDtyAStopLevelSP	Wet well duty A pump stop level	Integer	-3160	mmAHD
Wwl01txDtyAStopLevelSP	Wet well duty A pump stop level	Integer	-3160	mmAHD
Wwl01txZero	Wet well empty level (4mA of Probe)	Integer	-3580	mmAHD
Variable Frequency Drive				
Stn01grMinSpeed	Variable Frequency Drive – Minimum Speed	Integer	5000	Hz x 100
Stn01grMaxSpeed	Variable Frequency Drive – Maximum Speed	Integer	5000	Hz x 100

Table 2: Site Specific Constants defined in the RTU

Tag Name	Description	Type	Value	Units
prelalmInhibitTm	Delivery pressure - Alarm inhibit timer	Integer	15	sec
wwl1surchLvIVol	Wet well volume at surcharge level	Real		kl
wwl1lvISurcharge	Wet well surcharge occurring level	Real	0.070	mAHD
Pumps 1 & 2				
Pmp[x]almInhPwrTm	Pump [x] - Motor power alarm inhibit timer.	Integer	15	sec
pmp[x]almInhCmtTm	Pump [x] - Motor current alarm inhibit timer.	Integer	15	sec
pmp[x]currRange	Pump [x] - Motor current range	Real	120.0	Amps

Table 3: Site Specific Variable defined in the RTU

Wet well level				
wwl1highLimit	Wet well level - High alarm set point	Integer	-2.100	mmAHD
wwl1lowLimit	Wet well level - Low alarm set point	Integer	N/A	mmAHD
Delivery flow				
flw1highLimit	Delivery flow - High alarm set point	Integer	N/A	ml/s x 10
flw1lowLimit	Delivery flow - Low alarm set point	Integer	N/A	ml/s x 10
Delivery pressure				
prelhighLimit	Delivery pressure DN1370 – High alarm set point	Integer	Max	mmAHD
prellowLimit	Delivery pressure DN1370 – Low alarm set point	Integer	Min	mmAHD
Pumps 1 & 2				
pmp[x]currHiLimit	Pump [x] - Motor current high alarm set point ⁴	Integer	130	Amps
pmp[x]currLoLimit	Pump [x] - Motor current low alarm set point ⁵	Integer	130	Amps
pmp[x]powHiLimit	Pump [x] - Motor power high alarm set point	Integer		Watts
pmp[x]powLoLimit	Pump [x] - Motor power low alarm set point	Integer		Watts

Table 4: Wet Well Level vs Volume Data


	Height (mAHD)	Volume m ³	Remaining Storage m ³	% Level	% Volume
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					

3.2 Non Standard Monitoring and Alarms

3.2.1 Gravity Sewer Level

As the Vega probe takes a few seconds to initialise, all the wet well alarms except for invalid, are suppressed for 10 seconds upon RTU start up

Gravity Sewer	Invalid	1
Gravity Sewer	Patricks Lane Surcharge Occuring alarm	1
Gravity Sewer	Patricks Lane Overflow Warning High_high alarm	1
Gravity Sewer	330 Coronation Drive Oxleys on the River" Surcharge Occuring alarm	1
Gravity Sewer	330 Coronation Drive Oxleys on the River" Overflow Warning High alarm	1



Invalid

The signal is deemed invalid if it is :

Less than (4mA – dead band) or greater than (20mA + dead band) for 1 second.

Once the invalid alarm has been activated it can only be reset when the signal is both greater than 4mA and less than 20mA for 20 seconds. The time delays ensure that a signal is truly invalid before an alarm is set and that it is stable before it is reset. The dead band is calculated using the site invalid hysteresis value multiplied by the range.

If the gravity sewer level becomes invalid, the gravity sewer low and high alarm alarms are suppressed.

NOTE: As the wet well level is backed up by the battery – the site power does not suppress the invalid alarm.

Low Alarm

If the signal is valid and the start up delay has expired then the low alarm is activated if the signal is less than the low limit set point. It is deactivated if any of the above conditions become false or the signal is greater than the low limit set point plus the dead band. The dead band is calculated using the alarm hysteresis value multiplied by the range.

High Alarm

If the signal is valid and the start up delay has expired then the high alarm is activated if the signal is greater than the high limit set point. It is deactivated if any of the above conditions become false or the signal is less than the high limit set point minus the dead band. The dead band is calculated using the alarm hysteresis value multiplied by the range.

3.2.2 Bump Pumps Routine

Each sewer pump will be requested to run for 30 seconds every 3 days to prevent the pumps from seizing. The pumps will be run regardless of wet well level. The RTU will check if a pump has not run within 48 hours or if either pump is inhibited before initiating the bump pump routine.

3.3 Non Standard BWTS Picture




Figure 4 SP306 Details Page

3.4 Sewer Network Overview

The sewer network overview page will be updated to include the gravity sewer at Coronation drive pumping into the new S1 rising main at Coronation drive.

4 REFERENCES

1

TITLE	SPSV3 Sewage Pumping Station Submersible 3 Pumps With VFD – Functional Specification
DOCUMENT ID	003589
VERSION	0.30
AUTHOR	Alex Witthoft , Brisbane Water – Network Control Systems
DOCUMENT OWNER	Peter Sherriff, Brisbane Water – Network Control Systems

2

TITLE	Heroes Avenue Functional Specification
DOCUMENT ID	N/A
VERSION	N.A
AUTHOR	N.A
DOCUMENT OWNER	Cardino Davies Pty Ltd

3

TITLE	Diesel Standby Generator - Local Control Panel - Functional Description
DOCUMENT ID	N/A
VERSION	02
AUTHOR	SOUTH EAST POWER GENERATION
DOCUMENT OWNER	



BRISBANE WATER

Network Control Systems

SITE ACCEPTANCE TEST (SAT)

TEST DOCUMENT (On Site)

SP306 Coronation Dr

Submersible 2 Sewage Pumping Station

Pumps With VSD and Sewer Level

Project & Commissioning Details

Date Commissioned	14/03/2007 + 27/4/07
Project Manager	Reg McGirr
Construction Manager	Bill Collie
Electrical Inspector	
RTU Programmer	G. Anderson
Electricians	Andrew Graham

Two Pump Submersible Sewerage Pump Station
SITE ACCEPTANCE TEST

Brisbane Water - Network Control Systems

IDTS COMMISSIONING TEST SHEET

SP306

CORONATION DR

The purpose of these tests is to confirm that the new RTU is running and responding to inputs and sending data back to the IDTS master station.

- Notify Control Room that site is being commissioned - ph 340 78414
- Contact IDTS Test Room ph 3407 8477 to confirm receipt of alarms

Action	Observation	Result
Site in remote mode Switch on RTU power	Confirm that RTU ABNORMAL OPERATION alarm is received by IDTS Confirm that operator adjustable alarm setpoints are downloaded on RTU restart.	<input checked="" type="checkbox"/> Yes <input checked="" type="checkbox"/> Yes
Cycle the Energex power	Confirm that Energex Power Alarm is received by IDTS and <u>no other alarms</u> [alarm suppression] are sent. Ensure that the Generator Starts and transfers before the site mains fail alarm activates	<input checked="" type="checkbox"/> Yes
Switch off RTU mains power	Confirm that RTU MAINS FAIL alarm is received by IDTS.	<input checked="" type="checkbox"/> Yes
Test operation of all pumps in REMOTE mode (Manual)	Each pump starts and stops when commanded by the IDTS picture controls	<input checked="" type="checkbox"/> OK
Activate the probe itself to produce the surcharge imminent alarm.	Confirm that 2 pumps start <u>1 pump starts</u> Confirm that SURCHARGE IMMINENT alarm is received by IDTS	<input checked="" type="checkbox"/> Yes <input checked="" type="checkbox"/> Yes
Switch site to LOCAL and STOP pumps Wait until surcharge pumping timer expires (Record Time). Open Valve 1 via the push buttons.	Confirm that LOCAL mode alarm is received by IDTS	<input checked="" type="checkbox"/> Yes
Test operation of all pumps in LOCAL mode.	Each pump starts and stops when commanded by the site pushbuttons.	<input checked="" type="checkbox"/> OK
Site in Remote mode, RTU operating Test operation of the pump inhibit.	Apply pump inhibit to each pump and confirm that "station inhibit" is active	<input checked="" type="checkbox"/> OK
Fault Pump 1 <i>Note: not every point that causes an availability alarm is tested, as this linkage is proved by SPSS2 standard code and FAT of switchboard</i>	Confirm Availability alarm is received by IDTS. Look at the points page and confirm the reason for the fault. Send a remote reset to clear the fault	<input checked="" type="checkbox"/> OK <input checked="" type="checkbox"/> OK <input checked="" type="checkbox"/> OK
Fault Pump 2	Confirm Availability alarm is received by IDTS. Look at the points page and confirm the reason for the fault. Send a remote reset to clear the fault	<input checked="" type="checkbox"/> OK <input checked="" type="checkbox"/> OK <input checked="" type="checkbox"/> OK
Trigger Wet Well Surcharge Occurring Alarm	Confirm alarm is received by IDTS	<input checked="" type="checkbox"/> OK
Trigger Wet Well High alarm	Confirm alarm is received by IDTS	<input checked="" type="checkbox"/> OK
Trigger Wet Well Invalid Alarm	Confirm alarm is received by IDTS	<input checked="" type="checkbox"/> OK
Allow well to fill.	Observe that the duty pump starts and stops. Only need to test for 1 pump on a slow filling site. Confirm that IDTS is receiving the correct wet well level (%).	<input checked="" type="checkbox"/> Yes <input checked="" type="checkbox"/> Yes
Pump start and stop values shown on the wet well label match the IDTS picture	Duty A start <u>11</u>% Duty A stop <u>4</u>%	

SAT
Site FAT by (RTU Programmer)

Pre-commissioning Test Sheet checked by NCS Project Officer

Name: Gerald Anderson

Name:

Signature: [Signature]

Signature:

Date: 27/4/07

Date:

Two Pump Submersible Sewerage Pump Station
SITE ACCEPTANCE TEST

Brisbane Water - Network Control Systems

GRAVITY SEWER LEVEL

Action	Observation	Result
Calibrate the Sewer Level	Ensure the Level is the same in the Code as in IDTS	<input checked="" type="checkbox"/>
IDTS Points	Level (mAHD)	<input checked="" type="checkbox"/>
	Invalid	<input checked="" type="checkbox"/>
	High + High High	<input checked="" type="checkbox"/>
	Low	<input checked="" type="checkbox"/>
	High Limit	<input checked="" type="checkbox"/>
	Low Limit	<input checked="" type="checkbox"/>
	High Limit Fbk ✓	<input checked="" type="checkbox"/>
	Low Limit Fbk	<input checked="" type="checkbox"/>
	Range Fbk	<input checked="" type="checkbox"/>
	Zero Fbk	<input checked="" type="checkbox"/>

GRAVITY SEWER LEVEL

Action	Observation	Result
Trigger the Electrode	Ensure the Sewer level high high alarm is activated	<input checked="" type="checkbox"/>
IDTS Points	High High Alarm	<input checked="" type="checkbox"/>
	Calibration Fault	
	Calibration Fault Reset	

Generator connected + running

RTU Indication

stn 1 Main CB Closed = No

stn 1 Mains Power = Yes

stn 1 gen Online = Yes

stn 1 energex Fail = Yes

gen 1 connected = Yes

Site FAT by (RTU Programmer)

Name: Gerard Andersic

Signature: 


Date: 27/4/07

Pre-commissioning Test Sheet checked by NCS Project Officer

Name:

Signature:

Date:



BRISBANE WATER

Network Control Systems

FACTORY ACCEPTANCE TEST (FAT) TEST DOCUMENT

SP306 Coronation Drive Submersible 2 Sewage Pumping Station Pumps With VSD, 1 Valves & Mobile Generator Capability

Project & Commissioning Details

Date Commissioned	
Project Manager	
Construction Manager	
Electrical Inspector	<i>Peter Hague</i>
RTU Programmer (NCS)	<i>Alex Wittkott / Geoff Timmins</i>
Electricians	

SP306Two Pump Submersible Sewerage Pump Station
FACTORY ACCEPTANCE TEST

Brisbane Water - Network Control Systems

FAT TEST (FOR ELECTRICAL INSPECTOR)

SP306 CORONATION DRIVE

This check list is to be performed before the official IDTS commissioning of the sewerage pump station.

CABINET

Task	Outcome
Check that locks are fitted on all doors and keyed correctly.	OK <input checked="" type="checkbox"/>
Check that the Power Supply, Radio and RTU have their lights visible	OK <input checked="" type="checkbox"/>
The heat shield are to be attached via welding NOT drilling through the board.	OK <input checked="" type="checkbox"/>
Drawing Sheet pouch to be attached on the RTU cubicle door	OK <input type="checkbox"/> <i>Not be done</i>
90mm gap above and below the RTU (to allow for cables from laptop to be plugged into the ports)	OK <input checked="" type="checkbox"/>
Gland plate in the PLC cubicle (cables such as aerial, phone line, surcharge imminent electrode).	OK <input checked="" type="checkbox"/>
Check that the limit switch works and turns off when the doors are closed.	OK <input type="checkbox"/> <i>Generate for cubicle 9w fault on security</i>
Check that Energex meter lock is fitted on the meter box.	OK <input type="checkbox"/>
Red Indicator Line on the Wet Well Indicator	OK <input checked="" type="checkbox"/>
Antenna Pole is Hinged	OK <input checked="" type="checkbox"/>
Caps on the lifting points – and adequately sealed	OK <input checked="" type="checkbox"/>
No means of Gas Ingress	OK <input checked="" type="checkbox"/>
No 240VAC in the RTU section	OK <input checked="" type="checkbox"/>
Perform a physical inspection of the site and switchboard to determine if it is safe. Note any defect on the Defect notification sheet.	OK <input checked="" type="checkbox"/>
Note any defects in switchboard.(On Defect Sheet)	

POINT TO POINT

Task	Outcome
Using the Electrical Drawing do a thorough point to point on the control circuit to ensure that the local control of the pump operates independantly of the RTU (ie Part of the PLC) Wired to the RTU/PLC from beginning to end. (ie press the actual button and watch the I-O change in Isagraf / Versapro). The Drawings should be marked up with any changes to provide the AS BUILT markups (in conjunction with any modifications made during Site Acceptance Testing). (All circuits should be 'highlighted' as they are checked.	OK <input checked="" type="checkbox"/>

VARIABLE SPEED DRIVE

Task	Outcome
Check that the motor starter is programmed and able to start the each pump	Pmp1-OK <input checked="" type="checkbox"/> Pmp2-OK <input checked="" type="checkbox"/>
Check that each VSD modbus connection active and that the Power and Current are being read correctly and are scaled correctly.	Pmp1-OK <input checked="" type="checkbox"/> Pmp2-OK <input checked="" type="checkbox"/>

Site pre-commissioned by (Electrical Inspector)

Pre-commissioning Test Sheet checked by NCS Project Officer

Name:
Signature: *BT*
Date:

Name:
Signature: *OF*
Date: *27/5/8*

Doc Id: Active Date: July 2004 Brisbane Water Confidential
Printed: 28/04/2005 Owner: Peter Sherriff Page 2 of 4
Note: Printed copies of this document should be verified for currency against the published electronic copy.

SP306Two Pump Submersible Sewerage Pump Station
FACTORY ACCEPTANCE TEST

Brisbane Water - Network Control Systems

FUNCTIONALITY TESTING OF VFD

The following test should be carried out once a full point to point test has been completed and the VFD drives have been completely configured.

NOTE: the VFD drive has 2 setups – local and remote – both of which are configurable. To ensure full functionality, the test below are often repeated for both local and remote mode.

Task	VFD 1	VFD 2
Local/Remote Mode Setup Selection: <i>When the station local-remote selector switch is selected to</i> <ol style="list-style-type: none"> 1. Remote that setup 1 is active on both Drives 2. Local setup 2 is active on both Drives 	<input checked="" type="checkbox"/> <input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> <input checked="" type="checkbox"/>
Drive in Auto Mode: In both local and remote modes repeat the following: <ul style="list-style-type: none"> <input type="checkbox"/> Ensure that the Auto mode is active <i>Press the "Hand Start" button on the keypad</i> <ul style="list-style-type: none"> <input type="checkbox"/> Ensure that the Auto mode feedback deactivates <i>Press the "Auto Start" button on the keypad</i> <ul style="list-style-type: none"> <input type="checkbox"/> Ensure that the Auto mode is active 	<input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/>
Run Command, Speed Control and Speed Feedback, Run at Maximum In Remote: – Setup 1 - DO FOR BOTH PUMPS SEPERATLY <i>Command the pump to run via the digital output from the PLC.</i> <ul style="list-style-type: none"> <input type="checkbox"/> Ensure that the VFD runs and the running signal is received from by the PLC. <input type="checkbox"/> Ensure that the VFD speed is controlled by the PLC Analog output. <input type="checkbox"/> Ensure that the speed of the pump from the VFD to the PLC is accurate. <input type="checkbox"/> Ensure that the Maximum Speed is 50Hz (or whatever the current design max is). <i>Checking interlock is OFF</i> <i>Initiate Surge Pumping mode.</i> <ul style="list-style-type: none"> <input type="checkbox"/> Ensure that both pump are commanded to run at maximum speed and that the run at max is active. <i>Stop Surge Pumping mode but activate duty A and then Duty B start commands</i> <ul style="list-style-type: none"> <input type="checkbox"/> Ensure that the duty A and then the duty B pumps are commanded to run at the PID speed control and that the speed feedback is accurate. <i>Set the Drive to run in remote at minimum speed, then force the run at max output.</i> <ul style="list-style-type: none"> <input type="checkbox"/> Ensure that the drive runs at maximum speed. 	<input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/>
In Local: Setup 2 - DO FOR BOTH PUMPS SEPERATLY <i>Command the pump to run via the start pushbutton (output from the PLC)</i> <ul style="list-style-type: none"> <input type="checkbox"/> Ensure that the VFD runs and the running signal is received from by the PLC. <input type="checkbox"/> Ensure that the VFD speed is controlled by the POT. <input type="checkbox"/> Ensure that the Maximum Speed is 50Hz (or whatever the current design max is) <input type="checkbox"/> Ensure that the speed of the pump from the VFD to the PLC is accurate. <i>Checking interlock is OFF - Try to start 2nd pump</i> <ul style="list-style-type: none"> <input type="checkbox"/> Ensure that it gets commanded to run and does so <i>Set the Drive to run in local at minimum speed, then force the run at max output.</i> <ul style="list-style-type: none"> <input type="checkbox"/> Ensure that the drive DOES NOT runs at maximum speed. 	<input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> <input checked="" type="checkbox"/>
VFD Ready / Thermistor Fault / Reset: Repeat the following for both local and remote modes <i>Trigger the thermistor fault. Used programmed fan has no thermistors</i> <ul style="list-style-type: none"> <input type="checkbox"/> Ensure that the VFD ready signal deactivates (fault). <i>Re-enable the thermistor and ensure that the VFD is still not ready.</i> <i>Activate the reset output from the PLC.</i> <ul style="list-style-type: none"> <input type="checkbox"/> Ensure that the VFD resets. 	<input checked="" type="checkbox"/> <input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> <input checked="" type="checkbox"/>

Doc Id:

Active Date: July 2004

Brisbane Water Confidential

Printed: 28/04/2005

Owner: Peter Sherriff

Page 4 of 4

Note: Printed copies of this document should be verified for currency against the published electronic copy.

SP306Two Pump Submersible Sewerage Pump Station
FACTORY ACCEPTANCE TEST

Brisbane Water - Network Control Systems

FAT TEST (RTU PROGRAMMER)

SP306

COROANTION DRIVE

RTU

Task	Outcome
Check that the RTU has the correct IP address set	IP Address <u>192.168.34.95</u> Subnet mask <u> </u>
Check that the RTU has the correct program code loaded	Code Name <u>SP306-X7</u>
Check CPU Firmware Version and Serial Number	Serial Number <u>1004.3441</u> Firmware Ver <u>1.0.4</u>
Check that the .main file has been downloaded from the IDTS	OK <input type="checkbox"/> <u>No</u>

POINT TO POINT

Task	Outcome
Using the Physical I-O Spreadsheet check each individual physical I-O Wired to the RTU from beginning to end. ie press the actual button and watch the I-O change in Isagraf. Output lights and relays activate Inject 4-20mA into the Analog Inputs. The I-O spreadsheet should be ticked and signed by the test and attached to this FAT Test Document.	OK <input checked="" type="checkbox"/>

BATTERY

Task	Outcome
Check that the battery is connected and charging (i.e. 24V across the terminals).	OK <input checked="" type="checkbox"/>
Check that the RTU is running off battery when the mains supply is isolated	OK <input checked="" type="checkbox"/>

RADIO

Task	Outcome
Check that the correct radio type has been installed - high or low (transmit frequency)	High <input type="checkbox"/> Low <input type="checkbox"/>
Check that radio is set on the correct frequency for the desired base station.	Tx MHz Rx MHz Base Station:

Site FAT by (RTU Programmer)

Pre-commissioning Test Sheet checked by NCS Project Officer

Name:
Signature:
Date:

Name:
Signature: GT
Date: 27/5/05

Doc Id: Active Date: July 2004 Brisbane Water Confidential
Printed: 28/04/2005 Owner: Peter Sherriff Page 3 of 4
Note: Printed copies of this document should be verified for currency against the published electronic copy.

5.2 Pump Performance Testing

5.2.1 Purpose

The purpose of this test is to verify performances of the pumps are valid for the pump curves specified for the contract, and supplied by the manufacturer.

5.2.2 Scope

Grundfos will attend the test and verify all pumps satisfy the latest pump selection schedule/curve (dated 02/07/2004) and factory certifying documents. Copies of these documents are attached. Data taken from the tests would be used to draw up site pump curves.

All tests will be conducted in LOCAL mode to allow manual start/stop of the pumps, while hand start/stop of the VSDs would be required to run pumps at the desired speeds. The following data shall be recorded on the Pump Performance Testing Record to verify performance conforms to pump curves and specifications:

- Speed (in Hz)
- Current (in A)
- Power (in kW)
- Delivery (in L/sec)
- Pressure (in m)
- Well Level at operation (% / mAHD)

The pumps shall be tested and verified to the following points:

- A 4 points tested at 50Hz on each pump
- B 2 points tested at 40Hz on each pump
- C 3 points tested at 32,5Hz on each pump

5.2.3 Procedures

A. 50Hz 4 points testing

1. Record wet well level.
2. Set discharge throttling valve fully open.
3. Start **Pump 1** and ramp to maximum speed **50Hz**.
4. With the discharge throttling valve fully open, record Q & H.
5. Close discharge throttling valve to a flow of **200L/s**, run for 10 minutes to let it settle, record readings.
6. Close discharge throttling valve to a flow of **100L/s**, run for 10 minutes to let it settle, record readings.
7. Close discharge throttling valve to a flow of **150L/s**, run for 10 minutes to let it settle, record readings.
8. Close discharge throttling valve to a flow of **50L/s**, run for 10 minutes to let it settle, record readings.
9. Shut down Pump 1 and repeat same process for Pump 2.

B. 40Hz 2 points testing

1. Record wet well level.
2. Set discharge throttling valve fully open.
3. With the discharge throttling valve fully open, record Q & H.
4. Start **Pump 1** and ramp to speed **40Hz**.
5. Close discharge throttling valve to a flow of **150L/s**, run for 10 minutes to let it settle, record readings.
6. Close discharge throttling valve to a flow of **100L/s**, run for 10 minutes to let it settle, record readings.
7. Shut down Pump 1 and repeat same process for Pump 2.

C. 32.5Hz 4 points testing

1. Record wet well level.
2. Set discharge throttling valve fully open.
3. With the discharge throttling valve fully open, record Q & H.

4. Start **Pump 1** and ramp to speed **32,5Hz**.
5. Close discharge throttling valve to a flow of **150L/s**, run for 10 minutes to let it settle, record readings.
6. Close discharge throttling valve to a flow of **100L/s**, run for 10 minutes to let it settle, record readings.
7. Close discharge throttling valve to a flow of **50L/s**, run for 10 minutes to let it settle, record readings.
8. Shut down Pump 1 and repeat same process for Pump 2.

< Pump Performance Testing Record Attachment >

< Pump Schedule/Curve and Factory Certifying Documents >

Brisbane
Water



hps

HVAC

SP306

**Patrick Lane Sewage
Pump Station
Commissioning Plan**

For Approval

**REDIRECTION OF HEROES AVE SEWERAGE PUMP
STATION, MECHANICAL & ELECTRICAL FITOUT &
COMMISSIONING**

CONTRACT: BW.30079-02/03

REF: 243-98-30082/2002/2003



ISO 9001
APPROVED COMPANY

Prepared by: William Wong

Last revision: 16/08/2005

HVAC/hps Queensland Pty Ltd

101 Cobalt Street, Carole Park Qld 4300

Ph: 3712.3400 Email: info@hvacqld.com

Fax: 3712.3444 Web: www.hvacqld.com

TABLE OF CONTENTS

1. VERSION CONTROL	4
2. COMMISSIONING PLAN	5
2.1 Purpose	5
2.2 Scope	5
2.3 References	5
2.3.1 Specifications	5
2.3.2 Drawings	6
2.3.3 Testing and Certifying Documents	6
2.3.4 Management Plans & Documents	6
2.4 Staff Responsibilities	7
2.5 Procedures	8
2.5.1 Factory Acceptance Testing	8
2.5.2 Pre-Commissioning	8
2.5.3 Commissioning	9
2.6 Timeline	10
2.7 Commissioning Inspection and Test Plan	10
3. FACTORY ACCEPTANCE TESTING	13
3.1 Purpose	13
3.2 Scope	13
3.2 Procedures	13
4. PRE-COMMISSIONING	14
4.1 Pipework Hydrostatic Pressure Testing	14
4.1.1 Purpose	14
4.1.2 Scope	14
4.1.3 Procedures	14
4.2 Switchboard Pre-Commissioning SAT	15
4.2.1 Purpose	15
4.2.2 Scope	15
4.2.3 Procedures	15
4.3 Variable Speed Drives Programming	17
4.3.1 Purpose	17
4.3.2 Scope	17
4.3.3 Procedures	18
4.4 Pumps Pre-Commissioning Testing	19
4.4.1 Purpose	19
4.4.2 Scope	19
4.4.3 Procedures	19
4.5 Instrumentation Calibration and Commissioning	20

4.5.1 Purpose.....	20
4.5.2 Scope	20
4.5.3 Procedures	20
5. COMMISSIONING.....	22
5.1 Switchboard Functional Testing.....	22
5.1.1 Purpose.....	22
5.1.2 Scope	22
5.1.3 Procedures	22
5.2 Pump Performance Testing.....	23
5.2.1 Purpose.....	23
5.2.2 Scope	23
5.2.3 Procedures	24
 APPENDIX A	
BW NCS Pre-Commissioning Acceptance Test Document.....	26
APPENDIX B	
BW NCS Site Acceptance Test Document.....	27
APPENDIX C	
On Site Instrument Calibration Documents	28

1. VERSION CONTROL

Version	Date	Author	Details
1.0	01/08/05	William Wong	First draft
1.1	16/08/05	William Wong	For Approval

2. COMMISSIONING PLAN

2.1 Purpose

This plan details the description of methods and processes involved in site testing the Patrick Lane Pump Station portion of Contract BW.30079-02/03, including pre-commissioning and commissioning of the system resulting in the production of a Commissioning Inspection and Test Plan (ITP).

2.2 Scope

The scope of the project consists of the installation of a new switchboard and 2 submersible pumps along with associated pipework and control instrumentation.

The switchboard is tested separately in the workshop and then delivered to site to be installed by HVAC. The construction of the switchboard follows the process of sheet metal, minor bar works, power cable works, then electrical and control fit out.

Electrical installation follows the process of mains cabling, pumps cabling, and electrical and control cabling for field devices, as per cable schedule.

Mechanical installation follows the process of pumps installation, and associated pipework and valves installation, as per issued for construction drawings.

2.3 References

2.3.1 Specifications

- Commissioning attachment of Contract BW.30079-02/03 Redirection of Heroes Avenue Sewage Pump Station, Mechanical & Electrical Fitout & Commissioning
- Brisbane Water Patrick Lane Pump Station Functional Specification
- All associated Brisbane Water specifications supplied for the project

2.3.2 Drawings

- All electrical drawings as per specification supplied by Brisbane Water (Drawings no. 486/5/7-KJ006 to 486/5/7-KJ023)
- All civil and mechanical drawings as per specification supplied by Brisbane Water (Drawings no. 486/5/7-KJ002, 486/5/7-KJ003)
- All associated Brisbane Water standard drawings supplied for the project
- Switchboard sheet metal design drawings supplied by MPA Engineering (Drawings no. 7690-G20, 7690-G21, 7690-G22, 7690-G24)

2.3.3 Testing and Certifying Documents

- Switchboard Factory Acceptance Testing (FAT) document supplied by MPA Engineering
- Hydrostatic pressure test sheets and report
- Switchboard Pre-commissioning Site Acceptance Testing (SAT) document supplied by Common Logic
- Factory calibration certificates for level and pressure transmitters
- Variable speed drives programming parameter record
- Pumps pre-commissioning test sheets
- Switchboard functional test sheets
- Pump performance testing record
- Pump schedule/curve and factory certifying documents
- Brisbane Water Network Control Systems Pre-commissioning Acceptance Test Document
- Brisbane Water Network Control Systems Site Acceptance Test Document
- Defect Notice Template

2.3.4 Management Plans & Documents

- Site Environmental Management Plan
- Site Workplace Health & Safety Plan
- Project Quality Plan

2.4 Staff Responsibilities

Project Manager – Graham James, to prepare commissioning plan, ensure that ITPs are complete and pre-commissioning done prior to commissioning, coordinate commissioning activities, and to observe and verify as required.

Project Engineer – William Wong, to prepare commissioning plan, coordinate commissioning activities.

Mechanical Supervisor – Rene Bongers, to conduct mechanical pre-commissioning activities, and to assist in commissioning as required.

Commissioning Engineer – Grant Kerr, to commission pump station station as per contract specification 4.2.1.

Vega Australia Representative – Bradley Bailey, to calibrate and commission pressure transmitter, and to provide certification documents.

Grundfos Pumps – Andrew White, to certify correct pump installation, and observe and verify pump performances conform to specification.

Danfoss Australia – Nick Taylor, to assist in programming the VSDs, and observe and verify its correct operation.

BW Commissioning Representative – Reg McGirr, to witness commissioning activities, and to observe and verify as required, as per contract specification 4.2.2.

BW Networks Representative – Alex Witthoft, to program, operate and monitor the PLC and RTU to ensure proper operation of the pump station control system.

2.5 Procedures

2.5.1 Factory Acceptance Testing

The switchboard has been delivered to site and all FAT testings have been completed by MPA Engineering. Refer to Section 3. FACTORY ACCEPTANCE TESTING for testing procedures and completed test sheets.

2.5.2 Pre-Commissioning

All activities prior functional and pump performance tests are classed as "Pre-Commissioning". All mechanical and electrical installations by HVAC shall be tested. The following is a brief description of the activities involved:

1. **Hydrostatic Pressure Testing** – test for any leaks in the pumping system, ie. pipework, valves, pump seals, etc;
2. **Switchboard Pre-Commissioning SAT** – all tests prior to energising the switchboard and component test after energisation; test for insulation and resistance, earthing system, general wiring & inspection, point to point test of field wirings, component operational test after energisation;
3. **Variable Speed Drives Programming** – check and program parameters to ensure correct motor settings and correct communication between VSDs and control system, to meet functional specification;
4. **Pumps Pre-Commissioning Testing** – motor directional check, general inspection and checking of operation;
5. **Instrumentation Calibration and Commissioning** – on site calibration and commissioning of level and pressure transmitters;
6. **Brisbane Water Pre-Commissioning** – standard pre-commissioning acceptance testing conducted by Brisbane Water Network Control Systems, and may include I/O checks.

Refer to Section 4. PRE-COMMISSIONING for the procedures and test sheets for the above activities.

2.5.3 Commissioning

The following is a brief description of the activities that cover commissioning:

1. **Switchboard Functional Testing** – check functionality of the switchboard by testing every device to verify correct operation, all faults shall be simulated and indicated to the relevant PLC/RTU I/O point;
2. **Brisbane Water Site Acceptance Testing** – standard site acceptance testing conducted by Brisbane Water Network Control Systems to test pump station functionality;
3. **Pump Performance Testing** – verify pump performance by running pumps to various test points, and observe result matches pump curve;

Refer to Section 5. COMMISSIONING for the procedures and test sheets for the above activities.

2.6 Timeline

Below is an approximate order and duration of activities throughout commissioning.

COMMISSIONING ACTIVITIES	DATES
Factory Acceptance Testing	
• Switchboard FAT	Completed (27/05/2005)
Pre-Commissioning	
• Hydrostatic Pressure Testing	22/08/2005
• Switchboard Pre-Commissioning SAT	18/08/2005
• Variable Speed Drives Programming	22/08/2005
• Pumps Pre-Commissioning Testing	TBA
• Instrumentation Calibration and Commissioning	23/08/2005
• Brisbane Water Pre-Commissioning	24/08/2005
Commissioning	
• Switchboard Functional Testing	TBA
• Brisbane Water Site Acceptance Testing	TBA
• Pump Performance Testing	TBA
• Pump Draft Test Results Submission to BW	TBA

2.7 Commissioning Inspection and Test Plan

< Commissioning ITP Attachment >

REDIRECTION OF HEROES AVENUE SEWAGE PUMP STATION (HEROES AVENUE) INSPECTION AND TEST PLAN COMMISSIONING	BRISBANE WATER - CONTRACT BW 30079-02/03 HVAC/HPS QUEENSLAND PTY LTD DOCUMENT NO: 3251Q-HEROES-COMMISSION-01 REVISION DATE: 27/06/05
--	--

LEGEND		ITP REVISION STATUS		
INSPECTION ACTIVITY	DEFINITIONS	REVISION DATE	SECTION NUMBERS REVISED	ISSUE STATUS
(I) Visual Inspection	Visual Inspection	01/08/2005	3 to 5.2	Approval
(A) Action	Action			
(H) Hold Point	Work must not proceed until inspection activity has been carried out.			
(T) Third Party	Outside agency nominated by client or end user involvement			
(W) Witness Point	Work may proceed where inspection personnel are not available at the specified time.			
(M) Monitor	Monitor on a random basis would be visual or dimensional or exam. of records, etc.			
(S) Send	Send documents to purchaser for approval.	P-001	COMPANY PROCEDURES	
(E) Examine	Examine and endorse records for compliance to Quality Plan	P-002	MANAGING OUR SYSTEM	
ABBREVIATIONS		P-003	ESTIMATING	
DEFINITIONS		P-004	LAUNCHING THE PROJECT	
WPS	Weld Procedure Specification	P-005	PROJECT IN PROGRESS	
WPQR	Weld Procedure Qualification Record	P-006	PROJECT WRAP UP	
NCR	Non Conformance Report	P-007	AFTER CARE	
SC	Subcontractor	P-008	REPORTING	
MDR	Manufacturers Data Report	P-010	PROCESS CONTROL	
JI	Job Instructions	P-012	TRAINING	
POA	Purchase Order Attachments (eg. Form 06a for ductwork)	P-015	AUDITING AND WORKPLACE INSPECTION	
REFERENCE DOCUMENTS		P-016	PLANT AND EQUIPMENT	
CODE	DEFINITION	P-016	PURCHASING	
C1	HVAC/HPS QLD Heroes Avenue Sewage Pump Station Commissioning Plan	P-021	DESIGN PROCEDURE	
C2	Brisbane Water Specification - Contract BW.30079-02/03	P-028	DRAFTING STANDARDS	
C3	Associated Brisbane Water Standard Specification	P-029	HANDLING STORAGE AND DELIVERY	
C4	Issued for Construction Drawings supplied for the project			

**REDIRECTION OF HEROES AVENUE SEWAGE PUMP STATION (HEROES AVENUE)
INSPECTION AND TEST PLAN
COMMISSIONING**

**BRISBANE WATER - CONTRACT BW/30079-02/03
HVAC/HPS QUEENSLAND PTY LTD
DOCUMENT NO: 3251Q-HEROES-COMMISSION-01 REVISION DATE: 27/06/05**

SECT NO.	ACTIVITY	INSPECTION CRITERIA	ACCEPTANCE CRITERIA	CERTIFYING/ VERIFYING DOCUMENT	VERIFIED AND WITNESSED BY (INITIALED AND DATED)		COMMENTS
					HVAC/HPS QLD	BRISBANE WATER	
3.	Switchboard Factory Acceptance Testing	FAT Document	FAT completed and signed.	MPA Engineering FAT Inspection and Test Sheets	I	I	
4.1	Hydrostatic Pressure Testing	Hydrostatic Pressure Test Document	Testing completed and signed.	HVAC/HPS QLD Hydrostatic Pressure Test Sheets and Report (Form 15W, Form 90F)	A	H	
4.2	Switchboard Pre-Commissioning Site Acceptance Testing	SAT Document	SAT completed and signed.	SAT Inspection and Test Sheets	A	H	
4.3	Variable Speed Drives Programming	Record of programmed parameters	VSDs programmed and recorded.	VSDs Parameters Record	A	I	
4.4	Pumps Pre-Commissioning Testing	Pumps Pre-commissioning Test Document	Pumps pre-commissioning completed and test sheets signed.	HVAC/HPS QLD Pumps pre-commissioning test sheets (Form 46K)	A	I	
4.5	Level Transmitters Calibration and Commissioning	Calibration Certifying Document	Wet well and gravity sewer level transmitters calibrated on site.	Factory & Site Calibration Certifying Documents	I	H	
4.5	Pressure Transmitter Calibration and Commissioning	Calibration Certifying Document	Pressure transmitter calibrated and certified on site by manufacturer.	Vega Factory & Site Calibration Certifying Documents	A	H	
5.1	Switchboard Functional Testing	Functional Testing Document	Functional testing completed and test sheets signed.	HVAC/HPS QLD Functional Test Sheets	A	H	
5.2	Pump Performance Testing	Pump Performance Test Document	Pumps performed to client and manufacturer's specifications.	HVAC/HPS QLD Pump Performance Testing Records	A	H	

HVAC hps

COMMISSIONING SWITCHBOARD FUNCTIONAL TEST SHEET			
CONTRACT NO.	BW.30079-02/03	SW.BOARD NAME	SP306
JOB NUMBER	3251Q	LOCATION	Patrick Lane / Coronation Drive, Toowong
MANUFACTURER	MPA Engineering	DRAWING NUMBER	486/5/7-KJ006 to 486/5/7-KJ023
CUSTOMER REF.	Brisbane Water	FED FROM	New 315A Pillar Box Supply
DETAIL		OK	COMMENTS
Pumps in Local			
1	Allow well to fill to a reasonable level (ie. above PID setpoint and below Start Duty 2) and check pumps start in local:		
2	Have station in REMOTE and pumps will start automatically according to well level		
3	Observe pressing all 2 pumps START pushbuttons have no effect		
4	Switch station to LOCAL and check all pumps stop operation		
5	Push pump 1 START pushbutton, and observe pump 1 operates		
6	Observe pump 1 speed can be adjusted via its potentiometer		
7	Push pump 1 STOP pushbutton, and observe pump 1 stops		
8	Push pump 2 START pushbutton, and observe pump 2 operates		
9	Observe pump 2 speed can be adjusted via its potentiometer		
10	Push pump 2 STOP pushbutton, and observe pump 2 stops		
11	At no time should 2 pumps operate simultaneously (auto interlock ???)		
Pumps in Remote			
1	Switch station to REMOTE mode and check pumps start/stop to setpoints:		
	A. One pump starts when wet well level rises to START DUTY PUMP		
	B. Duty pump runs variably to keep wet well level at PID SETPOINT		
	C. Duty A pump stops when wet well level drops to STOP DUTY PUMP		
2	When duty pump is running, simulate pump failure and observe standby pump activates and becomes duty pump, check its operation		
3	Check failed pump reset ok		
4	Simulate SURCHARGE IMMINENT ALARM and observe station operation:		
	A. Surge Imminent relay ON, alarm signalled to PLC		
	B. Duty pump run at maximum speed		
Pumps Status			
1	Observe that lamp status indicates correct state of motors at all times		
2	Observe the hours run meters operate correctly on all pumps		
3	Observe cubicle fan operates and record their thermostat settings:		
	A. Pump 1 _____ degrees		
	B. Pump 2 _____ degrees		
4	Check and verify motor thermistors functionality on all pumps		
5	Check and verify motor moisture in oil sensor functionality on all pumps		
6	Check and verify reflux valve microswitches functionality on all pumps		
7	Check all MCC emergency stops functionality		

PRINT NAME	SIGNATURE	DATE	COMMENTS
INSPECTED BY			
APPROVED BY			

SHEET 1

PRINT NAME	SIGNATURE	DATE	COMMENTS
INSPECTED BY			
APPROVED BY			

SHEET 2

SYSTEM INTEGRATION TESTING PROCEDURE
NEW SEWAGE MAIN FROM SP103 TO NORTH QUAY EXISTING S1 SEWER CONECTION
REDIRECTION OF HEROES AVENUE (SP 103) SEWAGE PUMP STATION

Notes of Site Commissioning Work.
Monday/Tuesday/Wednesday 19/20 & 21 February 2007

Present:	Gordon Carr	(BW)
	Nicholas Siebel	(BW)
	Marty Vanyperen	(BW)
	Bill Collie	(BW)
	Harald Kemmettmuller	(BW)
	John Smith	(BW)
	Gerard Anderson	(BW)
	Alan Steward	(BW)
	Tony Deadman	(BW)
	Darryl Hayman	(BW)
	Gavin Smith	(BW)
	Reg McGirr	(BW)
	Justin White	(Appaway)
	Phil Williams	(Statewide)
	David Little	(Statewide)

The following is a brief overview of work carried out.

The following Commissioning was carried out according to:
Stage 1 System Integration Testing Procedure dated 07 February 07 Rev 3.0.

Monday 19/20 February 07 Time 08:30hrs

- 1) Toolbox Talk 08:30hrs.
- 2) Close isolation valve on the Indooroopilly rising main and open isolation valve on new rising main. New rising main filling.
- 3) Bleed air valve AV1 and AV 1/1.
- 4) Scour valve SC2/1 leaking sewage through manhole cover onto bikeway.
 Location approximately 300meters from Patrick Lane pump station towards North Quay 2meters off bikeway.
 Shut down pumps at SP103 and redirect sewage up the Indooroopilly rising main and start pumps.
 Close new rising main knife gate valve at Patrick Lane pump station.
 Open scour valve at Patrick Lane pump station and drain new main back to wetwell.
 Arrange sucker truck to empty manhole.
 Cause of leaking sewage scour valve not fully closed.
 Open new rising main knife gate valve at Patrick Lane pump station.
 Close scour valve at Patrick Lane pump station.
 Shut down pumps at SP103 and close isolation valve on the Indooroopilly rising main and open. isolation valve on new rising main and restart pumps. New rising main filling.
- 5) Scour valve under Dunmore Bridge SC 3/1 leaking sewage through valve. Close valve.
- 6) Air valve AV 3/1 20meters after Lang Pde towards North Quay in the centre of Coronation drive sewage leaking through manhole.
 Shut down pumps at SP103 and redirect sewage up the Indooroopilly rising main and start pumps.
Approximately 16:30hrs on Monday 19 February 07 all pump station personal off site to return at 21:00hrs.
 Tool Box Talk 21:00hrs.
 At 21:00hrs arrange sucker truck to empty manhole.
 Cause of leaking sewage air valve not fully closed.
 Shut down pumps at SP103 and close isolation valve on the Indooroopilly rising main and open isolation

G:\185 SEW_DRAIN\255 Des_Const\8890 Transport\S1 Luggage PT\SQSJ Redirect Heroes Ave
 (s1)\COMMISS\Reg McGirr SP103 Heroes\Integration Testing SP103 S1 Sewer\Commissioning Report New
 Rising Main\Site Work Minutes 19 and 20 February 07.doc

SYSTEM INTEGRATION TESTING PROCEDURE
NEW SEWAGE MAIN FROM SP103 TO NORTH QUAY EXISTING S1 SEWER CONECTION
REDIRECTION OF HEROES AVENUE (SP 103) SEWAGE PUMP STATION

valve on new rising main and restart pumps. New rising main filling.
 Bleed air valve AV1 and AV 1/1.

- 7) The time to fill the new rising main was excesses.
 On further investigation we found the scour valve at MH 1/3 was open and scouring into the gravity main. Close scour valve.
- 8) **Approximately 02:30hrs on Tuesday 20 February 07 all pump station personal off site to return at 15:00hrs on Tuesday 20 February 07.**
- 9) All valving as per Check Lists 1/2 & 3 were checked for position opened/closed.
- 10) Approximately 04:00hrs on 20 February 07 we had sewage into the manhole at North Quay.
- 11) All air valving was checked for air.
 All manhole pits were checked for leaking valving and pipework.
 Air intake valving at point of rising main flows into gravity main was checked for leaks.
- 12) Odour levels at North Quay appear to be within acceptable levels. Ongoing monitoring of odour levels will be recorded. And the life cycle of Odour Scrubbers Activated Carbon to be monitored.
- 13) **Outstanding work:** Fine tuning of the PID parameters to occur, this will be conducted over the next couple of weeks (which could hopefully include a rain event!).
 Final Odour report outstanding.

Attachments:

- Harald Kemmetmuller Performance Report
- Attendance Record 2pages.
- Trend 2pages.
- Schematic Operational Diagram 1page.
- Stage 1 System Integration Testing Procedure 10pages.
- ITP 1page.
- Check Lists 3pages.
- North Quay Odour Report 11pages.

G:\185 SEW_DRAIN\255 Des_Const\8890 Transport\S1 Luggage PT\SQSJ Redirect Heroes Ave
 (s1)\COMMISS\Reg McGirr SP103 Heroes\Integration Testing SP103 S1 Sewer\Commissioning Report New
 Rising Main\Site Work Minutes 19 and 20 February 07.doc

Reg McGirr - Fwd: Re: SP103 redirection of Heroes Avenue Sewage Pump Station into New Sewage Main

From: Reg McGirr
To: Barton, Michael; Karydas, Jim
Date: 07/03/2007 12:47
Subject: Fwd: Re: SP103 redirection of Heroes Avenue Sewage Pump Station into New Sewage Main
CC: Bannink, Andrew; Browne, Jeff; Cruden, Mark; Low, Stuart; Robson, Warner; Say, Jeff; Stanton, Neville; Sutherland-Macleod, Robert

Regards,
Reg McGirr
Commissioning Manager
Tel: 07 34033349
Mobile: 0414576374
E-mail: Reg.McGirr@brisbane.qld.gov.au

>>> Harald Kemmetmuller 07/03/2007 10:32 >>>

The pump station duty specification was for 2 duty pumps to be capable of 360 L/s at 35.8 m while running at 50Hz. HVAC tendered pumps capable of meeting this duty at 48.5Hz.

The pump station performance exceeds the duty requirement. This is verified by SCADA trends showing the test carried out by the BW Networks Control System Engineer, Gerard Anderson, which show flow exceeding 365L/s.

Jim appears to be asking if the rising main hydraulic performance is what was predicted in the design? The answer to this is yes. I plotted a number of point on the theoretical system resistance curve, and found that they were within the normal operating envelope.

Jim also appears to be asking if we are sure that the pump is performing according to the design requirements and according to the suppliers undertakings. The answer to this question is also yes. Firstly as stated below, the pump performance has already been verified by the Senior Mechanical Design Engineer and by the Grundfos Engineer, William Wong. I have sited the test results for on site testing and confirm that the results matche the type performance for these pump types, claimed by the manufacturer.

All testing has been completed and all components of the system are performing according to all undertakings, by all parties. The asset acceptance process should proceed for all matters relating to flow performance.

Best Regards

Harald Kemmetmuller
Mechanical Engineer (em2psbw)
Projects Branch
Brisbane Water

Phone: 07 340 33418

Fax: 07 340 30205

>>> Reg McGirr 6/03/2007 11:34 am >>>
Harald,

Will talk to you regarding Jim comments below.

Regards,
Reg McGirr
Commissioning Manager
Tel: 07 34033349
Mobile: 0414576374
E-mail: Reg.McGirr@brisbane.qld.gov.au

>>> Jim Karydas 06/03/2007 11:01 >>>
Reg,

You missed the point, the checks done by Henry Lai were checking the performance of the pumps at the station by recirculating the water.

What we need to verify that the flow calculations of the new rising main are correct and the pumps meet the head and flow requirements pumping through this rising main.

How do you know if the pumps are pumping too much or not enough through the new main.

This is the same procedure we go through when commissioning a donate asset.

We are supplied the test certificate from the pump manufacture, but at the end of the day what counts is the pumps meeting the design head and flow through the rising main.

Regards

Jim Karydas

>>> Reg McGirr 6/03/2007 8:57:44 am >>>
Jim,

Yes the pumps were checked for performance by Henri Lai and all OK. Refer to O&MM for test results.

Regards,
Reg McGirr
Commissioning Manager
Tel: 07 34033349
Mobile: 0414576374
E-mail: Reg.McGirr@brisbane.qld.gov.au

>>> Jim Karydas 06/03/2007 8:14 >>>
Reg,

Before we accept the rising main, with heroes pumping into the new rising main have you checked the performance of the pumps to prove that they meet the design flow and head.

Jim Karydas

>>> Reg McGirr 5/03/2007 3:09:25 pm >>>
Jim,

The following information regarding the above subject.

Regards,
Reg McGirr
Commissioning Manager
Tel: 07 34033349
Mobile: 0414576374
E-mail: Reg.McGirr@brisbane.qld.gov.au

>>> Michael Barton 05/03/2007 15:02 >>>

Reg

Could you resend this email addressed to Jim Karydas. Jim has responsibility for commissioning liaison with Project Branch.

Thanks

Michael Barton
Maintenance Planning Manager Networks
Brisbane Water
Telephone (07) 34078460
Mobile 0419 688 087
Fax 340 78470
michael.barton@brisbane.qld.gov.au

>>> Reg McGirr 5/03/2007 2:53 pm >>>

Michael,

Heroes Avenue Sewage Pump Station SP103 into New Sewage Main has been operational from 19 February 07.

The operation of Heroes Avenue Sewage Pump Station SP103 into New Sewage Main will fall under Networks/Operational (M&E) personal as of above date 05 March 07.












Should Networks operational personal require further training on the pumping station/system please contact Reg McGirr.


Regards,
Reg McGirr
Commissioning Manager
Tel: 07 34033349
Mobile: 0414576374
E-mail: Reg.McGirr@brisbane.qld.gov.au

Subject: Commissioning Stage 1 System Integration Testing
SP103 Redirection of Heroes Avenue Sewage Pump Station

Site: Heroes Avenue Sewage Pump Station
 19/20/21 February 2007 Time 08:30hrs/21:00hrs

Attendance Record


Print Name	Section	Date	Signature
JUSTIN WHITE	ZAPPAWAY	19-2-7	
GRAVIN SMITH	BRIS WATER	19.2.07	
DARREYL HAYMAN	BRIS WATER	19.2.07	
PAUL WILLIAMS	STATEWIDE	19.2.07	
DAVID LITTLE	STATEWIDE	19.2.07	
Anthony Deedon	Brisbane Water	19-2-07	
Harald Kommetz	Projects	19-2-07	
GORDON CARR	BRIS WATER	19/2/07	
Gerard Anderson	Brisbane Water	19/2/07	
Reg M GIRR	BW Projects	19/2/07	
LI COUKE	BL Projects	19/02/07	




Trend

— Heroes Ave. SP103M Flow refer: 1: Flow rate (L/s)

**NEW SEWAGE MAIN FROM SP103 TO NORTH QUAY EXISTING S1 SEWER CONNECTION
REDIRECTION OF HEROES AVENUE (SP 103) SEWAGE PUMP STATION**
Commissioning detail refer to Notes of site work.



Trend







Dedicated to a better Brisbane

STAGE 1 SYSTEM INTEGRATION TESTING PROCEDURE

NEW SEWAGE MAIN FROM SP103 TO NORTH QUAY EXISTING S1 SEWER CONNECTION

REDIRECTION OF HEROES AVENUE (SP 103) SEWAGE PUMP STATION

Document Approval

Name	Section	Signature
Andrew Bannink (Project Manager)	Projects (BW)	
Jeff Browne (W&S Operations)	Networks (BW)	
Peter Sherriff	Networks Control Systems (BW)	
Gerard Anderson	Networks Control Systems (BW)	
Sid Wain	Networks (BW)	
Harald Kennetmuller (Mechanical Engineer)	Projects (BW)	

07 February 2007

Rev 3.0

Page 1 of 10

This page has been left blank intentionally

STAGE 1 SYSTEM INTEGRATION TESTING PROCEDURE
NEW SEWAGE MAIN FROM SP103 TO NORTH QUAY EXISTING S1 SEWER CONNECTION
REDIRECTION OF HEROES AVENUE (SP 103) SEWAGE PUMP STATION

- STAGE 2** Coronation Drive Pump Station SP306 (New Rising Main) to North Quay Existing S1 Sewer Connection.
- STAGE 3** Cribb Street Connection for Existing XXXX Pump Station (New Rising Main) to North Quay Existing S1 Sewer Connection.
- STAGE 4** Hockings Street Syphon Live Sewer Connection to Maintenance Holes EX. 1/4 & EX.2/4

TABLE OF CONTENTS

<u>Section</u>	<u>Page</u>
1. PROJECT/SYSTEM BACKGROUND.....	4
2. HEROES AVENUE PUMP STATION.....	4
3. RESPONSIBILITY CODES.....	5
4. ATTACHMENTS:	5
5. INSPECTION & TEST PLAN (ITP) & INSPECTION CHECK LIST ABOVE IN ITEM 4.....	5
6. STAFF RESPONSIBILITIES.....	6
7. SYSTEM PRE-COMMISSIONING PROCEDURE MONDAY 10/11 APRIL & 11 MAY 2006 CHECK ALL VALVING.	6
8. SYSTEM INTEGRATION TESTING – DAY 1 MONDAY 19 FEBRUARY 2007 TIME 08:30HRS.	7
9. SYSTEM INTEGRATION TESTING– DAY 2 TUESDAY 20 FEBRUARY 2007 TIME 08:30HRS...10	
10. CONTINGENCY PLAN.....	10

STAGE 1 SYSTEM INTEGRATION TESTING PROCEDURE
NEW SEWAGE MAIN FROM SP103 TO NORTH QUAY EXISTING S1 SEWER CONNECTION
REDIRECTION OF HEROES AVENUE (SP 103) SEWAGE PUMP STATION


1. Project/System Background

HEROES AVENUE SP103 PUMP STATION UPGRADE

- 1.1 The upgrade involves increasing the capacity of the pump station, minimising odour generation and redirection from the S2 catchment to the S1 catchment via new rising main along Coronation Drive to North Quay Existing S1 Sewer Connection.
To understand the layout of SP103 Heroes Avenue Pump Station and the new rising/gravity sewer mains into the S1 sewer main, refer to drawing numbers (486/5/8-SM12/209) (486/5/8-SM12/210) (486/5/7-LI005) (486/5/7-L1007) & 486/5/7-L1008.
- 1.2 It is intended to upgrade the existing Heroes Avenue wet well and install new pumps in the existing dry well and controls in the existing structure. The existing dry well pump station structure shall be retained to house the switchboard and the new pumps. The existing pumps and valves, switchboard, resistor banks and RTU cabinet shall be de-commissioned and removed to make way for the new equipment.
- 1.3 **Note: Heroes Avenue Pump Station SP103 upgrade is complete and was commissioned on 19 September 2005 using the Emergency Mode pumping to Oxley Creek via Indooroopilly Rising Main.**
- 1.4 Stage 2 Coronation Drive Pump Station SP306 will not be part of this commissioning procedure. **Note:** It is important that all valving at SP306 is set to the correct position, refer to Check List 3 Item No's 3.1/3.2/3.3.&3.4 Drg 486/5/8-SM12/061 & 486/5/7-KJ003. SP306 will only be commissioned when the new rising main has been in services for approximately 4 weeks.
- 1.5 Stage 3 Cribb Street connection (for existing XXXX pump station) will not be part of this commissioning procedure. **Note:** It is important that all valving at Cribb Street connection is set to the correct position, refer to Check List 3 Item No 3.5. Drg 486/5/8-SM12/068.
- 1.6 Stage 4 Hockings Street Syphon Live Sewer Connection to Maintenance Holes EX. 1/4 & EX.2/4 will not be part of this commissioning procedure.

2. Heroes Avenue Pump Station

- 2.1 SP103 is a sewage pump station incorporating three variable speed driven 122 kW dry mounted submersible pumps operating in a two duty and one standby arrangement. **Note: SP103 is set to EMERGENCY Mode, in this mode only one pump is allowed to run. Refer to SP103 Functional Specification (Version 1.10 31/10/2005 Updated for As Built Site Variables) Page 11 Section 3.2 Non Standard Control**
- 2.2 To understand the layout of Heroes Avenue PS, refer to drawings numbers (486/5/7-LI005) (486/5/7-L1007) & 486/5/7-L1008
- 2.3 To understand the control philosophy attached, refer to SP103 Functional Specification (Version 1.10 31/10/2005 Updated for As Built Site Variables), it is important you read and understand this document.
- 2.4 **Before we can start filling the new rising main, we need to reinstall Gate Valve item No 36, refer to drg 486/5/7-L1007.** *Installed on 10 January 2007*


 Reg McGirr

 - The valve is stored at Eaglefarm Pumping Station.

Rev: 2.0

Page 4 of 10

G:\185 SEW_DRAIN\255 Des_Const\8890 Transport\S1 Luggage PT\SQSJ Redirect Heroes Ave (s1)\COMMISS\Reg McGirr SP103 Heroes\Integration Testing SP103 S1 Sewer\Procedure Rev3.doc

STAGE 1 SYSTEM INTEGRATION TESTING PROCEDURE
NEW SEWAGE MAIN FROM SP103 TO NORTH QUAY EXISTING S1 SEWER CONNECTION
REDIRECTION OF HEROES AVENUE (SP 103) SEWAGE PUMP STATION

- Only when the Vortex Structure has been installed at the existing S1 sewer connection will the valve be installed.
- Networks (Steve Ellwood) will arrange installation (16 January 2007) of the valve.

3. Responsibility Codes

The Responsibility Codes used on the ITP and Inspection Check Lists are as follows:

Name	Code	Branch/Section	Required Dates
Gerard Anderson	GA	Networks Control Systems (BW)	
Sid Wain	SW	Networks (BW)	
Harald Kemmetmuller	HK	Mechanical Engineer (BW)	
Reg McGirr	RM	Commissioning Manager (BW)	
Jeff Browne	JB	Water & Sewerage Operations (BW)	
Alan Steward	AS	Networks (BW)	

4. Attachments:

- Inspection & Test Plan (ITP) No.: 001 Rev.2 REDIRECTION OF HEROES AVENUE SEWAGE PUMP STATION (SP 103). NEW SEWAGE MAIN FROM SP103 TO NORTH QUAY EXISTING S1 SEWER CONNECTION.
- Inspection Check List No 1 Rev 1. Rising Main Air Bleed Valving.
- Inspection Check List No 2 Rev 1. Rising Main Scour Valving.
- Inspection Check List No 3 Rev 1. Pump Station Valving.
- Pump Station/Rising Mains and Connections Drawing Register, including drawings.
- Functional Specification SP103 Heroes Avenue Sewage Pumping Station Version 1.10 31/10/2005 Updated for As Built Site Variables.

5. Inspection & Test Plan (ITP) & Inspection Check List above in item 4.

- To be signed before proceeding with system integration testing.



Reg McGirr

STAGE 1 SYSTEM INTEGRATION TESTING PROCEDURE
NEW SEWAGE MAIN FROM SP103 TO NORTH QUAY EXISTING S1 SEWER CONNECTION
REDIRECTION OF HEROES AVENUE (SP 103) SEWAGE PUMP STATION

6. Staff Responsibilities

Commissioning Manager	Reg McGirr	To provide direction as required and to insure that all ITPs and check sheets have been signed before proceeding with system integration testing
Senior Mechanical Engineer	John Blake	Backup Commissioning Manager to provide direction as required and to insure that all ITPs and check sheets have been signed before proceeding with system integration testing
Networks Control Systems	Gerard Anderson	Inform Control Room of work to be carried out refer section 8. Responsible for Monitoring SP103 (RTU/PLC) during the filling process. Also finetuning the system when we are pumping up the new rising main. To supply pumping Trends refer to section 8.3.
Electrical	Bill Collie	Ensure that all electrical equipment is ready for automatic/manual operation including flow-meter.
Field Commissioning Monitoring	Sid Wain/ Stan Sheeran	Ensure all valving is in the correct position (according to BW Tag Out Procedure) for manual/automatic operation. The above in accordance with Inspection Check Lists (1)/(2) & (3). Traffic control procedures. And bleeding of all Air Valves and carry out visual inspection of new sewage main.
Networks	Alan Steward	Odour equipment to be set-up to monitor the levels at North Quay Existing S1 Sewer. Operation of odour units at North Quay.
Mechanical Engineer	Harald Kemmetmuller	Control monitoring the operation of the pumping station/system. (Wet Well) (Pumps) (Flow) (Pressure) (Valve Position)

7. System Pre-commissioning Procedure Monday 10/11 April & 11 May 2006 Check all valving.

This section of work under item 7 will be completed well in advance of filling the rising main. This will give us time to carry out a detailed inspection of all valving listed in the following three (3) inspection checklists. Should we require work to be carried out or the updating of as-constructed drawings we will have time to complete.

7.1 Everyone involved in the Inspection Check Lists (1)/(2)&(3) to assemble at Heroes Avenue Pumping Station on Monday 10 April 2006 Time 7:30am. ☒

7.2 Workplace Health & Safety

- Tool Box talk (9am) before the start of inspection and recording of the Check Lists (1)/(2) &(3) to cover the following. ☒
- Everyone has a copy and understands the System Integration Testing Procedure/Documentation and Traffic Control Procedures. ☒
- In case of an emergency (during normal working hours) regarding the System Integration Testing:
 First point of contact **Reg McGirr :** **Mobile Tel No. 0414576374**
 Second point of contact **Stan Sheeran :** **Mobile Tel No. 0414299802**
 Third point of contact **Sid Wain :** **Mobile Tel No. 0416159788**

Reg McGirr

Rev: 2.0

Page 6 of 10

G:\185 SEW_DRAIN\255 Des_Const\8890 Transport\S1 Luggage PT\SQSJ Redirect Heroes Ave (s1)\COMMISS\Reg McGirr SP103 Heroes\Integration Testing SP103 S1 Sewer\Procedure Rev3.doc


STAGE 1 SYSTEM INTEGRATION TESTING PROCEDURE
NEW SEWAGE MAIN FROM SP103 TO NORTH QUAY EXISTING S1 SEWER CONNECTION
REDIRECTION OF HEROES AVENUE (SP 103) SEWAGE PUMP STATION

- Confined Space Entry Permit will be the responsibility of Sid Wain.
 Note: No entry into a confined space without Authority Card.




7.3 As-Constructed Drawings

- Full set of marked-up As-Constructed rising main drawings.



7.4 There will be the following inspection check lists to be signed and dated.


: Inspection Check List 1 Rising Main Air Bleed Valving.



: Inspection Check List 2 Rising Main Scour Valving.



: Inspection Check List 3 Pump Station Valving.



7.5 Odour Monitoring/Date Collection & Odour Units operation/control at North Quay Existing S1 Sewer

It is important that we have a detailed record of the Odour levels at the different stages of the work/commissioning and under all operational conditions. The above information will determine if further Odour control measures are required.

Note: Before commissioning of the new sewage main the two (2) odour units to be running at maximum capacity 2 units running continually.

During the commissioning the odour levels at North Quay to be monitored/recorded continually 24hours for 7days to gain an overview of the odour levels.


The final operational philosophy of the odour units will be decided only when we have all odour data collection and final report from Alan Steward.

- Part 1 Odour data collection before Odour Unit at North Quay is up and running.
Note: The gravity main feeding into the North Quay existing S1 sewer connection should not be flumed.



- **Note:** The Odour unit is to be reinstated to the functional requirements as per the S1 operation and maintenance manual.

- Part 2 Odour data collection after Odour Unit at North Quay is up and running. **Note:** The gravity main feeding into the North Quay existing S1 sewer connection should not be flumed.



- Part 3 Odour data collection after new main has been commissioned. **Note:** The gravity main feeding into the North Quay existing S1 sewer connection should not be flumed.



- Note that during the commissioning of the new rising main into the S1 at North Quay, the operational philosophy of the odour unit could change. Should this occur, the relevant personnel within Brisbane Water will be consulted in regard to any operational changes. Any major changes will be considered external to the current Project Scope.

8. System Integration Testing – Day 1 Monday 19 February 2007 Time 08:30hrs.

- Everyone involved in the system integration testing to assemble at Heroes Avenue Pumping Station.
- Workplace Health & Safety

Reg McGirr



Rev: 2.0

Page 7 of 10

G:\185_SEW_DRAIN\255_Des_Const\8890_Transport\S1_Luggage_PT\SQSJ_Redirect_Heroes_Ave(s1)\COMMISS\Reg McGirr SP103 Heroes\Integration Testing SP103 S1 Sewer\Procedure Rev3.doc

STAGE 1 SYSTEM INTEGRATION TESTING PROCEDURE
NEW SEWAGE MAIN FROM SP103 TO NORTH QUAY EXISTING S1 SEWER CONNECTION
REDIRECTION OF HEROES AVENUE (SP 103) SEWAGE PUMP STATION

Tool Box talk (08:30hrs) before the filling of the new rising main.

- Everyone has a copy and understands the System Integration Testing Procedure/Documentation and Traffic Control Procedures. ☒
- In case of a emergency regarding the System Integration Testing:
 First point of contact **Reg McGirr :** **Mobile Tel No. 0414576374**
 Second point of contact **Gerard Anderson:** **Mobile Tel No. 0410536405**
 Third point of contact **Harald Kemmettmuller:** **Mobile Tel No. 0410536405**
 Forth point of contact **Sid Wain :** **Mobile Tel No. 0416159788**
- Confined Space Entry Permit will be the responsibility of Sid Wain.
 Note: No entry into a confined space without Authority Card. ☒
- At all times the control room must be contacted by phone and informed of what you are planing to do before you start the work. ☒
- **Note:** Air valve (AV1/1) on the corner of High St & Benson St will be bleed during the daytime. ☒
- **Note:** All air valves excluding air valve (AV 1/1) will be bleed on the night of 19 & 20 February 2007 from 21:00hrs to 06:00am. ☒

8.1 Redirection of Heroes Avenue (SP103) Sewage Pump Station.

- Change over from **S2 catchment** (Oxley Creek via Indooroopilly rising main) to **S1 catchment** via new rising main along Coronation Drive to North Quay existing S1 sewer connection.
- Before we start filling the new rising main all valving Air Bleed/Scour & Pump Stations valves to be checked for correct position (open/closed). There will be the following inspection check lists to be signed and dated.

: Inspection Check List 1 Rising Main Air Bleed Valving. ☒

: Inspection Check List 2 Rising Main Scour Valving. ☒

: Inspection Check List 3 Pump Station Valving. ☒

- Pump Station/Rising Mains and Connections Drawing Register. ☒
- Check wet well level. Place all pumps in manual mode and pump wet well down to stop level. ☒
- **Switch pump station (all 3 pumps) to manual mode** then stop pumps. ☒
- Selector switch inside board to be switched **from Emergency mode to Normal mode.** ☒
- Ensure the minium speed on the VFD is set to 28Hz and max speed to 50Hz. These speed settings to be set on pump No's 1 2 & 3 for normal operation. (Not Emergency mode). ☒
- Pumps 2 & 3 to be locked out from running. ☒
- Close isolation valve on the Indooroopilly rising Main (Check List 3 Item.3.1). ☒
- Start pump No 1 in manual mode, the pump will ramp up to 28Hz. ☒

Reg McGirr

Rev: 2.0

Page 8 of 10

G:\185 SEW_DRAIN\255 Des_Const\8890 Transport\S1 Luggage PT\SQSJ Redirect Heroes Ave (s1)\COMMISS\Reg McGirr SP103 Heroes\Integration Testing SP103 S1 Sewer\Procedure Rev3.doc

STAGE 1 SYSTEM INTEGRATION TESTING PROCEDURE
NEW SEWAGE MAIN FROM SP103 TO NORTH QUAY EXISTING S1 SEWER CONNECTION
REDIRECTION OF HEROES AVENUE (SP 103) SEWAGE PUMP STATION

- At the same time as pump 1 starts, slowly open the isolation valve (on the new rising main at Heroes Avenue (SP103) Sewage Pump Station (Check List 3 Item 3)) until the gauge pressure is indicating 105 Kpa. Corresponding to approximately a flow of 55 l/s. ☒

While the rising main is filling, the back pressure on the pump should be controlled by throttling the isolation valve, to ensure that the main is not filled to rapidly and the pump is not allowed to cavitate.

The expected flow range to maintain the level in the wet well is between 50 and 100l/s. The flow rates can be achieved by varying the pump speed between 28Hz and 30Hz & by gradually opening or closing the isolation valve.

It is recommended to operate the pump at minimum speed, if possible, while the main is filling and only increase the speed, if the level in the wet well is beginning to rise.

Once the main begins to fill and the flowmeter is flooded, the flowmeter should begin to provide an accurate indication of the flow rate.

The isolation valve should be progressively opened as the main fills, to maintain the required flow rate (to match inflow rate).

It will take approximately 4hours to fill the main at ADWF of 65l/s.

- Once the main is full and all air has been bleed from the main, all pumps are to be placed in automatic mode. ☒

8.2 Monitor the operation of the pump systems according to the Functional Specifications SP103 Version 1.10 30/10/2005.

- Monitor the wet well at SP103 and confirm that the duty pumps start at the start levels and stops at the stop level. ☒
- Monitor the operation of the pump systems according to the Functional Specifications SP103 Version 1.10 30/10/2005. ☒

8.3 Pumping trends of Heroes Avenue PS to be captured at the end of the day.

- Trends required of Wet Well Levels.
- Trends required of Delivery Pressure.
- Trends required of Pump Power, Speed and Running Signal.
- Trends required of Pump Flow. ☒

8.4 The pumping system will be left in the automatic position.


- Site Instruction will be left at SP103 (Control Room) so that if there is a failure on the new rising main we will revert back to Emergency Mode. ☒

8.5 The following procedure for changing from (Normal Mode) pumping to the S1 connection and changeover to (Emergency Mode) pumping to Oxley Creek via Indooroopilly rising main.

Procedure for changing from the S1 rising main (Normal Mode) to (Emergency Mode) pumping to Oxley Creek via Indooroopilly rising main.

- All pumps set to manual mode.
- Pump wet well down to cut-out level.
- Place switchboard in Emergency Mode.

Reg McGirr



STAGE 1 SYSTEM INTEGRATION TESTING PROCEDURE
NEW SEWAGE MAIN FROM SP103 TO NORTH QUAY EXISTING S1 SEWER CONNECTION
REDIRECTION OF HEROES AVENUE (SP 103) SEWAGE PUMP STATION

- d) Close S1 rising main Gate Valve item No 36 refer to drg 486/5/7-L1007. ☒
- e) Slowly open Indooroopilly Gate Valve on 470MSCL RL2.905 refer to drg 486/5/7-L1005. ☒

Note: The Indooroopilly Rising Main could be empty extreme caution when opening valve.

- f) Switch all three pumps to auto mode. ☒

Procedure for changing from (Emergency Mode) pumping to Oxley Creek via Indooroopilly rising main to the S1 rising main (Normal Mode).

- a) All pumps set to manual mode. ☒
- b) Pump wet well down to cut-out level. ☒
- c) Close Indooroopilly Gate Valve on 470MSCL RL2.905 refer to drg 486/5/7-L1005. ☒
- d) Place switchboard in Normal Mode. ☒
- e) Slowly open S1 rising main Gate Valve item No 36 refer to drg 486/5/7-L1007. ☒
- f) Switch all three pumps to auto mode. ☒

9. System Integration Testing– Day 2 Tuesday 20 February 2007 Time 08:30hrs.

- Everyone involved in the system integration testing to assemble at Heroes Avenue Pumping Station. ☒
- Review of previous days work and work to be carried out. ☒
- **Note:** Air valve (AV1/1) on the corner of High St & Benson St will be bleed during the daytime. ☒
- **Note:** All air valves excluding air valve (AV 1/1) will be bleed on the night of 19 & 20 February 2007 from 21:00hrs to 06:00am. ☒

9.1 All items on Inspection Check Lists (1) (2) & (3) to be re-checked dated and signed.

- Inspection & Test Plan No.: 001 Rev.0 ☒

9.2 The pumping system will be left in the automatic position.

- Site Instruction will be left at SP103 (Control Room) so that if there is a failure on the new rising main we will revert back to Emergency Mode. ☒

9.3 If required day three system testing.

Reg H. Ginn

10. Contingency Plan

- Be aware that the overarching contingency plan, should the odour be at unacceptable levels, is to redirect the flow back into the S2 system.

INSPECTION & TEST PLAN						PAGE: 1						
CUSTOMER/PROJECT: Redirection of Heroes Avenue Sewage Pump Station SP103, EQUIPMENT: System Integration Commissioning of <u>New Sewage Main from SP103 to North Quay Existing S1 Sewer Connection</u>					CONTRACT REF:		Date 14/03/06 ITP: 001 Rev. 2					
ITEM NO: 1 Drawing No.s: 486/5/8-SM12/209 & 210 COMPONENT: Mechanical/Electrical & <u>New Sewage Main from SP103 to North Quay Existing S1 Sewer Connection</u> System Integration Commissioning MATERIAL:					KEY TO INSPECTION ACTIVITIES H-Hold Point W-Witness S-Surveillance R-Review N-Notification DR-Document Reqd							
NO	PROCESS DESCRIPTION/ACTIVITY	LOC	PROCEDURE	ACCEPTANCE STANDARD	Certifying Verifying Document	Inspection						
						BW						
						Key	Date	Sgn	Key	Date	Sgn	Code
1	Site Induction/Confined Space Training	E	Visual Inspection	BW	BW PROCEDURE Doc id: 002728				DR/R			SW
2	Site commissioning of Heroes Avenue SP103 using Emergency Mode pumping to Oxley Creek via indoor rooftop rising main	E	Visual Inspection	Contract Document BW30079-02/02	BW System Integration Testing Procedure Emergency Mode				R/ DR	12/04/06	[Signature]	RM
3	Review Functional Specification SP103 Version 1.10 31/10/2005 Updated to As Built Site Variables	E	Visual Inspection	Contract Document BW30079-02/03	BW Functional Specification				R/ DR	19/2/07	[Signature]	RM/ GA
4	Review of As Constructed Drawings or Marked-up As Installed Drawings: Pump Station/Rising Mains and Connections Drawing Register	E	Visual Inspection	BW	BW Drawings				R/ DR	14/2/07	[Signature]	RM/ SW
5	Odour data collection (Part 1) at the S1 shaft connection before Odour unit is up and running.	E	Visual Inspection	BW	BW PROCEDURE				R/ DR			AS
6	Odour unit up and running. Odour data collection (Part 2) at the S1 shaft connection	E	Visual Inspection	BW	BW PROCEDURE				R/ DR			AS
7	Installation of Vortex Assembly at S1 Shaft Connection	E	Visual Inspection	BW	BW Drawings				R/ DR	04/01/07	[Signature]	RM
8	Review of Stage 1 System Integration Testing Procedure New Sewage Main From SP103 to North Quay Existing S1 Sewer Connection Redirection of Heroes Avenue SP103 Sewage Pump Station	E	Visual Inspection	BW	BW ITP & Check Sheets/Records Sheets/System Integration Testing Procedure				R/ DR	19/2/07	[Signature]	RM/ GA/ HK
9	Stage 1 System Integration Testing Procedure Item 2.4 has been completed. <u>Reinstall Gate Valve Item 36 refer drg 486/5/7-L1007</u>	E	Visual Inspection	BW	Stage 1 System Integration Testing Procedure				R/ DR	19/2/07	[Signature]	RM
10	Stage 1 System Integration Testing Procedure Item 7.4 has been completed.	E	Visual Inspection	BW	Stage 1 System Integration Testing Procedure. Check List 1 2 & 3.				R/ DR			SW
11	Clearance for use of new discharge sewage main	E	Visual Inspection	BW	BW PROCEDURE				R/ DR	14/2/07	[Signature]	RM/ SW
12	Odour data collection (Part 3) at the S1 shaft connection. After the new main has been commissioned.	E	Visual Inspection	BW	BW PROCEDURE				R/ DR			AS
13	Networks Operation Final Acceptance	E	Visual Inspection	Contract Document BW30079-02/03	BW PROCEDURE				R/ DR			JB

ORIGINAL ISSUE PREPARED BY: Reg McGirr APPROVED BY: Andrew Bannink	RELEASED BY: BW Projects	KEY TO LOCATION ACTIVITIES A-BW S-Supplier C-Sub Contractor E-Site	BRISBANE WATER T.C. Burnie Building 315 Brunswick St. Mall, Fortitude Valley, Brisbane Qld 4000
--	--------------------------	---	--

STAGE 1 SYSTEM INTEGRATION TESTING PROCEDURE
NEW SEWAGE MAIN FROM SP103 TO NORTH QUAY EXISTING S1 SEWER CONECTION
REDIRECTION OF HEROES AVENUE (SP 103) SEWAGE PUMP STATION

Inspection Check List 1 Rising Main Air Bleed Valving
Refer to Schematic Operational Diagram Drg No. 486/5/8-SM12/210

The following manual operated Air Bleed Valving to be inspected and checked for correct position open/closed.

Print name/signed and dated in the following check list.

Item No	Item Description	BW Drawing No.	Valve Position	Date Air Bleed	Date Checked	Code/Print Name	Sgn
1	AV1 in Josling St AV2 in Brisbane St To Gravity Main ✓	AV1 & AV2 486/5/8-SM12/203 486/5/8-SM12/205	Closed		10-4-06 AV1 2-3-07 20-2-07	S. SHEERAN 40105 A. Deelman A. Deelman	
1.1	AV1/1 Corner of High & Benson St To Gravity Main ✓	AV1/1 486/5/8-SM12/054 486/5/8-SM12/059	Closed		10-4-06 2-3-07 20-2-07	S. SHEERAN 40105 A. Deelman A. Deelman	
1.2	AV2/1 Just before Landsborough TCE on Coronation Drive To Gravity Main ✓	AV2/1 486/5/8-SM12/055 486/5/8-SM12/060	Closed		10/5/06 2-3-07 20-2-07	S. SHEERAN 40105 A. Deelman A. Deelman	
1.3	AV6/1 58.440m from P/S1/1 Patrick Lane/ Coronation Drive (Note: Knifegate Valve Item 15 Drg No. Drg 486/5/7-KJ003 must be open when you bleed air) To Gravity Main ✓	AV6/1 486/5/8-SM12/019 486/5/8-SM12/026 486/5/8-SM12/009	Closed		2-3-07 20-2-07	A. Deelman A. Deelman	
1.4	AV3/1 Just before Lang PDF on Coronation Drive To Gravity Main	AV3/1 486/5/8-SM12/056 486/5/8-SM12/064	Closed	chick m/h	11/5/06 20-2-07	S. SHEERAN 40105 A. Deelman	
1.5	AV4/1 Just before Cribb St on Coronation Drive To Gravity Main ✓	AV4/1 486/5/8-SM12/057 486/5/8-SM12/067	Closed		11/3/07 20-2-07	S. SHEERAN 40105 A. Deelman A. Deelman	
1.6	AV5/1 Just after Cribb St on Coronation Drive To Gravity Main ✓	AV5/1 486/5/8-SM12/021 486/5/8-SM12/026	Closed		2-3-07 20-2-07	- No Air Valve A. Deelman A. Deelman	
1.7							
1.8							

STAGE 1 SYSTEM INTEGRATION TESTING PROCEDURE
NEW SEWAGE MAIN FROM SP103 TO NORTH QUAY EXISTING S1 SEWER CONECTION
REDIRECTION OF HEROES AVENUE (SP 103) SEWAGE PUMP STATION

Inspection Check List 2 Rising Main Scour Valving.
Refer to Schematic Operational Diagram Drg No. 486/5/8-SM12/210

The following manual operated Scour Valving to be inspected and checked for correct position open/closed.
Print name/signed and dated in the following check list.

Item No	Item Description	BW Drawing No.	Valve Position	Date Scoured	Date Checked	Code/Print Name	Sgn
2	Heroes Avenue Pump Station Car Park (S1 Sucker Truck)	S1 486/5/8-SM12/202 486/5/8-SM12/205	Closed		10/4/06 20-2-07	S. SHEERAN 40109 A. Deelman	
2.1	Herbert St (S2 To Gravity Main)	S2 486/5/8-SM12/203 486/5/8-SM12/205	Closed		20-2-07 10/4/06 20-2-07	S. SHEERAN 40109 A. Deelman	
2.2	Brisbane St (S3 To Wet Well SP99)	S3 486/5/8-SM12/204 486/5/8-SM12/205	Closed		9/7/07 20-2-07	S. SHEERAN 40109 A. Deelman	
2.3	Patrick Lane/Coronation Drive SP306 (To Gravity Main via Wet Well) (Note: Knifegate Valve Item 15 Drg No. 486/5/7-KJ003 must be open when Scouring Main)	Scour Valve No.10 486/5/7-KJ003 486/5/8-SM12/061	Closed		10/4/06 20-2-07	S. SHEERAN A. Deelman	
2.4	Just before Chasely St/ Coronation Drive (SC2/1 To Vactor Coupling)	SC2/1 486/5/8-SM12/056 486/5/8-SM12/062	Closed		10/5/06 20-2-07	S. SHEERAN A. Deelman	
2.5	Just after Lang PDE/ Coronation Drive (SC3/1 To Gravity Main)	SC3/1 486/5/8-SM12/056 486/5/8-SM12/065	Closed		11/5/06 20-2-07	S. SHEERAN A. Deelman	
2.6	Cribb St/ Coronation Drive MH3/1 (To Gravity Main)	Scour Valve 486/5/8-SM12/057 486/5/8-SM12/068 486/5/8-SM12/017	Closed	check 11/7.	11/5/06 20-2-07	S. SHEERAN A. Deelman	
2.7	Eagle Terrace MH1/3 (To Gravity Main)	Scour Valve 486/5/8-SM12/101 486/5/8-SM12/106	Closed		20-2-07	A. Deelman	
2.8							

STAGE 1 SYSTEM INTEGRATION TESTING PROCEDURE
NEW SEWAGE MAIN FROM SP103 TO NORTH QUAY EXISTING S1 SEWER CONECTION
REDIRECTION OF HEROES AVENUE (SP 103) SEWAGE PUMP STATION

Inspection Check List 3 Pump Stations Valving & Piping.
Refer to Schematic Operational Diagram Drg No. 486/5/8-SM12/210

The following manual operated Valving to be inspected and checked for correct position open/closed.

Print name/signed and dated in the following check list.

Item No	Item Description	BW Drawing No.	Valve Position	Date Checked	Code/Print Name	Sgn
3	Heroes Avenue Pump Station SP103 (Item 36 will be closed. Only when we are filling the new rising main will the valve be opened) Item 36 Rising Main 375 NB Gate Valve.	Item 36 486/5/7-LI007 486/5/7-LI005	Closed/Open	10/4/06	S. SHGGERAN 40105	 VALUE NOT INSTALLED
3.1	Heroes Avenue (SP103) P/S Indooripilly rising main Isolation Valve	486/5/7-LI005	Closed Open	10/4/06	S. SHGGERAN 40105	
3.2	Patrick Lane/Coronation Drive SP306 Item 4 Rising Main DN600 Knife Gate Valve	Item 4 486/5/8-SM12/061	Open	2-3-07 10/4/06 20-2-07	A. Deedman S. SHGGERAN 40105 A. Deedman	
3.3	Patrick Lane/Coronation Drive SP306 Item 6 & 7 DN300 Sluce Valve into Wet Well SP306	Item 6 & 7 486/5/8-SM12/061	Close	10/4/06 22-3-07 20-2-07	S. SHGGERAN 40105 A. Deedman A. Deedman	
3.4	Patrick Lane/Coronation Drive SP306 Item 15 300NB Knife Gate Valve into Gravity Main	Item 15 486/5/7-KJ003	Open Closed Open	10/4/06 20/5/2-07	S. SHGGERAN 40105 A. Deedman A. Deedman	
3.5	Cribb St/Coronation Drive Item 3 DN 400 Knif Gate Valve to XXXX	Item 3 486/5/8-SM12/068	Closed	20-2-07	A. Deedman	
3.6	Just after Cribb St/Coronation Drive EX4/1	EX4/1 486/5/8-SM12/101 486/5/8-SM12/105	Piping to be checked for leaks	2-3-07 20-2-07	A. Deedman A. Deedman	
3.7	Eagle Terrace MH1/3	486/5/8-SM12/101 & 106	Piping to be checked for leaks	20-3-07 20-2-07	A. Deedman A. Deedman	
3.8						


From: Alan Steward
To: Barton, Michael; McGirr, Reg; Thompson, Bruce
Date: 15/03/2007 9:22:31
Subject: Heroes Ave Rising Main

Reg

I have attached the report concerning summarising the odour monitoring undertaken. I have limited the data to high level summation, I am unfortunately short of time at the moment. Please feel free to constructively criticize the document.

Kindest Regards
Alan Steward
PH 340 78416
Mobile 0438 684 231
alan.steward.brisbane.qld.gov.au

North Quay Odour Monitoring Plan



PROJECT ODOUR MONITORING PLAN

REDIRECTION OF HEROES AVENUE (SP103) SEWAGE PUMP STATION

Project Code: N/A

Maintenance Planning

Project Manager:

Andrew Bannick

Project Owner:

N/A

Doc Id:	Activate Date:	Module 9 – Project Implementation Plan Template
Printed: 06/02/07	Owner: BSO10BW	Page 1 of 3

Note: Printed copies of this document should be verified for currency against the published electronic copy.

REDIRECTION OF HEROES AVENUE (SP103) SEWAGE PUMP STATION



ODOUR MONITORING PLAN

Purpose

To monitor Hydrogen Sulphide (H₂S) gas release from the North Quay discharge maintenance hole throughout the commissioning of the Heroes avenue pump station rising main. The purpose of this monitoring is to determine the new system configuration operates within acceptable odour levels.

Document Signoff

Approval

	NAME	ROLE	SIGNATURE	DATE
Project Manager	Andrew Bannik			
Operations	Jeff Brown			
Network	Peter Sherrif			
Controls				
Network	Gerard			
Controls	Anderson			
Networks	Sid Wain			
Projects	Harald Hekketmuller			

Distribution

NAME	ROLE	SIGNATURE	DATE

Version History

Version	Author	Change	Date
---------	--------	--------	------

Doc Id: Activate Date: Module 9 – Project Implementation Plan Template
 Printed: 06/02/07 Owner: BSO10BW Page 2 of 3
 Note: Printed copies of this document should be verified for currency against the published electronic copy.

REDIRECTION OF HEROES AVENUE (SP103) SEWAGE PUMP STATION



ODOUR MONITORING PLAN

Doc Id:	Activate Date:	Module 9 – Project Implementation Plan Template
Printed: 06/02/07	Owner: BSO10BW	Page 3 of 3

Note: Printed copies of this document should be verified for currency against the published electronic copy.

REDIRECTION OF HEROES AVENUE (SP103) SEWAGE PUMP STATION



ODOUR MONITORING PLAN

Background

This document is an appendix to the "Systems Integration testing procedure" for the commissioning of the new Heroes Avenue pump station rising main. The procedure for monitoring Hydrogen Sulphide (H_2S) levels at North Quay discharge maintenance hole (MH235401) is given, outlining the minimum emissions goals for this system to operate under. The management of H_2S emissions is critical to the continued operation of this new infrastructure, in the advent levels exceed the specified goals sewage will be redirected as per the emergency pumping mode to Oxley creek using Indooroopilly Road pumps station.

1. Monitoring Method

The method for monitoring must be identical to the previous two sampling periods to ensure consistency of results. The current procedure used for monitoring, challenging and spanning gas detectors should be utilised.

1.1. Monitoring Period

Monitoring will commence on the 12 February and continue until the 19 March 2007.

1.2. Locations

The gas detectors will be located as per schedule in Appendix A. The gas detectors in North Quay discharge maintenance hole are to be located with the preset positioning ropes at the top, middle and bottom of the shaft, with the bottom most logger being located approximately 30cm above the obvert of the S1 outlet.

1.3. Equipment

The Apptek "Odalog" units are to be used as per previous sampling and are referred to in this document as "Gas Detector". The units are to be hired for the duration of this sampling work and each unit is to be supplied with a calibration certificate.

2. Emission Goals

The criterion for success has been set at a level that will best serve the public in the vicinity of the discharge maintenance hole and the associated odour scrubbing facility. This criterion has been set with respect to the Environmental Protection Agency's Environmental Protection (AIR) Policy 1997. In the advent an issue arises beyond the criterion stated here, this policy should be used as a guide in consultation with Networks and Systems Planning branches.

REDIRECTION OF HEROES AVENUE (SP103) SEWAGE PUMP STATION



ODOUR MONITORING PLAN

2.1. Hydrogen Sulphide

Indicators And Goals Relevant To The Aesthetic Enjoyment Of Places And Visual And Local Amenity			
Air Quality Indicators and Goals			
Air Quality Indicator	Micrograms per m3	Parts per Million (ppm)	Averaging Time
Hydrogen Sulphide	7	0.005	30 Minutes
Other Indicators and Goals			
Air Quality Indicator	Micrograms per m3	Parts per Million	Averaging Time
Hydrogen Sulphide	150	0.099	24 Hours
<i>Stated goals per Schedule 1 – Air Quality Indicators and Goals</i>			

Table 1. Air Quality Criterion – Upper limits for Hydrogen Sulphide Emissions.

The air quality emission goals have been set at the levels in Table 1. on the premise that any emission above these stated levels may be detectable by people at the sensitive sites of the Commonwealth Law courts (20m from stack), the Inns of Court (20m from stack) or the Cycle path on the river bank (10m from stack).

2.2. Monitoring Projections

The sampler should give due consideration to the impact of any H₂S detected and make considered projections if any gas continues to be detected. An example is given below:

As per a point reading this would equate to a 0.1ppm reading within a window of thirty minutes. This would equate to a 30 minute average of 0.00333ppm and a single reading of 0.2 ppm equates to an average of 0.00668ppm, which is over the allowable 0.005.

2.3. Odorous Compounds

Other odorous compounds are known to be associated with sewage and be present in sewer systems. At times these can be detected at vents stacks, discharge maintenance holes and pump stations. In the advent any odours other odour are detected emitting from North Quay discharge maintenance hole a full investigation should follow. Table 3 gives known examples of odorous compound associated with sewage:

REDIRECTION OF HEROES AVENUE (SP103) SEWAGE PUMP STATION



ODOUR MONITORING PLAN

Substance	Approximate odour thresholds (ppm)
Hydrogen sulphide	0.002
Styrene	0.07
Toluene	8
Ammonia	6
benzene	10
Ethylbenzene	0.5
Xylene (o)	5
Xylene (m)	0.4
Ethyl mercaptan	0.001
Methyl mercaptan	0.002
Dimethyl sulphide	0.002
Dimethyl disulphide	0.01
Skatole	0.001
Odour concentration	1 ou

Table 3. Typical Odorous compounds associated with sewage.

3. Monitoring Procedure

The telemetry system is to have the following alarms configured to the analogue signal received at SLP14.

1. Hydrogen Sulphide readings between 0 and 200ppm
2. Alarm at 5ppm
3. Alarm at 2mA or less (indication problem with equipment)

During the commissioning period sampling staff are to monitor the site during the period from 19 February 2007 through to the

3.1. Commissioning Schedule

- This H₂S monitoring is to continue from 19 February 2007 through to the 26 February 2007.

Pre – commissioning	11 January 2007	19 February 2007
Commissioning Part 1	19 February 2007	22 February 2007
Commissioning Part 2	22 February	26 February 2007
Post Commissioning	26 February 2007	26 March 2007

Table 2. Heroes Avenue pump station rising main H₂S monitoring schedule.

Doc Id: Activate Date: Module 9 – Project Implementation Plan Template
 Printed: 06/02/07 Owner: BSO10BW Page 6 of 3
 Note: Printed copies of this document should be verified for currency against the published electronic copy.

REDIRECTION OF HEROES AVENUE (SP103) SEWAGE PUMP STATION



ODOUR MONITORING PLAN

- Hydrogen Sulphide monitoring will continue at the North Quay scrubber vent stack (NQSVS) until such a time that the system is not emitting unacceptable levels of gas.

3.2. Pre-commission

- Hydrogen sulphide monitoring taken from NQSVS.
- See Heroes Avenue North Quay H₂S Report Stage II Revision II for further information on preliminary monitoring observations.
- The revised Preliminary data is to be presented to project manager on the 12 February 2007.
- All necessary monitoring equipment to be hired, calibration certificates supplied by the 12 February 2007.
- Site audit to be carried out on the 15 February 2007 to ensure no other odour issues are present that may confound the data. A low range gas detector set in "Instantaneous evaluation" mode to be utilised for this task.
- Informal testing of the Activated Carbon to be carried out on the 15 February 2007. In the advent the media indicates it is over 75 % exhausted a change of the media is to be scheduled immediately and completed by the 19 February 2007.
- Installation of the gas logger to the NQSVS utilising an analogue telemetry connection to Brisbane Water control room by 15 February 2007.
- Installation of a low range (in-line) gas detector to be installed to the scrubber outlet ducting (SDO) by the 15 February 2007. NB This should be a sealed system.

3.3. Commissioning Part 1

- Installation of monitoring equipment to site as per appendix A. on the 19 February 2007.
- A network sampler is to monitor the site constantly through Part 1 of the commissioning period. During this period 3 hourly observation (3am, 6am, 9am, 12pm & 3pm) of the monitoring equipment is to be recorded, starting at 12:00am, manually recording any gas level detected.
- The gas detectors and data loggers are to be gas challenged, zeroed, spanned and the data downloaded daily from 9am.
- In the advent a positive readings are observed the sampler is to begin constantly monitoring the gas detectors located in the NQSVS and SDO. If the observations are trending towards a violation of the Air Quality Indicators or are greater than these contact Alan Steward on 0438 684 231 or 340 78416 to review the data and escalate the issue to the commissioning manager.

Doc Id:
Printed: 06/02/07

Activate Date:
Owner: BSO10BW

Module 9 – Project Implementation Plan Template
Page 7 of 3

Note: Printed copies of this document should be verified for currency against the published electronic copy.

REDIRECTION OF HEROES AVENUE (SP103) SEWAGE PUMP STATION



ODOUR MONITORING PLAN

- In the advent a positive readings alarm is observed in the control room the controller is to notify the sampler on site. The sampler is to begin constantly monitoring the gas detectors located in the NQSVS and SDO. If the observations are trending towards a violation of the Air Quality Indicators or are greater than these contact Alan Steward on 0438 684 231 or 340 78416 to review the data and escalate the issue to the commissioning manager.
- Hydrogen sulphide emissions outside the allowable criteria noted in section 2 should be responded in the following manner.
 1. Divert Heroes avenue pump station from (Normal Mode) pumping to the S1 connection and changeover to (Emergency Mode) pumping to Oxley Creek via Indooroopilly rising main. See section 8.5 of "STAGE 1 SYSTEM INTEGRATION TESTING PROCEDURE".
 2. Test the scrubber media for level of useful life and report results to commissioning manager.

3.4. Commissioning Part 2

- Monitoring of the site is to continue from the control room as per part 1 from the 22 February.
- In the advent a positive readings alarm is observed in the control room the controller is to notify the sampler the sampler on call (see appendix B). The sampler is to begin constantly monitoring the gas detectors located in the NQSVS and SDO. If the observations are trending towards a violation of the Air Quality Indicators or are greater than these contact Alan Steward on 0438 684 231 or 340 78416 to review the data and escalate the issue to the commissioning manager.
- The gas detectors and data loggers are to be gas challenged, zeroed, spanned and the data downloaded daily from 9am.

3.5. Post Commissioning

- Ongoing site monitoring at the NQSVS and SDO is to continue as per appendix A from 26 February.
- All other gas detectors are to be decommissioned.
- The gas detectors and data loggers are to be gas challenged, zeroed, spanned and the data downloaded weekly on Tuesday.
- An audit of the activated carbon media is to be undertaken to determine its remaining useful life.

Doc Id:	Activate Date:	Module 9 – Project Implementation Plan Template
Printed: 06/02/07	Owner: BSO10BW	Page 8 of 3

Note: Printed copies of this document should be verified for currency against the published electronic copy.

REDIRECTION OF HEROES AVENUE (SP103) SEWAGE PUMP STATION



ODOUR MONITORING PLAN

Doc Id:	Activate Date:	Module 9 -- Project Implementation Plan Template
Printed: 06/02/07	Owner: BSO10BW	Page 9 of 3

Note: Printed copies of this document should be verified for currency against the published electronic copy.

REDIRECTION OF HEROES AVENUE (SP103) SEWAGE PUMP STATION



ODOUR MONITORING PLAN

A. High Level Schedule

TASK	TASK DETAILS	TIME	DATE	RESOURCE

REDIRECTION OF HEROES AVENUE (SP103) SEWAGE PUMP STATION



ODOUR MONITORING PLAN

Appendix A.

No.	Site Location	Monitoring Period	Sensor Size	Logging Freq.	Description of Location
1	North Quay Vent Stack	12 February to 19 March	1 to 200 ppm	1 minute	Top of Vent Stack – odotrack system recommended.
2	North Quay Scrubber Ducting	12 February to 19 March	0 to 2 ppm	10 Minutes	Scrubber Ducting at outlet to media containers.
3	Brisbane Commonwealth Law Courts	19 February to 23 February	0 to 2 ppm	10 minutes	23 Tank St Brisbane Qld 4000
4	Brisbane Inns Of Court	19 February to 23 February	0 to 2 ppm	10 minutes	107 North Quay Brisbane Qld 4000
5	North Quay Vortex -	19 February to 23 February	1 to 200 ppm	1 minute	Top
6	North Quay Vortex -	19 February to 23 February	1 to 200 ppm	1 minute	Middle
7	North Quay Vortex -	19 February to 23 February	1 to 200 ppm	1 minute	Bottom - approximately 30 cm above the obvert of the S1 outlet
8	Turbot St S1 Mh	19 February to 23 February	1 to 200 ppm	1 minute	
9	Ann St and North Quay Main Sewer	19 February to 23 February	1 to 200 ppm	1 minute	

Appendix B.

Date	Time	Name	Phone
19 February		Geoff Bain	
20		John Smith	

Doc Id: Activate Date: Module 9 – Project Implementation Plan Template
 Printed: 06/02/07 Owner: BSO10BW Page 11 of 3
 Note: Printed copies of this document should be verified for currency against the published electronic copy.

STAGE 2 SYSTEM INTEGRATION TESTING PROCEDURE
CORONATION DRIVE PUMP STATION SP306 (NEW RISING MAIN) TO NORTH
QUAY EXISTING S1 SEWER CONNECTION

Notes of Site Commissioning Work.
Wednesday 14 March 2007

Present:

Bill Collie	(BW)
Gerard Anderson	(BW)
Tony Deadman	(BW)
Reg McGirr	(BW)

The following is a brief overview of work carried out.

The following Commissioning was carried out according to:
Stage 2 System Integration Testing Procedure dated 08 March 07 Rev 2.

Wednesday 14 March 07 Time 06:00hrs

- 1) Toolbox Talk 06:00hrs.
- 2) Close 300 NB Knife Gate Valve interconnection wet-well to gravity main.
- 3) Open Scour valve on new rising main to fill wet-well.
- 4) We attempted to start the pumps but they were tripping on motor over-current.
 On further investigation we found because the pumps were standing for a long period of time there was a build up of rust between the Pump Impeller and wearing ring this caused the rotor to lock.
 Pump No 1 freed itself after numerous attempts to start the pump.
 Pump No2 started after we hit the suction area of the casing with a piece of wood.
 To stop the above from occurring again we decided to add code to PLC to bump pumps once per day to prevent lockup.
- 5) All further work proceeded according to Stage 2 System Integration Testing Procedure dated 08 March 07 Rev 2.
 Day two (2) testing was not required as we completed all testing except generator testing.

Outstanding work: Refer to Gerard Anderson e-mail dated 19/03/2007.

Attachments:

- Stage 2 System Integration Testing Procedure dated 08 March 07 Rev 2.
- Functional Specification Version 1.00 14/3/2007.
- Pump Trends SP103.
- Pump Trends SP306.
- Gerard Anderson e-mail dated 19/03/2007 and attachments.
- Minutes of Commissioning meeting.

G:\185 SEW_DRAIN255 Des_Const\8890 Transport\S1 Luggage PT\SQSJ Redirect Heroes Ave
 (s1)\COMMISS\Reg McGirr SP306 Coronation Drive\Site Commissioning Work Minutes Wednesday 14 March
 07.doc

Reg McGirr - Re: Commissioning data for SP306 Coronation Drive - 14thMarch07

From: Reg McGirr
To: Anderson, Gerard; Collie, Bill
Date: 20/03/2007 14:51
Subject: Re: Commissioning data for SP306 Coronation Drive - 14thMarch07
CC: Sherriff, Peter

Gerard,

The following is confirming our telephone conversation today regarding Bump Pumps Once per day to prevent lockup.

After discussions with the pump supplier regarding pump lockup he recommended the following.

- **Each pump to be switched on for 30sec every 7days. We will change from every 7days to every 3days.**

Regards,
 Reg McGirr
 Commissioning Manager
 Tel: 07 34033349
 Mobile: 0414576374
 E-mail: Reg.McGirr@brisbane.qld.gov.au

>>> Gerard Anderson 19/03/2007 11:53 >>>

Reg,


Attached is an excel spreadsheet with pump commissioning data for SP306 Coronation Drive. Also attached are trend files for the pump station operation on the commissioning day. The test with SP103 Heroes Ave running with 2 pumps full speed was performed at approximately 2.30PM in the afternoon (14/3/2007).

Also attached is the latest functional specification for SP306.

Outstanding testing to be performed at this site include :

- Generator testing to ensure generator can power the site and telemeter correctly back to Cullen Ave.
- VFD Run at Max testing : check digital output in PLC powers pumps when analog output is invalid
- Sewer level calibration fault code to be added for the gravity sewer probe against high level electrode.
- Sewer level high electrode hanging height to be determined- ie HiHi or High level
- Check % Wet Well indication onsite matches Cullen Ave graphic.
- Check mmAHDF elevation for Delivery Pressure probe.
- Add code to PLC to bump pumps once per day to prevent lockup.

Regards
 Gerard Anderson
 Brisbane Water
 07 340 78410
 0410 536 405



Dedicated to a better Brisbane

STAGE 2 SYSTEM INTEGRATION TESTING PROCEDURE

CORONATION DRIVE PUMP STATION SP306 (NEW RISING MAIN) TO NORTH QUAY EXISTING S1 SEWER CONNECTION

Document Approval

Name	Section	Signature
Andrew Bannink (Project Manager)	Projects (BW)	
Jeff Browne (W&S Operations)	Networks (BW)	
Peter Sherriff	Networks Control Systems (BW)	
Gerard Anderson	Networks Control Systems (BW)	
Ron Wilson	Networks (BW)	
Harald Kennetmuller (Mechanical Engineer)	Projects (BW)	

08 March 2007

Rev 2

This page has been left blank intentionally

STAGE 2 SYSTEM INTEGRATION TESTING PROCEDURE
CORONATION DRIVE PUMP STATION SP306 (NEW RISING MAIN) TO NORTH
QUAY EXISTING S1 SEWER CONNECTION

- STAGE 2** Coronation Drive Pump Station SP306 (New Rising Main) to North Quay Existing S1 Sewer Connection.....
- STAGE 3** Cribb Street Connection for Existing XXXX Pump Station (New Rising Main) to North Quay Existing S1 Sewer Connection.
- STAGE 4** Hockings Street Syphon Live Sewer Connection to Maintenance Holes EX. 1/4 & EX.2/4

TABLE OF CONTENTS

<u>Section</u>	<u>Page</u>
1. PROJECT/SYSTEM BACKGROUND.....	4
2. CORONATION DRIVE PUMP STATION SP306	4
3. RESPONSIBILITY CODES	5
4. ATTACHMENTS:	5
5. INSPECTION & TEST PLAN (ITP) & INSPECTION CHECK LIST ABOVE IN ITEM 4.....	5
6. STAFF RESPONSIBILITIES	5
7. SYSTEM INTEGRATION TESTING – DAY 1 WEDNESDAY 14 MARCH 2007 TIME 06:00HRS... 6	6
8. SYSTEM INTEGRATION TESTING – DAY 2 THURSDAY 15 MARCH 2007 TIME 06:00HRS..... 7	7
9. PWWF TESTING OF HEROES AVENUE P/S SP103 AND CORONATION DRIVE P/S SP306 PUMPING INTO THE NEW RISING MAIN SIMULTANEOUS.	8
10. CONTINGENCY PLAN.....	8

STAGE 2 SYSTEM INTEGRATION TESTING PROCEDURE CORONATION DRIVE PUMP STATION SP306 (NEW RISING MAIN) TO NORTH QUAY EXISTING S1 SEWER CONNECTION

1. Project/System Background

HEROES AVENUE SP103 PUMP STATION UPGRADE

- 1.1 **Note:** Heroes Avenue Pump Station SP103 upgrade is complete and was commissioned on 19 September 2005 using the Emergency Mode pumping to Oxley Creek via Indooroopilly Rising Main.
- 1.2 **Note:** Stage 1 Heroes Avenue Pump Station SP103 was commissioned on 19 February 2007 using the New Sewage Main from SP103 to North Quay Existing S1 Sewer Connection.
- 1.3 Stage 3 Cribb Street connection (for existing XXXX pump station) will not be part of this commissioning procedure. **Note:** It is important that all valving at Cribb Street connection is set to the correct position, refer to Drg 486/5/8-SM12/068.
- 1.4 Stage 4 Hockings Street Syphon Live Sewer Connection to Maintenance Holes EX. 1/4 & EX.2/4 will not be part of this commissioning procedure.

2. Coronation Drive Pump Station SP306

- 2.1 SP306 Coronation Drive sewage pump station is required to relieve the surcharging in the Coronation Drive gravity sewer. Under wet weather flow conditions, the gravity sewer is susceptible to surcharge and overflows to the environment. SP306 Coronation Drive is therefore a wet weather sewage pump station only, incorporating two variable speed driven 65 kW submersible pumps operating in a one duty and one standby arrangement.

General Process Description

SP306 Coronation Drive pump station will be connected to the gravity sewer via a short inlet. During wet weather events the sewage will flow into the well. This sewage will then be pumped into the rising main. This will continue until the level in the gravity sewer has receded, at which point the pumps shall stop under level control.

The sewage Pumping Station is of underground configuration operating in wet weather conditions only, with a wet well operating volume (under surcharge) of approximately 10 kl. The pump station will operate as a surcharge pump station, only allowing flows into the wet well during periods of surcharge in the adjacent gravity sewer. The wet well will be free to drain back into the gravity sewer at the end of the surcharge event. The pump station will have two submersible type sewage pumps installed in the Pump Well operating as duty/standby units. The pumps are interlocked so that only one pump can operate at a time. The station output with one pump operating at maximum speed will be approximately 150 l/sec.

This pump station will operate, as a stop/start station only there will be no PID control at this site. Pump speed will be limited to 50Hz this is designed to pump down the Wet Well as quickly as possible.

- 2.2 To understand the layout of Coronation Drive PS, refer to drawing numbers (486/5/8-SM12/061) (486/5/7-KJ003) (486/5/8-SM12/009).
- 2.3 To understand the control philosophy attached, refer to SP306 Functional Specification Version 0.03 21/08/2006, **it is important you read and understand this document.**

STAGE 2 SYSTEM INTEGRATION TESTING PROCEDURE
CORONATION DRIVE PUMP STATION SP306 (NEW RISING MAIN) TO NORTH
QUAY EXISTING S1 SEWER CONNECTION

3. Responsibility Codes

The Responsibility Codes used on the ITP and Inspection Check Lists are as follows:

Name	Code	Branch/Section	Required Dates
Gerard Anderson	GA	Networks Control Systems (BW)	
Ron Wilson	RW	Networks (BW)	
Harald Kemmetmuller	HK	Mechanical Engineer (BW)	
Reg McGirr	RM	Commissioning Manager (BW)	
Jeff Browne	JB	Water & Sewerage Operations (BW)	

4. Attachments:

Inspection & Test Plan (ITP) No.: 306 Rev.0 STAGE 2 SYSTEM INTEGRATION TESTING
 PROCEDURE CORONATION DRIVE PUMP STATION SP306 (NEW RISING MAIN) TO NORTH
 QUAY EXISTING S1 SEWER CONNECTION.

- Inspection Check List No 1 Rev 0 Pump Station Valving.
- SP306 Functional Specification Version 0.03 21/08/2006.

5. Inspection & Test Plan (ITP) & Inspection Check List above in item 4.

- To be signed before proceeding with system integration testing.

☐

6. Staff Responsibilities

Commissioning Manager	Reg McGirr	To provide direction as required and to insure that all ITPs and check sheets have been signed before proceeding with system integration testing
Senior Mechanical Engineer	John Blake	Backup Commissioning Manager to provide direction as required and to insure that all ITPs and check sheets have been signed before proceeding with system integration testing
Networks Control Systems	Gerard Anderson	Inform Control Room of work to be carried out. Responsible for Monitoring SP306 (RTU/PLC) during the commissioning process. Also finetuning the system when we are pumping into the new rising main. To supply pumping Trends refer to section 7.3.
Electrical	Bill Collie	Ensure that all electrical equipment is ready for automatic/manual operation.
Field Commissioning Monitoring	Ron Wilson	Ensure all valving is in the correct position (according to BW Tag Out Procedure) for manual/automatic operation. The above in accordance with Inspection Check List (1)
Mechanical Engineer	Harald Kemmetmuller	Control monitoring the operation of the pumping station/system. (Wet Well) (Pumps) (Pressure) (Valve Position)

Rev: 2

Page 5 of 8

G:\185 SEW_DRAIN\255 Des_Const\8890 Transport\S1 Luggage PT\SQSJ Redirect Heroes Ave
 (s1)\COMMISS\Reg McGirr SP306 Coronation Drive\Procedure Rev2.doc

STAGE 2 SYSTEM INTEGRATION TESTING PROCEDURE
CORONATION DRIVE PUMP STATION SP306 (NEW RISING MAIN) TO NORTH
QUAY EXISTING S1 SEWER CONNECTION

7. System Integration Testing – Day 1 Wednesday 14 March 2007 Time 06:00hrs.

- Everyone involved in the system integration testing to assemble at Coronation Drive Pumping Station. ☐
- Workplace Health & Safety
Tool Box talk (06:00hrs) before commissioning. ☐
- Everyone has a copy and understands the System Integration Testing Procedure. ☐
- In case of a emergency regarding the System Integration Testing:
 First point of contact **Reg McGirr :** **Mobile Tel No. 0414576374**
 Second point of contact **Gerard Anderson:** **Mobile Tel No. 0410536405**
 Third point of contact **Harald Kemmettmuller:** **Mobile Tel No. 0410536405**
 Forth point of contact **Ron Wilson :** **Mobile Tel No. 0404083674**
- Confined Space Entry Permit will be the responsibility of Sid Wain.
Note: No entry into a confined space without Authority Card. ☐
- **At all times the control room must be contacted by phone and informed of what you are planing to do before you start the work.** ☐

7.1 Commissioning of Coronation Drive (SP306) Sewage Pump Station.

- Before we start commissioning the new Pump Stations all valves to be checked for correct position (open/closed). There will be the following inspection check list to be signed and dated.
 : Inspection Check List 1 Pump Station Valving. ☐
- **Note:** For the commissioning process the 300 NB Knife Gate Valve will be closed. Refer to Drg No 486/5/7-KJ003 Item 15 Section A. ☐
- **Switch pump station (all 2 pumps) to manual mode.** ☐
- Ensure the minium speed on the VFD is set to 28Hz and max speed to 50Hz. ☐
- Fill wet well by opening DN150 Sluice Gate Valve. Refer to Drg No 486/5/8-SM12/061 Plan View Item 10. ☐
- Fill the wet well to just above Start Duty A pump and place the pump in auto mode. The pump should pump down to Stop Duty A pump. ☐
- Repeat the above step on Duty B pump. ☐
- With the pumps in manual mode fill the wet well to just above Surgecharge Imminent, place the pumps in auto mode. One pump should pump down to Stop pump level. ☐
- Repeat the above step and the other pump should pump down to Stop pump level. ☐

STAGE 2 SYSTEM INTEGRATION TESTING PROCEDURE
CORONATION DRIVE PUMP STATION SP306 (NEW RISING MAIN) TO NORTH
QUAY EXISTING S1 SEWER CONNECTION

7.2 Monitor the operation of the pump systems according to the Functional Specifications SP306 Version 0.03 21/8/06.

- Monitor the wet well at SP306 and confirm that the duty pumps start at the start level and stops at the stop level. ☐
- Monitor the operation of the pump systems according to the Functional Specifications SP306 Version 0.03 21/08/06. ☐
- Check the operation of the Reflux Limit Switches. ☐

7.3 Pumping trends of Heroes Avenue PS SP103 and Coronation Drive PS SP306 to be captured at the end of the day.

- Trends required of Wet Well Levels.
- Trends required of Delivery Pressure. ☐
- Trends required of Pump Power, Speed and Running Signal.
- Trends required of Pump Flow.

7.4 The pumping system will be left in the automatic position.

- **Note:** The 300 NB Knife Gate Valve must be open. Refer to Drg No 486/5/7-KJ003 Item 15 Section A. ☐

8. System Integration Testing – Day 2 Thursday 15 March 2007 Time 06:00hrs

- Everyone involved in the system integration testing to assemble at Coronation Drive Pumping Station. ☐
- Workplace Health & Safety
Tool Box talk (06:00hrs) before commissioning. ☐
- Everyone has a copy and understands the System Integration Testing Procedure. ☐
- In case of a emergency regarding the System Integration Testing:

First point of contact	Reg McGirr :	Mobile Tel No. 0414576374
Second point of contact	Gerard Anderson:	Mobile Tel No. 0410536405
Third point of contact	Harald Kemmetmuller:	Mobile Tel No. 0410536405
Fourth point of contact	Ron Wilson :	Mobile Tel No. 0404083674
- Confined Space Entry Permit will be the responsibility of Sid Wain.
Note: No entry into a confined space without Authority Card. ☐
- At all times the control room must be contacted by phone and informed of what you are planing to do before you start the work. ☐

8.1 System Control – Power Failure.

- Simulate complete energex power failure by isolating main incoming switch. ☐
- Monitor the Generator cutin when energex main isolating switch is closed. ☐

Rev: 2

Page 7 of 8

G:\185 SEW_DRAIN\255 Des_Const\8890 Transport\S1 Luggage PT\SQSJ Redirect Heroes Ave
 (s1)\COMMISS\Reg McGirr SP306 Coronation Drive\Procedure Rev2.doc

STAGE 2 SYSTEM INTEGRATION TESTING PROCEDURE
CORONATION DRIVE PUMP STATION SP306 (NEW RISING MAIN) TO NORTH
QUAY EXISTING S1 SEWER CONNECTION

- Open energex main isolating switch and monitor Generator cutout. ☐

9. PWWF Testing of Heroes Avenue P/S SP103 and Coronation Drive P/S SP306 Pumping into the new rising main Simultaneous.

- Heroes Avenue P/S SP103. Pumps placed in manual mode and fill Wet Well level to just below surcharge level. ☐
- Coronation Drive P/S SP306. Pumps placed in manual mode and fill Wet Well level to just below surcharge level. ☐
- Heroes Avenue P/S SP103. Pumps placed in auto mode. Approximately 60sec later place Coronation Drive P/S SP306 in auto mode. ☐
- Pumping trends of Heroes Avenue P/S SP103 and Coronation Drive P/S SP306 to be captured
 - Trends required of Wet Well Levels.
 - Trends required of Delivery Pressure.
 - Trends required of Pump Power, Speed and Running Signal. ☐
 - Trends required of Pump Flow.

Note: To achieve meaningful test results the above trends to be captured after an actual Wet Weather event.

10. Contingency Plan

Shutdown complete pump station.





STAGE 2 SYSTEM INTEGRATION TESTING PROCEDURE
COTONATION DRIVE PUMP STATION SP306 (NEW RISING MAIN) TO NORTH QUAY EXISTING S1 SEWER CONNECTION

Inspection Check List 1 Pump Stations Valving & Piping.
Refer to Drg No.s. (486/5/8-SM12/061)(486/5/7-KJ003) (486/5/8-SM12/009)

The following manual operated Valving to be inspected and checked for correct position open/closed.

Print name/signed and dated in the following check list.

Item No	Item Description	BW Drawing No.	Valve Position	Date Checked	Code/Print Name	Sgn
1	Patrick Lane/Coronation Drive SP306 Item 4 Rising Main DN600 Knife Gate Valve	Item 4 486/5/8-SM12/061	Closed/Open			
1.1	Patrick Lane/Coronation Drive SP306 Item 6 & 7 DN300 Sluce Valve into Wet Well SP306	Item 6 & 7 486/5/8-SM12/061	Open			
1.2	Patrick Lane/Coronation Drive SP306 Item 15 300NB Knife Gate Valve into Gravity Main	Item 15 486/5/7-KJ003	Open			
1.3	Patrick Lane/Coronation Drive SP306 Item 10 DN150 Sluce Gate Valve into Wet Well SP306	Item 15 486/5/8-SM12/061	Close			
1.4	Check Piping for leaks in Valve Chamber and Wet Well					
1.5						
1.6						
1.7						
1.8						



PIPE FITTING SCHEDULE			
No.	DESCRIPTION	MATERIAL	QUANTITY
1	DN150-350x150 TEE WITH CONCENTRIC TAPER FL. FL.	S.S. 304L PIPE HS	1
2	DN150x300 UNEQUAL TEE FL. FL. FL.	S.S. 304L PIPE HS	1
3	DN150x300 UNEQUAL TEE FL. FL. FL.	S.S. 304L PIPE HS	1
4	DN150 KNEE GATE VALVE FL. FL. C/45H	S.S. 304L	1
5	DN150 DISMANTLING JOINT WITH STUDS FOR ANCHORING TO ANCHOR FLANGE	S.S. 304L PIPE HS	1
6	DN150 SLURGE VALVE FL. FL.	O.I.	1
7	DN150 SLURGE VALVE FL. FL.	O.I.	1
8	DN150 BLANK FLANGE	MILD STEEL	1
9	DN150 BLANK FLANGE	MILD STEEL	1
10	DN150 SLURGE GATE VALVE FL. FL.	O.I.	1
11	DN150 BLANK FLANGE	MILD STEEL	1
12	DN150 ANCHOR FLANGE WELDED TO PIPE TO RESTRAIN DISMANTLING JOINT	S.S. 304L PIPE HS	1
13	DN150 SPOOL PIECE FL. FL. APPROX 2300 (LONG LENGTH TO SITE)	S.S. 304L PIPE HS	1
14	DN150 SPOOL PIECE FL. FL. APPROX 3000 LONG	S.S. 304L PIPE HS	1
15	DN150 45° BEND FL. FL. 4.0" SO. WELD	S.S. 304L PIPE HS	1
16	DN150 SPOOL PIECE FL. FL. APPROX 3000 LONG	S.S. 304L PIPE HS	1
17	DN150 END-TO-END COUPLING	S.S. 304L	1

- NOTES:
- ALL S.S. PIPEWORK TO HAVE 5mm WALL THICKNESS.
 - ALL FLANGES TO AS4087 CLASS 2L.
 - CONTRACTOR TO CONFIRM FINAL ALIGNMENT OF KNEE GATE VALVE PRIOR TO INSTALLATION.
 - DN 150 RPTS TO BE MADE UP WITH DN 600 FLANGES.

AS CONSTRUCTED DRAWING

Brisbane City Council
Contract No. BW20132-01/02
Contractor: Tico Water Pty Ltd
Completed: 9 March 2004
Signed: *[Signature]*
Date: 8.03.2004

FOR CONSTRUCTION



486/5/B-SM 12/061

Sheet 12 of 35

Project No. 020300CW

AS SHOWN

PL012 A

Rev	Date	Revision Details	By	App.
1	02/06/03	ISSUED FOR TENDER		
2	10/06/03	TENDER MODIFICATIONS		
3	12/02/03	TENDER MODIFICATIONS		
4	12/02/03	TENDER MODIFICATIONS		
5	12/02/03	TENDER MODIFICATIONS		
6	12/02/03	TENDER MODIFICATIONS		
7	12/02/03	TENDER MODIFICATIONS		
8	12/02/03	TENDER MODIFICATIONS		
9	12/02/03	TENDER MODIFICATIONS		
10	12/02/03	TENDER MODIFICATIONS		
11	12/02/03	TENDER MODIFICATIONS		
12	12/02/03	TENDER MODIFICATIONS		
13	12/02/03	TENDER MODIFICATIONS		
14	12/02/03	TENDER MODIFICATIONS		
15	12/02/03	TENDER MODIFICATIONS		
16	12/02/03	TENDER MODIFICATIONS		
17	12/02/03	TENDER MODIFICATIONS		
18	12/02/03	TENDER MODIFICATIONS		
19	12/02/03	TENDER MODIFICATIONS		
20	12/02/03	TENDER MODIFICATIONS		
21	12/02/03	TENDER MODIFICATIONS		
22	12/02/03	TENDER MODIFICATIONS		
23	12/02/03	TENDER MODIFICATIONS		
24	12/02/03	TENDER MODIFICATIONS		
25	12/02/03	TENDER MODIFICATIONS		
26	12/02/03	TENDER MODIFICATIONS		
27	12/02/03	TENDER MODIFICATIONS		
28	12/02/03	TENDER MODIFICATIONS		
29	12/02/03	TENDER MODIFICATIONS		
30	12/02/03	TENDER MODIFICATIONS		
31	12/02/03	TENDER MODIFICATIONS		
32	12/02/03	TENDER MODIFICATIONS		
33	12/02/03	TENDER MODIFICATIONS		
34	12/02/03	TENDER MODIFICATIONS		
35	12/02/03	TENDER MODIFICATIONS		
36	12/02/03	TENDER MODIFICATIONS		
37	12/02/03	TENDER MODIFICATIONS		
38	12/02/03	TENDER MODIFICATIONS		
39	12/02/03	TENDER MODIFICATIONS		
40	12/02/03	TENDER MODIFICATIONS		
41	12/02/03	TENDER MODIFICATIONS		
42	12/02/03	TENDER MODIFICATIONS		
43	12/02/03	TENDER MODIFICATIONS		
44	12/02/03	TENDER MODIFICATIONS		
45	12/02/03	TENDER MODIFICATIONS		
46	12/02/03	TENDER MODIFICATIONS		
47	12/02/03	TENDER MODIFICATIONS		
48	12/02/03	TENDER MODIFICATIONS		
49	12/02/03	TENDER MODIFICATIONS		
50	12/02/03	TENDER MODIFICATIONS		
51	12/02/03	TENDER MODIFICATIONS		
52	12/02/03	TENDER MODIFICATIONS		
53	12/02/03	TENDER MODIFICATIONS		
54	12/02/03	TENDER MODIFICATIONS		
55	12/02/03	TENDER MODIFICATIONS		
56	12/02/03	TENDER MODIFICATIONS		
57	12/02/03	TENDER MODIFICATIONS		
58	12/02/03	TENDER MODIFICATIONS		
59	12/02/03	TENDER MODIFICATIONS		
60	12/02/03	TENDER MODIFICATIONS		
61	12/02/03	TENDER MODIFICATIONS		
62	12/02/03	TENDER MODIFICATIONS		
63	12/02/03	TENDER MODIFICATIONS		
64	12/02/03	TENDER MODIFICATIONS		
65	12/02/03	TENDER MODIFICATIONS		
66	12/02/03	TENDER MODIFICATIONS		
67	12/02/03	TENDER MODIFICATIONS		
68	12/02/03	TENDER MODIFICATIONS		
69	12/02/03	TENDER MODIFICATIONS		
70	12/02/03	TENDER MODIFICATIONS		
71	12/02/03	TENDER MODIFICATIONS		
72	12/02/03	TENDER MODIFICATIONS		
73	12/02/03	TENDER MODIFICATIONS		
74	12/02/03	TENDER MODIFICATIONS		
75	12/02/03	TENDER MODIFICATIONS		
76	12/02/03	TENDER MODIFICATIONS		
77	12/02/03	TENDER MODIFICATIONS		
78	12/02/03	TENDER MODIFICATIONS		
79	12/02/03	TENDER MODIFICATIONS		
80	12/02/03	TENDER MODIFICATIONS		
81	12/02/03	TENDER MODIFICATIONS		
82	12/02/03	TENDER MODIFICATIONS		
83	12/02/03	TENDER MODIFICATIONS		
84	12/02/03	TENDER MODIFICATIONS		
85	12/02/03	TENDER MODIFICATIONS		
86	12/02/03	TENDER MODIFICATIONS		
87	12/02/03	TENDER MODIFICATIONS		
88	12/02/03	TENDER MODIFICATIONS		
89	12/02/03	TENDER MODIFICATIONS		
90	12/02/03	TENDER MODIFICATIONS		
91	12/02/03	TENDER MODIFICATIONS		
92	12/02/03	TENDER MODIFICATIONS		
93	12/02/03	TENDER MODIFICATIONS		
94	12/02/03	TENDER MODIFICATIONS		
95	12/02/03	TENDER MODIFICATIONS		
96	12/02/03	TENDER MODIFICATIONS		
97	12/02/03	TENDER MODIFICATIONS		
98	12/02/03	TENDER MODIFICATIONS		
99	12/02/03	TENDER MODIFICATIONS		
100	12/02/03	TENDER MODIFICATIONS		

Connell Wagner

David Wagner Pty Ltd
200 St Georges Road, St Georges
Brisbane, QLD 4000
Tel: 07 3216 0000
Fax: 07 3216 0001
Email: david.wagner@connellwagner.com.au

Client:



Project:
REDIRECTION OF HEROES AVENUE
SEWAGE PUMP STATION
SUPPLY AND INSTALLATION
OF RISING MAIN
CONTRACT No. BW.20132-01/02

Drawn:

Checked:

Verified:

Approved:

Signature:

Date:

Scale:

Project:

Sheet:

Project:

Sheet:

Project:

Sheet:

Project:

Sheet:

Project:

Sheet:

Project:

Sheet:

Project:

Sheet:

Project:

Sheet:

Project:


Sheet:

Project:

Sheet:

Project:

Sheet:




Trend Display - Trend 1

☒ Dismiss
 ☐ Print
 ☐ Copy
 ☐ Paste
 ☐ Undo
 ☐ Redo
 ☐ Zoom In
 ☐ Zoom Out
 ☐ Full Screen

Profile: **Trend 1**
 Vertical Axis: **All**
 Horizontal Axis: **All**
☐ Realtime
 Poll (s): **60**

Show	Col	Status	Point	Value	Date/Time	Quality
<input checked="" type="checkbox"/>		Done: 720	Coronation Dve SP306 : Pressure_gauge : 1 : Pressure_mahd :	26.385	14/03/2007 2:30:13 PM	
<input checked="" type="checkbox"/>		Done: 720	Coronation Dve SP306 : Wet_well : 1 : Level :	-1.108	14/03/2007 2:30:13 PM	
<input checked="" type="checkbox"/>		Done: 720	Coronation Dve SP306 : Sewer_pump : 1 : Motor_current :	123.510	14/03/2007 2:29:13 PM	
<input checked="" type="checkbox"/>		Done: 720	Coronation Dve SP306 : Sewer_pump : 2 : Motor_current :	0.000	14/03/2007 2:29:13 PM	



Selection Trend Display Options

☒ Common Type/Interval
 Type: **Snapshot**

☒ Show Tabular
 History Step: **1 minute**

Max Pts/Trace: **10000**

Graph: **Line**

Start Date/Time: **14/03/2007 6:15:13 AM**
 Start Criteria: **1**
☐ Custom

Finish Date/Time: **14/03/2007 6:15:26 PM**
 Duration: **1**
☐ Custom

☒ Use Relative Dates

Reg McGirr - Commissioning data for SP306 Coronation Drive - 14thMarch07

From: Gerard Anderson
To: Collie, Bill; McGirr, Reg
Date: 19/03/2007 11:53
Subject: Commissioning data for SP306 Coronation Drive - 14thMarch07
CC: Sherriff, Peter

Reg,

Attached is an excel spreadsheet with pump commissioning data for SP306 Coronation Drive.

Also attached are trend files for the pump station operation on the commissioning day. The test with SP103 Heroes Ave running with 2 pumps full speed was performed at approximately 2.30PM in the afternoon (14/3/2007).

Also attached is the latest functional specification for SP306.

Outstanding testing to be performed at this site include :

- Generator testing to ensure generator can power the site and telemeter correctly back to Cullen Ave.
- VFD Run at Max testing : check digital output in PLC powers pumps when analog output is invalid
- Sewer level calibration fault code to be added for the gravity sewer probe against high level electrode.
- Sewer level high electrode hanging height to be determined- ie HiHi or High level
- Check % Wet Well indication onsite matches Cullen Ave graphic.
- Check mmAHDF elevation for Delivery Pressure probe.
- Add code to PLC to bump pumps once per day to prevent lockup.

Regards

Gerard Anderson
Brisbane Water
07 340 78410
0410 536 405

SP306 Coronation Drive commissioning

Full Load pump readings	Pump Amps	Pump kW	Delivery Pressure H ₂ O	Pressure kPa	Pressure MAHD
Pump 1	122.9	70.5	16550	183	21.49
Pump 2	128	72.68	16410	193	22.49

SP306 Coronation Drive Site Data with SP103 Heroes Ave running 2 pumps full speed.



Date/Time	Coronation Dve SP306 Wet_well : 1 : Level :	Coronation Dve SP306 : Sewer : 1 : Level :	Coronation Dve SP306 : Sewer_pump 2 : Running :	Coronation Dve SP306 : Sewer_pump : 1 : Running :	Coronation Dve SLP10 Sewer : 1 : Level :	Coronation Dve SP306 Pressure_gauge : 1 : Pressure_mahd :	Heroes Ave SP103M : Flow_meter : 1 : Flow_rate :
14/03/2007 10:00:00.000 AM					-4.320		
14/03/2007 1:25:57.000 PM			Off				
14/03/2007 1:35:45.000 PM				Off			
14/03/2007 1:41:00.000 PM		-3.799					0.000
14/03/2007 1:51:00.000 PM							
14/03/2007 2:12:00.000 PM	0.069						
14/03/2007 2:12:30.000 PM						13.350	
14/03/2007 2:25:00.000 PM	0.062					13.350	0.000
14/03/2007 2:26:45.000 PM							
14/03/2007 2:27:00.000 PM	0.062						
14/03/2007 2:27:15.000 PM							135.800
14/03/2007 2:27:30.000 PM						15.980	
14/03/2007 2:27:45.000 PM							369.700
14/03/2007 2:28:15.000 PM							388.500
14/03/2007 2:28:45.000 PM	0.061						430.300
14/03/2007 2:28:56.000 PM				On			
14/03/2007 2:29:15.000 PM	0.035						413.700
14/03/2007 2:29:45.000 PM	-0.395						381.300
14/03/2007 2:30:00.000 PM						26.560	
14/03/2007 2:30:15.000 PM	-0.846						391.500
14/03/2007 2:30:45.000 PM	-1.212						
14/03/2007 2:31:15.000 PM	-1.621						
14/03/2007 2:31:45.000 PM	-2.061						
14/03/2007 2:32:15.000 PM	-2.553						388.900
14/03/2007 2:32:30.000 PM						25.820	
14/03/2007 2:32:45.000 PM	-3.201						388.900
14/03/2007 2:33:00.000 PM	-3.184						
14/03/2007 2:33:15.000 PM				Off			290.300
14/03/2007 2:33:45.000 PM							0.000
14/03/2007 2:34:30.000 PM	-3.184						0.000
14/03/2007 2:35:00.000 PM	-3.394					25.820	
14/03/2007 2:35:30.000 PM	-3.580						
14/03/2007 2:36:00.000 PM							0.000
14/03/2007 2:36:30.000 PM							73.200
14/03/2007 2:37:00.000 PM							116.900
14/03/2007 2:37:30.000 PM						15.890	120.400
14/03/2007 2:38:00.000 PM							114.000
14/03/2007 2:38:30.000 PM							98.500
14/03/2007 2:40:00.000 PM						17.960	
14/03/2007 2:48:00.000 PM							92.500
14/03/2007 2:52:00.000 PM							86.400
14/03/2007 2:52:30.000 PM							85.100
14/03/2007 2:53:00.000 PM							14.100
14/03/2007 2:53:30.000 PM							0.000
14/03/2007 2:53:45.000 PM							0.000
14/03/2007 2:55:00.000 PM						17.960	
14/03/2007 2:57:30.000 PM						16.010	
14/03/2007 3:00:00.000 PM						15.890	
14/03/2007 3:01:45.000 PM							0.000
14/03/2007 3:02:30.000 PM						15.890	
14/03/2007 3:03:15.000 PM							0.000
14/03/2007 3:03:45.000 PM							11.500
14/03/2007 3:04:00.000 PM							69.900
14/03/2007 3:04:30.000 PM							95.000
14/03/2007 3:05:00.000 PM						18.420	
14/03/2007 3:05:30.000 PM							102.800
14/03/2007 3:07:30.000 PM						18.050	97.100
14/03/2007 3:16:00.000 PM							92.000
14/03/2007 3:17:30.000 PM						17.900	
14/03/2007 3:18:00.000 PM							88.000
14/03/2007 3:20:00.000 PM						17.900	
14/03/2007 3:21:15.000 PM	-3.580						
14/03/2007 3:21:30.000 PM							88.000
14/03/2007 3:21:45.000 PM	0.000						
14/03/2007 3:22:00.000 PM		-3.799					0.000
14/03/2007 3:22:15.000 PM	-3.580						
14/03/2007 3:22:30.000 PM						15.300	
14/03/2007 3:22:45.000 PM							0.000
14/03/2007 3:23:45.000 PM	-3.580						
14/03/2007 3:25:00.000 PM						16.040	
14/03/2007 3:27:30.000 PM						15.830	
14/03/2007 3:32:15.000 PM							0.000
14/03/2007 3:35:00.000 PM						15.830	
14/03/2007 3:35:30.000 PM							0.000
14/03/2007 3:36:00.000 PM							63.400
14/03/2007 3:36:30.000 PM							88.100
14/03/2007 3:37:30.000 PM						18.670	94.500
14/03/2007 3:39:30.000 PM							88.900
14/03/2007 3:40:00.000 PM						17.920	
14/03/2007 3:48:30.000 PM							84.700
14/03/2007 3:52:30.000 PM						17.920	
14/03/2007 5:29:00.000 PM		-3.799					
14/03/2007 5:30:45.000 PM	-3.580						
15/03/2007 9:59:45.000 AM					-4.320		
15/03/2007 10:00:00.000 AM			Off	Off			

Date/Time	Coronation Dve SP306 : Sewer_pump : 1 : Motor_current	Coronation Dve SP306 : Sewer_pump : 1 : Motor_power	Coronation Dve : SP306 Sewer_pump : 2 : Motor_current	Coronation Dve : SP306 : Sewer_pump : 2 : Motor_power	Coronation Dve : SP306 : Wet_well : 1 : Level	Coronation Dve : SP306 : Sewer_pump : 1 : Running	Coronation Dve : SP306 : Sewer_pump : 2 : Running
14/03/2007 10:00:00.000 AM			0.000	0.000			Off
14/03/2007 10:09:28.000 AM					-2.503	Off	
14/03/2007 10:14:45.000 AM							
14/03/2007 10:15:00.000 AM	57.882	5.980					
14/03/2007 10:15:06.000 AM						On	
14/03/2007 10:15:15.000 AM		5.980					
14/03/2007 10:15:30.000 AM		71.500					
14/03/2007 10:15:45.000 AM		71.500			-2.657		
14/03/2007 10:16:00.000 AM	0.000	0.000	0.000			Off	
14/03/2007 10:16:06.000 AM							
14/03/2007 10:16:15.000 AM	0.000				-2.508		
14/03/2007 10:16:45.000 AM					-2.384		
14/03/2007 10:17:00.000 AM			58.530				
14/03/2007 10:17:15.000 AM				0.000	-2.384		
14/03/2007 10:17:26.000 AM							On
14/03/2007 10:17:30.000 AM				72.020			
14/03/2007 10:17:45.000 AM				70.200	-3.274		
14/03/2007 10:18:00.000 AM			28.242				
14/03/2007 10:18:15.000 AM					-3.215		
14/03/2007 10:18:30.000 AM				70.200			
14/03/2007 10:18:45.000 AM			0.000	0.000	-3.045		
14/03/2007 10:18:50.000 AM							Off
14/03/2007 10:19:15.000 AM	0.000				-2.888		
14/03/2007 10:19:45.000 AM			0.000		-2.713		
14/03/2007 10:20:15.000 AM					-2.553		
14/03/2007 10:20:30.000 AM					-2.443		
14/03/2007 10:20:45.000 AM			58.620	0.000			
14/03/2007 10:21:00.000 AM				70.540	-2.443		
14/03/2007 10:21:05.000 AM							On
14/03/2007 10:21:30.000 AM				70.540	-3.318		
14/03/2007 10:21:45.000 AM			21.498	4.540	-3.212		
14/03/2007 10:22:15.000 AM			0.000		-3.046		
14/03/2007 10:22:45.000 AM					-2.888		
14/03/2007 10:23:00.000 AM				4.540			
14/03/2007 10:23:07.000 AM							Off
14/03/2007 10:23:15.000 AM	0.000			0.000	-2.729		
14/03/2007 10:23:45.000 AM					-2.551		
14/03/2007 10:24:15.000 AM	51.462				-2.440		
14/03/2007 10:24:30.000 AM	57.252	0.000					
14/03/2007 10:24:42.000 AM						On	
14/03/2007 10:24:45.000 AM		48.480			-2.440		
14/03/2007 10:25:15.000 AM		48.480			-3.315		
14/03/2007 10:25:30.000 AM	24.732	1.220			-3.232		
14/03/2007 10:25:45.000 AM		0.000					
14/03/2007 10:25:48.000 AM						Off	
14/03/2007 10:26:00.000 AM					-3.066		
14/03/2007 10:26:15.000 AM	0.000						
14/03/2007 10:26:30.000 AM					-2.911		
14/03/2007 10:27:00.000 AM					-2.754		
14/03/2007 10:27:15.000 AM	0.000						
14/03/2007 10:27:30.000 AM					-2.565		
14/03/2007 10:27:45.000 AM			0.000				
14/03/2007 10:28:00.000 AM					-2.405		
14/03/2007 10:28:30.000 AM					-2.326		
14/03/2007 10:28:45.000 AM			58.968				
14/03/2007 10:29:00.000 AM					-2.326		
14/03/2007 10:29:15.000 AM				0.000			
14/03/2007 10:29:23.000 AM							On
14/03/2007 10:29:30.000 AM				70.552	-3.219		
14/03/2007 10:29:45.000 AM			32.472				
14/03/2007 10:30:00.000 AM				70.552	-3.214		
14/03/2007 10:30:18.000 AM							Off
14/03/2007 10:30:30.000 AM			0.000				
14/03/2007 10:31:15.000 AM	0.000						
14/03/2007 10:32:03.000 AM						On	
14/03/2007 10:39:15.000 AM		0.000					

BRISBANE WATER

Network Control Systems

FUNTIONAL SPECIFICATION

SP306 Coronation Drive

Sewage Pumping Station

Submersible 2 Pumps With VSD

(Wet Weather Station)

Document Signoff

Approval

	Name	Role	Signature	Date
Manager Mechanical and Electrical Services <i>Engineering Design Services</i>	Rahim Janfade.	Concur		
Manager <i>Water And Wastewater Operations Manager</i>	Anu Atukorala	Concur		
Team Leader <i>Network Control Systems</i>	Peter Sherriff	Concur		
Manager <i>System Planning</i>	Peter Casey	Concur		
Project Manager	Andrew Bannink.	Approve		

Distribution

Name	Role	Section

Revision Control

Revision Number	Date	Amendment Details	Responsible Officer
Version 0.00	16/08/2005	Original Draft: — Developed from Connell Wagner SP306 Revised Functional Spec	Alex Witthoft
Version 0.01	25/7/06	Updated approval sheet, removed flowmeter reference.	Gerard Anderson
Version 0.02	2/8/06	Updated approval sheet, Pump kW, picture details.	Gerard Anderson
Version 0.03	21/8/06	Updated confirmed sewer surcharge level and surcharge imminent level for SP306 (Noel Ralph). Station changed to Stop/Start at 50Hz (RM). Added Gravity Sewer alarm level diagram. Set High Level setpoint to 0.4M above TWL. Set pump inhibit limits to 200 and 400mm below Surcharge Imminent	Gerard Anderson
Version 1.00	14/3/2007	Site commissioned. Added level ranges.	Gerard Anderson

Document Consultation

Please review the attached document and add your comments where necessary. To ensure that the process is kept within reasonable timeframes, it would be appreciated if you could return this document by the **Requested Return Date** listed below.

Project Sponsor: Andy Moore

Officer Code: PM13BW

Location: T.C.B. Level 2

Author: Alex Witthoft/
Gerard Anderson

Officer Code: CTAMP12/
E2SBW

Location: Cullen Ave

Document Administrator: Gerard Anderson

Officer Code: E2SBW

Location: Cullen Ave

Version Number (1,2,3 etc)	Forwarded To: (Name / Officer Code)	Location (eg,TCB, Cullen Ave)	Date Sent	Requested Return Date	Date Returned	Comments Received (Y / N)	Comments Incorporated (Y / N)
PLEASE RETURN THIS DOCUMENT TO THE ABOVE DOCUMENT ADMINISTRATOR							
DO NOT SEND IT ANYWHERE ELSE!							

Table of Contents

1	INTRODUCTION.....	5
1.1	GENERAL PROCESS DESCRIPTION.....	6
2	EQUIPMENT INSTALLED.....	7
2.1	STANDARD EQUIPMENT.....	7
2.2	NON STANDARD EQUIPMENT.....	7
2.2.1	Emergency Generator.....	7
2.2.2	Gravity Sewer Monitoring.....	7
3	CONTROL PHILOSOPHY.....	8
3.1	SITE SPECIFIC VALUES.....	9
3.2	NON STANDARD MONITORING AND ALARMS.....	11
3.2.1	Gravity Sewer Level.....	11
	Invalid.....	12+1
	Low Alarm.....	12+1
	High Alarm.....	12+1
3.3	NON STANDARD IDTS PICTURE.....	13+2
3.4	SEWER NETWORK OVERVIEW.....	13+2
4	REFERENCES.....	14+3

Table of Figures

Figure 1: SP306 Location Map.....	5
Figure 2: SP306 Process and Instrumentation Overview.....	6
Figure 3: SP306 Station Level Set Points.....	8
Figure 4 SP306 Details Page.....	13+2

Table of Tables

Table 1: Site Specific Constants defined in the PLC.....	9
Table 2: Site Specific Constants defined in the RTU.....	9
Table 3: Site Specific Variable defined in the RTU.....	9
Table 4: Wet Well Level vs Volume Data.....	10

Definitions

BWTS	Brisbane Water Telemetry System
RTU	Remote Telemetry Unit
SCADA	Supervisory Control And Data Acquisition
MAHD	Metres above Australia Height Datum

1 INTRODUCTION

This document contains the site specific details and describes the non standard functional requirements for control, monitoring and telemetry at sewage pump station SP306 at Coronation Drive, Toowong, opposite Patricks Lane. The functional requirements described in the document are in addition to the standard functionality detailed in “SPSV3 SEWAGE PUMPING STATION SUBMERSIBLE 3 PUMPS WITH VFD”¹.

The standard specification was written for a 3 pump station, of which only 2 pumps are allowed to run at any given time. The functionality for SP306 Coronation Drive is identical, except the third pump is removed. The pumps are interlocked so that only one pump can operate at a time. All site specific values are detailed in this document. The site specific details and the non standard functional requirements in this document were derived from the functional specification written by Connell Wagner “PATRICK LANE FUNCTIONAL SPECIFICATION”².

SP306 Coronation Drive sewage pump station is required to relieve the surcharging in the Coronation Drive gravity sewer. Under wet weather flow conditions, the gravity sewer is susceptible to surcharge and overflows to the environment. SP306 Coronation Drive is therefore wet weather sewage pump station only, incorporating two variable speed driven 65 kW submersible pumps operating in a one duty and one standby arrangement




Figure 1: SP306 Location Map

1.1 General Process Description

SP306 Coronation Drive pump station will be connected to the gravity sewer via a short inlet. During wet weather events the sewage will flow into the well. This sewage will then be pumped into the rising main. This will continue until the level in the gravity sewer has receded, at which point the pumps shall stop under level control.

The sewage Pumping Station is of underground configuration operating in wet weather conditions only, with a wet well operating volume (under surcharge) of approximately 10 kl. The pump station will operate as a surcharge pump station, only allowing flows into the wet well during periods of surcharge in the adjacent gravity sewer. The wet well will be free to drain back into the gravity sewer at the end of the surcharge event. The pump station will have two submersible type sewage pumps installed in the Pump Well operating as duty/standby units. The pumps are interlocked so that only one pump can operate at a time. The station output with one pump operating at maximum speed will be approximately 150 l/sec.

This pump station will operate as a stop/start station only, there will be no PID control at this site. Pump speed will be limited to 50Hz, this is designed to pump down the Wet Well as quickly as possible.




Figure 2: SP306 Process and Instrumentation Overview

2 EQUIPMENT INSTALLED

2.1 Standard Equipment

SP306 Coronation Drive pump station has the following standard equipment installed. The functionality for the control, monitoring and alarming for these items is fully described in the standard functional specification.

Pumps	Two Grundfoss submersible pumps with 65 kW four pole electric motors are installed in the wet well. Each pump is fitted with moisture probes in the oil chamber and thermistors in the stator windings.
Pump Starters	Two Danfoss Variable Frequency Drives (VFDs) are installed in the pump station switchboard. The VFDs will also provide soft starting functionality.
Level Sensors	One Vega hydrostatic level transmitter installed in the wet well. One Multitrode level probe (Surcharge imminent) installed in the wet well.
Pressure Transmitters	One Vega D84 pressure transmitters are installed on the discharge side of the pumps.

2.2 Non Standard Equipment

SP306 Coronation Drive pump station has the following non standard equipment installed. The functionality for the control, monitoring and telemetry for is described in the following sections as these items are NOT described in the standard specification. The pumps are interlocked so that only one pump can operate at a time.

Emergency Generator	The switchboard will have the facility for a generator to be connected. No generator will be installed on site.
Level Sensors	One Vega hydrostatic level transmitter installed in the gravity sewer One Multitrode level probe (Gravity Sewer High) installed in the gravity sewer
Reflux Limit Switches	Each pumps reflux valve has a reflux limit switch fitted. NB There is no flowmeter onsite.
Wet well washer solenoid	Well washer solenoid valve with flow switch installed in the wet well. Note that there is currently no water supply to the Wet well washer. The Wet Well washer will not be commissioned at this stage.

2.2.1 Emergency Generator

The emergency generator is designed to the standard functionality as described by “DIESEL STANDBY GENERATOR LOCAL CONTROL PANEL FUNCTIONAL DESCRIPTION”.³ The generator is supplied with the PLC fully configured and loaded with the standard program. The RTU (Logica MD3311) will programmed with the standard interface program that will provide the monitoring, control and telemetry to the BWTS master station.

2.2.2 Gravity Sewer Monitoring

The gravity sewer will also have monitoring in the form of a vega hydrostatic level transmitter as well as a gravity high multitrode electrode.

3 CONTROL PHILOSOPHY

The station will operate according to the control philosophy detailed in the standard functional specification (SPSV3).

The initialisation block will be configured with the site specific set points listed in the tables in the next sections.

Surcharge Occurring & Surcharge Imminent mAHD will be the same levels as the gravity main setup (confirmed with Noel Ralph). There is no physical surcharge pipe at SP306. Inlet level of pipe from gravity main to wet well is IL - 3.790.




Figure 3: SP306 Station Level Set Points
SOME LEVELS MAY CHANGE ACCORDING TO COMMISSIONING FIGURES

3.1 Site Specific Values

Table 1: Site Specific Constants defined in the PLC

Tag Name	Description	Type	Value	Units
Sewerage Pumping Station				
Stn01grSurchPumpingTime	Surcharge pumping duration ³	Integer	60	Sec
Delivery pressure				
Pre01txRange	Delivery pressure - Range	Real	5000	mmAHD/10
Pre01txZero	Delivery pressure – Elevation of the transducer	Real	273	mmAHD/10
Pump Blockage				
Stn01grPmpBlockFlowKneeSP	Flow blocked limit for flow/level PID control (knee)	Integer	N/A	l/s x 100
Stn01grPmpBlockSpeedKneeSP	VFD speed blocked limit for flow/level PID control (knee)	Integer	N/A	Hz x 100
Stn01grPmpBlockSpeedMinSP	VFD speed blocked limit for minimum flow PID control	Integer	N/A	Hz x 100
Wet well level				
Wwl01txRange	Wet well level range	Integer	10	mmAHD
Wwl01txSurchImmLevelSP	Wet well surcharge imminent level (300mm below Overflow #330 Coronation Drive "Oxleys on the River" Surcharge point of 0.070 MAHD)	Integer	-0.230	mmAHD
Wwl01grInhStartLevelSP	Wet well inhibit mode start level	Integer	-0.430	mmAHD
Wwl01grInhStopLevelSP	Wet well inhibit mode stop level	Integer	-0.630	mmAHD
Wwl01grRunatMaxLvISP	Wet well run at maximum speed level	Integer	N/A	mmAHD
Wwl01txDtyBStartLevelSP	Wet well duty B pump start level	Integer	N/A	mmAHD
Wwl01txPIDLevelSP	Wet well PID set point	Integer	-2200	mmAHD
Wwl01txDtyAStartLevelSP	Wet well duty A pump start level	Integer	-2500	mmAHD
Wwl01txDtyAStopLevelSP	Wet well duty A pump stop level	Integer	-3160	mmAHD
Wwl01txDtyAStopLevelSP	Wet well duty A pump stop level	Integer	-3160	mmAHD
Wwl01txZero	Wet well empty level (4mA of Probe)	Integer	-3580	mmAHD
Variable Frequency Drive				
Stn01grMinSpeed	Variable Frequency Drive – Minimum Speed	Integer	5000	Hz x 100
Stn01grMaxSpeed	Variable Frequency Drive – Maximum Speed	Integer	5000	Hz x 100

Table 2: Site Specific Constants defined in the RTU

Tag Name	Description	Type	Value	Units
prelalmInhibitTm	Delivery pressure - Alarm inhibit timer	Integer	15	sec
wwlIsurchLvlVol	Wet well volume at surcharge level	Real		kl
wwlIvlSurcharge	Wet well surcharge occurring level	Real	0.070	mAHD
Pumps 1 & 2				
Pmp[x]almInhPwrTm	Pump [x] - Motor power alarm inhibit timer.	Integer	15	sec
pmp[x]almInhCmtTm	Pump [x] - Motor current alarm inhibit timer.	Integer	15	sec
pmp[x]currRange	Pump [x] - Motor current range	Real	120.0	Amps

Table 3: Site Specific Variable defined in the RTU

Wet well level				
wwlHighLimit	Wet well level - High alarm set point	Integer	-2.100	mmAHD
wwlLowLimit	Wet well level - Low alarm set point	Integer	N/A	mmAHD
Delivery flow				
flwHighLimit	Delivery flow - High alarm set point	Integer	N/A	ml/s x 10
flwLowLimit	Delivery flow - Low alarm set point	Integer	N/A	ml/s x 10
Delivery pressure				
preHighLimit	Delivery pressure DN1370 – High alarm set point	Integer	Max	mmAHD
preLowLimit	Delivery pressure DN1370 – Low alarm set point	Integer	Min	mmAHD
Pumps 1 & 2				
pmp[x]currHiLimit	Pump [x] - Motor current high alarm set point ⁴	Integer	130	Amps
pmp[x]currLoLimit	Pump [x] - Motor current low alarm set point ⁵	Integer	130	Amps
pmp[x]powHiLimit	Pump [x] - Motor power high alarm set point	Integer		Watts
pmp[x]powLoLimit	Pump [x] - Motor power low alarm set point	Integer		Watts

Table 4: Wet Well Level vs Volume Data


	Height (mAHD)	Volume m ³	Remaining Storage m ³	% Level	% Volume
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					

3.2 Non Standard Monitoring and Alarms

3.2.1 Gravity Sewer Level

As the Vega probe takes a few seconds to initialise, all the wet well alarms except for invalid, are suppressed for 10 seconds upon RTU start up.

Gravity Sewer	Invalid	1
Gravity Sewer	Low_alarm	3
Gravity Sewer	Patricks Lane Surchage Occuring alarm	1
Gravity Sewer	Patricks Lane Overflow Warning High_high alarm	1
Gravity Sewer	330 Coronation Drive Oxleys on the River" Surchage Occuring alarm	1
Gravity Sewer	330 Coronation Drive Oxleys on the River" Overflow Warning High alarm	1



Invalid

The signal is deemed invalid if it is :

Less than (4mA – dead band) or greater than (20mA + dead band) for 1 second.

Once the invalid alarm has been activated it can only be reset when the signal is both greater than 4mA and less than 20mA for 20 seconds. The time delays ensure that a signal is truly invalid before an alarm is set and that it is stable before it is reset. The dead band is calculated using the site invalid hysteresis value multiplied by the range.

If the gravity sewer level becomes invalid, the gravity sewer low and high alarm alarms are suppressed.

NOTE: As the wet well level is backed up by the battery – the site power does **not** suppress the invalid alarm.

Low Alarm

If the signal is valid and the start up delay has expired then the low alarm is activated if the signal is less than the low limit set point. It is deactivated if any of the above conditions become false or the signal is greater than the low limit set point plus the dead band. The dead band is calculated using the alarm hysteresis value multiplied by the range.

High Alarm

If the signal is valid and the start up delay has expired then the high alarm is activated if the signal is greater than the high limit set point. It is deactivated if any of the above conditions become false or the signal is less than the high limit set point minus the dead band. The dead band is calculated using the alarm hysteresis value multiplied by the range.

3.3 Non Standard BWTS Picture




Figure 4 SP306 Details Page

3.4 Sewer Network Overview

The sewer network overview page will be updated to include the gravity sewer at Coronation drive pumping into the new S1 rising main at Coronation drive.

4 REFERENCES

1

TITLE	SPSV3 Sewage Pumping Station Submersible 3 Pumps With VFD – Functional Specification
DOCUMENT ID	003589
VERSION	0.30
AUTHOR	Alex Witthoft , Brisbane Water – Network Control Systems
DOCUMENT OWNER	Peter Sherriff, Brisbane Water – Network Control Systems

2

TITLE	Heroes Avenue Functional Specification
DOCUMENT ID	N/A
VERSION	N.A
AUTHOR	N.A
DOCUMENT OWNER	Cardino Davies Pty Ltd

3

TITLE	Diesel Standby Generator - Local Control Panel - Functional Description
DOCUMENT ID	N/A
VERSION	02
AUTHOR	SOUTH EAST POWER GENERATION
DOCUMENT OWNER	

STAGE 2 SYSTEM INTEGRATION TESTING PROCEDURE
CORONATION DRIVE PUMP STATION SP306 (New Rising Main) TO NORTH QUAY
EXISTING S1 SEWER CONNECTION

Minutes of Meeting. Place: BW-Projman Conference Room
Tuesday 06 March 2007 Time 09:00hrs to 10:00hrs

Agenda:

Review of Stage 2 System Integration Testing Procedure SP 306 Rev 1

Staff responsibilities.

All work completed for commissioning to proceed on 14/15 March 2007 Start Time 06:00am.

Present: Ron Wilson (BW)
 Neville Stanton (BW)
 Jeff Browne (BW)
 Gerard Anderson (BW)
 Bill Collie (BW)
 Reg McGirr (BW)

The following is a brief overview of the meeting.

- 1) Stage 2 System Integration Testing Procedure 28 February 2007 Rev 1/Inspection Check List 1 & Drawings were handed out to all present at meeting. Brief review of procedure.
- 2) Review of procedure/check list & drawings with Ron Wilson/ Neville Stanton.
- 3) Review of electrical pre-commissioning by Bill Collie.
 - One of the pumps water in oil sensor faulty HVAC to investigate ASAP.
 - Reflux Limit Switches to be checked before commissioning and final set-up at commissioning.
 - Bill will arrange electrical leads for Generator connections into Coronation Drive switchboard.
 - Bill has checked the size of Generator at Lytton Road pumping station and OK to use at Coronation Drive SP306 for switchboard/pump generator testing.
- 4) Review of RTU/PLC pre-commissioning Gerard Anderson.
 - All OK.
 - Gerard will arrange for Lytton Rd pumping station to be redirected (taken out of service) before we remove the generator to Coronation Drive pumping station.
- 5) Ron Wilson will arrange the following:
 - The complete car parking area to be cordoned off for Generator and BW Commissioning personal only. From 13 March 07 to 16 March 07.
 - Arrange for the generator at Lytton Rd to be removed and placed in the car parking area at Coronation Drive pumping station on 14 March 07 time 22:00hrs. Arrange traffic control if required.
 - Inform the appropriate people (eg Local member/Residence) of commissioning and the car park will be cordoned off.
 - Supply 2 confined space trained personal with all equipment for 2days of commissioning.

- 6) Reg McGirr to update Stage 2 System Integration Testing Procedure to reflect the following test.
- Heroes Avenue P/S SP103 Wet Well level to just below surcharge level and repeat the same at Coronation Drive P/S SP306.
 - With the two pumping stations running at full capacity record pump trends at the two sites.
 - The above tests will indicate if SP306 pumping into the new rising main has any influence on SP103. The same goes for SP103 pumping into the new rising main has any influence on SP306.
 - The above tests will be carried out after the full commissioning has been completed.

Commissioning dates to be confirmed on Monday 12 March 07.

Stuart Cowhig - Fwd: Outstanding Commissioning of Stage 2 System Integration Testing Coronation Drive P/S SP306.

From: Reg McGirr
To: Cowhig, Stuart
Date: 9/05/2007 12:45:24 pm
Subject: Fwd: Outstanding Commissioning of Stage 2 System Integration Testing Coronation Drive P/S SP306.

Regards,
 Reg McGirr
 Commissioning Manager
 Tel: 07 34033349
 Mobile: 0414576374
 E-mail: Reg.McGirr@brisbane.qld.gov.au

>>> Reg McGirr 23/04/2007 13:30 >>>
 To All,

All outstanding commissioning of SP306 will be carried out on Friday 27 April 07 Time 6am.

1) Gerard will arrange for Lytton Rd pumping station to be redirected (taken out of service on 26 April 07) before we remove the generator to Coronation Drive pumping station.

a) Generator testing switching in & out in the auto mode as per Stage 2 System Integration Procedure 08 March 2007 Rev 2 Item 8.1.

b) Testing the code/system for pumps to run for 30sec every three (3) days to prevent rotor lock.

c) All outstanding testing regarding switchboard control.

2) Bill will arrange electrical leads for Generator connections into Coronation Drive switchboard.

3) Sid will arrange the following:

a) The complete car parking area to be cordoned off for Generator and BW Commissioning personal only. From 26 April 07 to 27 April 07.

b) Arrange for the generator at Lytton Rd to be removed and placed in the car parking area at Coronation Drive pumping station on 26 April 07 time 22:00hrs. Arrange traffic control if required.

c) Inform the appropriate people (eg Local member/Residence) of commissioning and the car park will be cordoned off.

d) Supply 2 confined space trained personal with all equipment for 1day of commissioning.

e) Arrange for generator to be removed from Coronation Drive P/S SP306 and reinstalled/cables connected at Lytton Rd. Once the generator cables have been connected the control room to be contacted and the station to be put back on line.

Should you require further information please contact me.

Regards,
 Reg McGirr

Commissioning Manager
Tel: 07 34033349
Mobile: 0414576374
E-mail: Reg.McGirr@brisbane.qld.gov.au

Vol 4 - Sect 3



Methodology Statement on Procedure to carry out Patrick Lane Works

ISSUE: 01
DATE: 10/02/2005

**REDIRECTION OF HEROES AVENUE SEWERAGE
PUMP STATION, MECHANICAL & ELECTRICAL
FITOUT AND COMMISSIONING**
CONTRACT NO.: BW.30079-02/03



Doc No.: WMS_PL
Date : 10/02/2005

Contract BW.30079-02/03 - HEROES AVENUE MECHANICAL & ELECTRICAL FITOUT
Patrick Lane Work Method Statement



REVISION STATUS

Date	Description	Original	Review	Approval
10/02/2005	Issued for Approval	Garth Hamilton	Graham James	

The information contained in this document is the property of HVAC/HPS Queensland Pty Ltd and must not be used for commercial or other purposes without prior approval.

Doc No.: WMS_PL
Date : 10/02/2005

Contract BW.30079-02/03 - HEROES AVENUE MECHANICAL & ELECTRICAL FITOUT
Patrick Lane Work Method Statement



1. OVERALL MANAGEMENT

The project manager will set up a "kick-off" meeting with Brisbane Water. All aspects of the works are to be discussed.

All work is to be carried out at "Patrick Lane" site on Coronation Drive Taringa.

Scheduling and planning of this aspect of the project is the single most important criteria if a successful outcome is to be achieved.

HVAC/hps planning engineer will work closely with the project team to monitor any design and construction issues that may arise.

2. METHOD STATEMENT

The works shall comprise the following principal activities plus all other activities necessary for the completion of the works as may be reasonably inferred from the Drawings and Specifications:

- Fitout existing wet well structure with all appurtenances and benching;
- Two new submersible sewage pumps;
- Power supply, controls and electrical works;
- New pipework, fittings, valves and actuator; and
- Surface works including stairs, general services, vent stack and fan pit.

3. CONSTRUCTION METHODOLOGY – DETAILED BREAKDOWN

1. Install Ladder in Existing Wet Well.
2. Excavate area between existing pipework chamber and existing wet well including excavation for electrical conduit installation. De-watering as required.
3. Install non-return valve and dismantling joint in existing valve chamber.
4. Install flanged mild steel fusion bonded PE lined and coated pressure pipework, fittings and supports between dismantling joint and existing wet well.
5. Continue 100mm Electrical conduit run from existing to RPZ housing and Limit switches in valve chamber.

Doc No.: WMS_PL
Date : 10/02/2005

Contract BW.30079-02/03 - HEROES AVENUE MECHANICAL & ELECTRICAL FITOUT
Patrick Lane Work Method Statement



6. Install PE induct ventilation pipework and fittings
7. Refill and compact excavated area.
8. Construct Induct / Fan pit.
9. Install in existing wet well, flanged mild steel fusion bonded PE lined and coated pressure pipework, fittings and supports
10. Install UPVC educt ventilation pipework and fittings
11. Install bar screens in manhole.
12. Construct benching in base of wet well.
13. Line wet well with protective coating
14. Install valve actuator and housing
15. Install well washer and water supply pipes and fittings
16. Install new submersible pumps
17. Construct concrete slab for switchboard
18. Electrical fit out
19. Construct concrete stairs
20. Connect rising main scour valve to PE discharge line within valve pit
21. Construction of Vent Pole
22. Construct new curbing and reinstate grassed area
23. Commission site

BRISBANE CITY COUNCIL Brisbane Water PATRICK LANE PUMP STATION	SP 306 OPERATING AND MAINTENANCE MANUAL Part 3: Appropriate Records	Contract No.: BW.30079-02/03 M & E Fitout & Commissioning
---	--	--

8. Completed Precommissioning and Commissioning Report

-----This section to be completed later.-----

BRISBANE CITY COUNCIL Brisbane Water PATRICK LANE PUMP STATION	SP 306 OPERATING AND MAINTENANCE MANUAL Part 3: Appropriate Records	Contract No.: BW.30079-02/03 M & E Fitout & Commissioning
---	--	--

9. As Constructed Drawings

Please refer to Appendix 30: As Built Drawings for the following drawings.

BW Drawing No.	CW / HVAC / MPA Drawing No.	Rev.	Drawing Title
486/5/7-KJ001	ME029	A	MH 2/1 PS 1/1 AND PS 2/1 CONTRACTOR LAYDOWN AND SITE ACCESS
486/5/7-KJ002	ME030	B	PUMP STATION PS 1/1 AND PS 2/1 GENERAL ARRANGEMENT
486/5/7-KJ003	ME031	A	PUMP STATION PS 1/1 AND PS 2/1 DETAILS
486/5/7-KJ004	ME032	A	PUMP STATION PS 1/1 AND PS 2/1 GSD, TED, TAC
486/5/7-KJ006	0203-E201	B	PATRICK LANE PS POWER DISTRIBUTION SCHEMATIC DIAGRAM
486/5/7-KJ007	0203-E202	B	PATRICK LANE PS PUMP 01 SCHEMATIC DIAGRAM
486/5/7-KJ008	0203-E203	B	PATRICK LANE PS PUMP 02 SCHEMATIC DIAGRAM
486/5/7-KJ009	0203-E204	B	PATRICK LANE PS MOTORISED VALVE SCHEMATIC DIAGRAM
486/5/7-KJ010	0203-E205	B	PATRICK LANE PS DC POWER SUPPLY SCHEMATIC DIAGRAM
486/5/7-KJ011	0203-E206	B	PATRICK LANE PS MITS RTU DIGITAL INPUT SHEET 1
486/5/7-KJ012	0203-E207	B	PATRICK LANE PS MITS RTU DIGITAL INPUT SHEET 2
486/5/7-KJ013	0203-E208	B	PATRICK LANE PS MITS RTU DIGITAL OUTPUT
486/5/7-KJ014	0203-E209	B	PATRICK LANE PS MITS RTU ANALOGUE INPUT
486/5/7-KJ015	0203-E210	B	PATRICK LANE PS PLC DIGITAL INPUTS SLOT 3
486/5/7-KJ016	0203-E211	B	PATRICK LANE PS PLC DIGITAL INPUTS SLOT 4
486/5/7-KJ017	0203-E212	B	PATRICK LANE PS PLC DIGITAL INPUTS SLOT 5
486/5/7-KJ018	0203-E213	B	PATRICK LANE PS PLC DIGITAL OUTPUTS SLOT 6
486/5/7-KJ019	0203-E214	B	PATRICK LANE PS PLC ANALOGUE INPUTS SLOT 7
486/5/7-KJ020	0203-E215	B	PATRICK LANE PS PLC ANALOGUE INPUTS SLOT 8
486/5/7-KJ021	0203-E216	B	PATRICK LANE PS PLC ANALOGUE OUTPUT SLOT 9
486/5/7-KJ022	0203-E217	B	PATRICK LANE PS CABLING BLOCK DIAGRAM
486/5/7-KJ023	0203-E218	B	PATRICK LANE PS CABLE SCHEDULE
486/5/7-KJ025	HVAC-	C	CORONATION DRIVE PUMP STATIONS PS 1/1 AND PS 2/1 PLAN
486/5/7-KJ026	HVAC-	C	CORONATION DRIVE PUMP STATIONS PS 1/1 AND PS 2/1 ELEVATION
486/5/7-KJ027	HVAC-	C	CORONATION DRIVE PUMP STATIONS PS 1/1 AND PS 2/1 PIPE FITTING DETAILS
486/5/7-KJ028	HVAC-SK-01	A	CORONATION DRIVE PUMP STATIONS PS 1/1 AND PS 2/1 PLAN OF FLANGE MODIFICATIONS

BRISBANE CITY COUNCIL Brisbane Water PATRICK LANE PUMP STATION	SP 306 OPERATING AND MAINTENANCE MANUAL Part 3: Appropriate Records	Contract No.: BW.30079-02/03 M & E Fitout & Commissioning
--	--	--

BW Drawing No.	CW / HVAC / MPA Drawing No.	Rev.	Drawing Title
	7690-G20	4	MPA PATRICK LANE SWITCHBOARD GENERAL ARRANGEMENT
	7690-G21	5	MPA PATRICK LANE SWITCHBOARD GENERAL ARRANGEMENT
	7690-G22	5	MPA PATRICK LANE SWITCHBOARD SECTIONAL VIEWS
	7690-G24	1	MPA PATRICK LANE SWITCHBOARD GENERAL ARRANGEMENT

BRISBANE CITY COUNCIL Brisbane Water PATRICK LANE PUMP STATION	SP 306 OPERATING AND MAINTENANCE MANUAL Part 3: Appropriate Records	Contract No.: BW.30079-02/03 M & E Fitout & Commissioning
---	--	--

10. List of Contract Variations and Plant Modifications

The contract variations for contract BW.30079-02/03 are as listed in the attached variation register.

HVAC NO.	DESCRIPTION	DATE SUBMITTED
1	Additional Bank Guarantees for Early Payment	21/07/2004
2	Upgrade of Motor Insulation from Class F to H on Pumps	21/07/2004
3A	Tender Vs 'Issued for Construction' Drawing Changes - Civil	15/10/2004
3B	Tender Vs 'Issued for Construction' Drawing Changes - Mechanical	
3C_1	Heroes Ave Tender Vs Construction Dwg. Changes - Electrical	15/10/2004
3C_2	Hockings Street Tender Vs Construction Dwg. Changes - Electrical	25/11/2004
3C_3	Patrick Lane Tender Vs Construction Dwg. Changes - Electrical	22/12/2004
4	Hockings St Electrical Supply & Streetlight Mains Relocation	09/08/2004
5	Remove Trees, garden bed & stairs Heroes Ave (PS-37)	25/08/2004
6A	Installation of Temporary Wet Well (Hallco's Work)	01/12/2004
6B	Installation of Temporary Wet Well (HVAC's Work)	01/12/2004
6B-1	Installation of TWW Additional Pipework and Cabling	09/02/2005
6B-2	Provision of Access Ladders and Platforms in Temporary Wet Well	04/02/2005
6B-3	Provision and Maintenance of Odour Control Equipment in Temporary Wet Well	04/02/2005
6C	Deletion of Grit Chamber	16/12/2004
6D	Contract Oncost and Contract Profit 10% and overhead 10%	11/01/2005
7	Transformer Culvert and Conduits	22/09/2004
7_Rev1	Transformer Drawing, Retaining wall, Concrete Pad, Safety Fence	27/10/2004
8	Harmonic Filter IP Upgrade	13/10/2004
9	Hockings St Streetlight Upgrade	14/10/2004
10A	EOT Claim #1	14/10/2004
10B	EOT Claim #2	14/10/2004
10C	EOT Claim #3	14/10/2004
11	EOT Claim 4B	21/03/2005
12	Temporary Wet Well Spoil	20/01/2005
13	Hockings Street Access Dates/ Deletion of Hockings St and XXXX	07/02/2005
14	Temporary Wet Well Roof	24/01/2005
15	Bypass Reducer	02/02/2005
16	Changes Patrick Lane Switchboard and/or Installation (PS-42)	18/08/2005
17	Practical Completion Dates	22/02/2005
18	EOT Claim #5	27/01/2005
19	EOT Claim #6	28/01/2005

BRISBANE CITY COUNCIL Brisbane Water PATRICK LANE PUMP STATION	SP 306 OPERATING AND MAINTENANCE MANUAL Part 3: Appropriate Records	Contract No.: BW.30079-02/03 M & E Fitout & Commissioning
---	--	--

HVAC NO.	DESCRIPTION	DATE SUBMITTED
20	Temporary Switchboard Additional Works	09/02/2005
21	Additional requirements Temporary Wet Well - Pump Base Supports	18/02/2005
22	Additional requirements Temporary Wet Well - Vega Well Tx	18/02/2005
23	Additional requirements Temporary Switchboard - Provision of ATS (Automatic Transfer Switch)	18/02/2005
24	Modification to S1 Sewer Connection Line	04/03/2005
25	H2S Gas in S1 Connection Scouring Pit	04/03/2005
26	Supply and Installation of Gibault Joint	08/03/2005
27	Changes Patrick Lane Piping (PS-39)	08/03/2005
28	Delays due to rising main rupture	11/03/2005
29	Provision of New Service Pole	21/03/2005
30	EOT Claim #4	11/01/2005
31	EOT Claim #7	24/03/2005
32	Retention of overheads for grit chamber deletion	29/03/2005
33	Heroes Ave Pump Station New Lightings	09/05/2005
34	Wet Well Ladder	09/05/2005
35	Vactor Pipe	
36	EOT 8	28/04/2005
37	EOT 9	28/04/2005
38	Extra Works in Wet Well Platform Removal	03/05/2005
39	Extra Works in Wet Well Benching Removal	02/05/2005
40	Extra Works Dry Well Isolation	02/05/2005
41	Hockings Street Enclosure Changes	15/08/2005
42	Alarms - Withdrawn	
43	Supply & Installation of Self Closing Gates	01/06/2005
44	Repairs to Wet Well Structure	07/06/2005
45	Dry Well Platforms- Heroes Ave (PS-22)	07/06/2005
46	Supply and installation of disconnect boxes Heroes av	07/06/2005
47	Pressure Gauge Tapping Points	15/06/2005
48	Supply and Installation of Relays for Grundfos Pump Oil Sensors	22/06/2005
49	Sump Electrodes for Heroes Avenue	21/07/2005
50	400NB Gate Valve for Patrick Lane (PS-9)	21/07/2005
51	EOT #12	30/06/2005
52		
53	Wet Well Washer Installation Heroes Avenue (PS-40)	30/09/2005
54	New Pressure Transmitter for Heroes Avenue(PS-07)	25/07/2005
55	Mounting Disconnect Boxes incl supply & install of 3 control disconnect boxes (PS-08)	27/07/2005
56	Cable Socks at Patrick Lane (PS-21)	28/06/2005
57	Construct and Supply Recirculation pipeline (PS-14)	25/07/2005
58	Removal of Switchboard Containing Asbestos (PS-17)	21/07/2005
59	Painting of Patrick Lane Vent pole (PS-20)	25/07/2005

BRISBANE CITY COUNCIL Brisbane Water PATRICK LANE PUMP STATION	SP 306 OPERATING AND MAINTENANCE MANUAL Part 3: Appropriate Records	Contract No.: BW.30079-02/03 M & E Fitout & Commissioning
---	--	--

HVAC NO.	DESCRIPTION	DATE SUBMITTED
60	By-pass Pumping System Settlement Adjustment	21/07/2005
61	EOT Settlement Adjustment	21/07/2005
62	Hockings St Takeout Settlement Adjustment	21/07/2005
63	After Hours Attendance of Bypass(PS-09)	21/07/2005
64	Extension of temporary Bypass Operation (PS-19)	22/07/2005
65	New Vent Fan GPO (PS-10)	25/07/2005
66	After Hours Attendance of Bypass 04/08/05 (PS-24)	05/08/2005
67	Supply and Installation of 100NB Gate Valve (PS-25)	08/08/2005
68	Induct Pit Patrick Lane (PS-41)	16/08/2005
69	Wet Well Covers Heroes Avenue (PS-28)	18/08/2005
70	Removal of Recirculation Pipeline and Reinstatement of Valve Pit (PS-31)	05/10/2005
71	Additional Pipe Supports in Dry Well (PS-38)	05/10/2005
72	Chains for Patrick Lane Pumps (PS-27)	18/08/2005
73	Switch Board Modifications (Indooroopilly pumping hardware interlock (PS-46))	25/10/2005
74	Valve Lockouts (Heroes Ave & Patrick Lane) (PS-44)	25/10/2005
75	Ladder for Valve Pit - Heroes Avenue (PS-43)	25/10/2005
76	Preparations For Indooroopilly commissioning incl Barrel Unions & Nipples for Vega Pressure gauges (PS-45)	25/10/2005
77	Remove Overflow plate - Heroes Ave (PS-34)	21/09/2005
78	Additional Drafting & Surveying (PS-36)	21/09/2005
79	Patrick Lane Temporary Fencing (PS-35)	22/09/2005
80	Extra Works CPS- Patrick Lane (PS-30)	31/10/2005
81	Extra Works CPS-Heroes Ave (PS-47)	24/11/2005
82	Valve Testing Heroes Avenue (PS-48)	31/10/2005
83	Loosen Pump Flanges For Inspection - Heroes Ave (PS-49)	31/10/2005
84	Indooroopilly Emergency Pumping Commissioning (PS-32)	30/09/2005
85	Heroes Kick rail & Mesh (PS-50)	31/10/2005
86	Washdown & Sump Pump Pipework (PS-51)	31/10/2005
87	Supply of Flexible Connectors for Hocking St (PS-29)	31/08/2005
88	Supply of Multitrode Probes for Hocking St (PS-33)	31/08/2005
89	Additional Site Surveys (PS-52)	24/10/2005
90	Fencing Hire October (PS-53)	31/10/2005
91	Heroes Ave Valve Backfilling (PS-54)	10/11/2005
92	Heroes Ave Transformer Landscaping (PS-55)	24/11/2005

**Corrosion Protection Services
CPS Sewerage Lining System**

11.5 Sample Site Management Plan

**PUMPSTATION REFURBISHMENT
HERO'S AVENUE
and
PATRICK'S LANE
BRISBANE QLD 4000**

**HVAC
BRISBANE QLD**

SITE MANAGEMENT PLAN

To be read in conjunction with:

Workplace Health & Safety Policy

Confined Space Entry Procedure

Hazardous Substance Management Procedure

**CORROSION PROTECTION SERVICES PTY LTD
P O BOX 1094
HERVEY BAY QLD 4655
PHONE: 07 4194 0400
FAX: 07 4194 0500
MOBILE: 0407 940 409**

Revised Version 3

Page 14 of 64
CPS Sewerage Lining System

3 March 2005

ISSUE: 1

[illegible]

DATE:

Revised Version 3

Page 16 of 64
CPS Sewerage Lining System

3 March 2005

<p align="center">Corrosion Protection Services CPS Sewerage Lining System</p>

Project Details: Pumpstation Resurfacing
 City of Brisbane Qld

Work to be

Performed: Resurfacing of Wastewater Pumpstation – Hero's Avenue, Brisbane.
 Resurfacing of Wastewater Pumpstation – Patricks's Lane, Brisbane.

BACKGROUND AND EXTENT OF WORK

Rehabilitation and resurfacing of Pumpstations using the CPS System and KL11 applied to all internal surfaces at a thickness of 5mm.

SYSTEM CONSTRAINTS

- Clearly defined work areas, normal access for pedestrians.
- To be aware of access to private houses.
- Endeavour to keep traffic flow uninterrupted.
- Site is left clean & environmentally friendly

SAFE WORK PLAN / PROCEDURE FOR ENTRY INTO CONDUITS / CONFINED SPACES

The persons referred to below shall have the following responsibilities with regard to the implementation of this site plan for the project/works.

Site Manager

Kel Atkins/ Stephen Atkins are the people responsible for ensuring that the operations of the system in which the works / project is to be carried out and is able to be operated in a manner so as to ensure the safety of those persons engaged in the performance of that specific work / project. The Site Managers must provide a situation where the safe work plan is able to be implemented and the system safely recommissioned.

The Site Manager is also responsible for the supervision of the confined space entry and to ensure that all persons entering the confined space are accredited / trained, and that all persons entering the confined space are captured on the entry form. A Site Foreman will be nominated for all major projects, prior to work commencing.

Site Manager – Kel Atkins Mobile: 0407 940 409
 Stephen Atkins Mobile: 0408 728 156

Revised Version 3

Page 17 of 64
 CPS Sewerage Lining System

3 March 2005

**Corrosion Protection Services
CPS Sewerage Lining System**

Site Personnel

Is the person(s) responsible for carrying out the project / works. They will be required to follow specific instructions from the Site Manager during this specific works / project until the work / project is completed.

Site Personnel – Kane Dennis

SITE SAFETY RULES

- ALL VISITORS MUST REPORT TO SITE MANAGER IMMEDIATELY UPON ARRIVAL AT SITE. THE SITE MANAGER SHALL ENSURE ALL VISITORS ARE WEARING APPROPRIATE SAFETY GEAR AND THAT THEY ARE AWARE OF THE SITE SAFETY RULES BEFORE MOVING ON SITE.
- ALL SITE PERSONNEL MUST WEAR SAFETY FOOTWEAR AND VESTS WHEN ON SITE. WHILE IN CONFINED SPACES, PROTECTIVE HOODS TOGETHER WITH EAR & EYE PROTECTION MUST BE WORN.
- ALL PERSONNEL MUST UNDERGO SITE INDUCTION PRIOR TO COMMENCEMENT OF WORK AT SITE AND BE AWARE OF INCIDENT MANAGEMENT PROCEDURE.
- PERSONNEL ENGAGED IN CONFINED SPACE WORK MUST CARRY THEIR CURRENT CONFINED SPACE TRAINING TICKET WHEN AT SITE.
- ALL PERSONNEL SHALL ENSURE SAFETY OF PUBLIC NEAR TO WORK SITE. USE SIGNS AND BARRICADES AS APPROPRIATE.
- ANY RESIDENTS AFFECTED MUST BE NOTIFIED PRIOR TO ENTRY INTO THEIR PROPERTY.
- ALL WORK AREAS MUST BE MADE SAFE PRIOR TO LEAVING SITE.
- ALL VISITORS MUST REPORT TO SITE MANAGER BEFORE LEAVING TO ENSURE SAFE EXIT.

CONTACT SITE MANAGER,
KEL ATKINS
IF YOU REQUIRE FURTHER INFORMATION.

Revised Version 3

Page 18 of 64
CPS Sewerage Lining System

3 March 2005

**Corrosion Protection Services
CPS Sewerage Lining System**

IN THE EVENT OF AN ACCIDENT OR EMERGENCY:

1. IMMEDIATE CONTACT SHALL BE MADE WITH THE SITE MANAGER.
2. THE SITE MANAGER SHALL APPROVE AND OVERSEE THE MATTER AND ENSURE THE NECESSARY PROCEDURES ARE INSTIGATED.
3. PROCEDURES FOLLOWED AS PER OUR WH&S POLICY.

CORROSION PROTECTION SERVICES PTY LTD

WORKCOVER POLICY NO: FW 025159018

AMP GENERAL INSURANCE LTD - POLICY NO: 4 Y048839P

Including Public Liability \$20,000,000

Product Liability \$10,000,000

All work vehicles are covered by full comprehensive insurance.

1. GENERAL SITE SAFETY REQUIREMENTS

The following safety requirements shall be complied with at all times when on site:

- 1.1 **Safety Helmets**
Safety helmets shall be worn by all site personnel and associated visitors where necessary on site.
- 1.2 **Footwear**
Steel capped boots must be worn at all times.
- 1.3 **Protective Equipment**
Protective equipment, including eye and ear protection shall be worn where necessary. Air feed hoods are worn when confined space work is carried out.
- 1.4 **Alcohol**
The consumption of alcohol on site, or elsewhere, any time during working hours is prohibited.
- 1.5 **Confined Space Entry**
Confined space entry shall be done when required under the Confined space entry permit and checklist records. The entry will follow the procedure in confined space procedure. A copy of the confined space entry permit is attached. All open manholes or access points shall be barricaded during the works and securely covered when the work team is not present. Working signs will be placed in strategic positions as per WH&S requirements.

Responsible Manager for confined space entry would be our Site Manager, Kel Atkins who will be on site full time.

Revised Version 3

Page 19 of 64
CPS Sewerage Lining System

3 March 2005

Corrosion Protection Services CPS Sewerage Lining System

- 1.6 Accidents**
Accidents shall be reported immediately to the Site Manager. Any employee who is off for more than seven (7) days along with any dangerous occurrence, will warrant a report to be lodged with WorkCover Authority of Qld.
- 1.7 First Aid**
All persons requiring first aid treatment are to contact the first aid officer who will administer the treatment and record the accident in a report record book, the person's name and nature of the accident. First Aid Officer – Mr Kel Atkins.
- 1.8 Fire Prevention**
Fire extinguishers shall be kept on site and accessible with all site personnel aware of their placement and fully instructed in their usage.
- 1.9 Work Areas / Housekeeping**
Work areas will be kept clean and tidy from rubbish and other safety hazards. Rubbish will be cleaned up on completion of the day's / project's work.
- 1.10 Parking of Vehicles**
Where possible work vehicles will be parked off the road. When vehicles are parked on streets to access the work site, the working area will be marked using traffic cones. The appropriate traffic warning signs shall be placed prior to commencement of work. A safety vest will be worn when working on or near the roadways. All traffic control devices for works on roads would conform to AS 1742.3 – 1985.
- 1.11 Material Handling**
All materials are clearly labelled.
Materials are stored as per State and Technical Safety Data Legislation.
Minimal amounts are stored on site.
Bulk materials are stored at our Hervey Bay Depot and delivered overnight as required.
- 1.12 Site Amenities**
Site amenities will be provided on site, or central locations to site work.
- 2. FIRST AID / FIRE / EMERGENCY PROCEDURES**
If an accident / emergency happens on site, notify the Site Manager – Kel Atkins with the following details:
- Location of Accident / Emergency
 - Type of Injury / Emergency
 - Severity of Injury / Emergency
 - Will the authorities (ie ambulance) be required
 - The Site Manager shall approve and oversee the matter and ensure the necessary procedures are instigated.
- Giving such details as:
- Time of Injury
 - Location
 - Cause
 - Extent
 - Action Taken

Revised Version 3

Page 20 of 64
CPS Sewerage Lining System

3 March 2005

**Corrosion Protection Services
CPS Sewerage Lining System**

CONTACT NAME AND TELEPHONE NUMBERS

Kel Atkins Mobile: 0407 940 409

Ambulance Phone: 000

In the event of a major accident/incident, Managerial / Office personnel shall, as soon as possible, contact:

WorkCover 4122 3122

HVAC

- Mr Graeme James 0403 607 032

All verbal contact will be confirmed in writing as soon as possible after the event.

3. RISK ASSESSMENT

1.1 Confined Space Entry

Potential Risks

- Contaminated Gas Inhalation inside manholes
- Sudden surge of flow

Safeguards

- Gas detectors are used before and during entry to Pumpstation to monitor the contaminants in the confined space.
- The person entering the pumpstation wears a safety harness attached to a Rescue Master during the work period.
- Airs feed hoods are worn by workers in confined spaces, limiting contaminated gas inhalation.
- Continual mechanical ventilation of manhole.

3.2 Lining Process

Potential Risks

- Risks in Confined Space Entry
- Equipment Failure

Safeguards

- All personnel to be trained and accredited with their Confined Space Entry Certificate.
- All personnel evacuated if necessary, until equipment is restored to a safe working level.
- Standby equipment available

2. INSPECTION AND TESTING

2.1 Plant and Equipment

Plant and equipment used in the project are inspected and maintenance work is carried out at regular intervals.

Revised Version 3

Page 21 of 64

3 March 2005

CPS Sewerage Lining System

Corrosion Protection Services CPS Sewerage Lining System

2.2 Lining Process

It is the responsibility of the Site Manager to follow the procedures and checklists given below:

- Pumpstation Relining start
- Pumpstation relining in Process
- Pumpstation Relining finish
- Pumpstation Inspection
- Confined Spaces Entry checklist
- Traffic Control checklist (if applicable)
- Storage Handling & Packaging checklist
- Daily Site Record

3. TRAINING

3.1 Site Induction

The following particulars outline requirements and standard procedure for the Induction Briefing. All employees would be inducted prior to commencement of work at the project.

- Project Layout
- Tools and equipment – used for lining
- Site Traffic Control – (if applicable)
- Location of First Aid and Safety Officer
- Location of Work Areas
- Reporting
- Certification and Licensing
- Safety Requirements
- Lifting Techniques
- NO Alcohol or Drugs allowed at any time
- Housekeeping
- Hazardous Substances
- Handling of Materials

3.2 Confined Space Entry

All personnel involved in confined space entry would be trained to required specifications.

4. HAZARDOUS SUBSTANCES – REFER MANAGEMENT PROCEDURE

The material used in this project would be:

KL11 Seal System
KL11 Trowelable System
KL11 Top Coat System
MEKP
Acetone

Suppliers of all hazardous substances will be required to provide MSDS for all items supplied. All personnel involved in handling would be suitably trained operators as per Hazardous Substances, Usage and Handling documentation.

- Protective clothing shall be worn by the operator during handling of the chemicals.
- Material Safety Data sheets would be kept on site for reference.

Revised Version 3

Page 22 of 64
CPS Sewerage Lining System

3 March 2005

Corrosion Protection Services CPS Sewerage Lining System

4.1 Register and Inventories

A register or inventory shall be kept on site to provide a central listing of all chemicals in the project.

Registers and inventories will be kept in the same location as MSDS's and be accessible to operations.

4.2 Labels

All containers of substances supplied to be used or handled in the workplace will be labelled to allow people to use the substances safely.

4.3 Control

Control of hazardous substances will be achieved through progressive application of the following hierarchy of control measures:

- Isolation of the process to control the emission of hazardous substances
- Engineering control, including local exhaust ventilation for vapour, gases or particulate, to control or minimise hazardous substances or processes
- Adoption of safe work practices, including changes to work methods which minimise exposure to hazardous substances

4.4 Employee's Duties

- All employees working with or near hazardous substances will maintain safe work practices so that their health and safety, and the health and safety of those around them, is maintained.
- Employees will use the control measures provided to minimise the risk of exposure to hazardous substances.
- Personal protective equipment will be used when required. It should be kept clean and maintained in an appropriate manner.
- Defects discovered in any control measures including personal protective equipment will be reported promptly to the Site Manager.

4.5 Records

Employee records are kept at Head Office at Point Vernon.

Records will include inventories of hazardous substances, results of workplace monitoring and employee health surveillance.

**Corrosion Protection Services
CPS Sewerage Lining System**

ON SITE RISK MANAGEMENT AND SAFE WORK PROCEDURE

WHAT CAN GO WRONG	HOW IT WILL BE MANAGED
Confined Space Category: Confined space category could change due to flow atmospheric conditions	Gas testing to monitor the work atmosphere. If applicable, use of bypass plugs. Air feed hoods worn.
Isolation of Work Site: Flow in Pumpstation could alter	Situation regularly monitored. Evacuation if necessary until Flow is at an acceptable level.
Pre-Entry Inspection: Access Chamber isolated Site established Vehicles parked correctly	Site has been clearly barricaded to isolate access chamber. Appropriate signage put out as per requirements.
Access: Access will be required to pumpstation	Confined Space personnel to remain at access points at all times.
Methods of Work: Ventilation of carrier Equipment Failure	Maintain natural ventilation and Mechanical Ventilation Standby equipment available.
Suitable Workers: Untrained or unsuitable workers involved in confined space work.	All persons entering the confined space will have undertaken and are currently certified to work in confined spaces
Rescue Precautions: Noxious gases entering system while working	All personnel entering the access chamber will have harnesses on them. Evacuate if necessary, then establish cause and rectify. Air feed hood worn.
Atmospheric Monitoring: A change in atmospheric conditions	Constant monitoring of atmosphere with a gas monitor during entry into confined space
Traffic and Public Access:	Follow CI 808 – Safe working on or near roadways and footpaths. Ensure workplace is properly barricaded.
Hazardous or Explosive Gas Dangers:	Continual ventilation of pumpstation until a safe working environment is created.
Contents / Hazard: Syringes etc.	Initial inspection and clean
Personal Injury risks:	Protective clothing worn. Air tools are provided to help prevent any serious personal injury. Personnel are fully trained and experienced in pump station rehabilitation works.
Electric Isolation: The risk of electrical shock or electrocution at work site	Pre-works investigation, appropriate shielding or isolation. Air tools only, used on site

Revised Version 3

Page 24 of 64
CPS Sewerage Lining System

3 March 2005

Vol 4 - S E C T 4

HVAC

HYDROSTATIC / PNEUMATIC
PRESSURE TEST REPORT

hps

PROJECT: Redirection of Heroes Avenue Sewage Pump Station	PROJECT NO.: 3251Q
CLIENT: Brisbane Water	TEST DATE: 26-8-05
LOCATION/AREA: SP306 - Patrick Lane Pump Station	

TEST SECTION DATA		TEST SECTION ID
LOCATION	CORONATION DRIVE/ PATRICK LANE	From Pump Bases to
TEST MEDIUM	WATER	Wet Wall To
VOLUME	~ 2000 Litres	SPACES BETWEEN CHECK VALVES & GATE VALVES
HIGH POINT	As Per Sketch	
LOW POINT	As Per Sketch	
GAUGE POINT	As Per Sketch	
PRESSURE RATING OF EQUIPMENT IN TEST SECTION		
ITEM	RATING	MAJOR KPa
Pump 1		450 KPa
Pump 2		450 KPa

TEST EQUIPMENT DATA				
DESCRIPTION	MAKE	SERIAL NO.	CALIBRATED BY	DATE
PRESSURE GAUGE	WIKA		ACS	10-8-05
PRESSURE RECORDED	-			
AMB. TEMP. RECORDER	-			
AMB. THERMOMETER	Digi Temp			

PRESSURISING DATA		
TIME	PRESSURE KPa	AMB. TEMP. °C
16:17	860 KPa	21°C
16:49	860 KPa	21°C
17:19	860 KPa	20°C

STRENGTH TEST DATA		
TIME	PRESSURE KPa	AMB. TEMP. °C

LEAK TEST DATA		
TIME	PRESSURE KPa	AMB. TEMP. °C

Supervisor report: No visible leaks detected	
TESTED BY: (NAME & SIGNATURE) Rene Burgess	WITNESSED BY: (NAME & SIGNATURE) M. Heritage



**AUSTRALIAN
CALIBRATING
SERVICES (A'SIA) PTY. LTD.**

ABN 37 623 153 738

126 Oxford Street, Collingwood
P.O. Box 1174, Collingwood, Vic. 3066, Australia
Phone: +61 3 9417 5688, Fax: +61 3 9417 1578

File No: Q.AC/635-E-2

Issue Date: 12 Aug 2005

Page: 1 of 1

CALIBRATION REPORT AN INDUSTRIAL PRESSURE GAUGE

FOR: HVAC CONSTRUCTIONS
101 COBALT STREET
CAROLE PARK
QLD 4300

LOCATION: ACS Brisbane

TEST DATE: 10 August 2005

EQUIPMENT DETAILS:

Gauge Details

Maker: WIKA

Model: 1600 x 20 kPa

Serial Number: 69911

Plant Number: Nil

Capacity: 1600 kPa

Resolution: 20 kPa

TEST DETAILS:

Australian Standard AS1349:1986

"Bourdon Tube Pressure and Vacuum Gauges"

Section 4. Performance and Testing

- The pressure gauge was calibrated in a vertical position with increasing and decreasing pressure.
- The case of the pressure gauge was lightly tapped before each reading.
- The pressure medium was mineral oil.
- The Ambient Temperature during calibration was 20 °C
- Reference Equipment: Q.AC/1000-3F
- Uncertainty Confidence Level = 95%; Coverage Factor $k = 2$

COMMENTS:

Prior to taking final readings, the pressure gauge was repaired and adjusted.

PERFORMANCE TABLE:

Applied Pressure (kPa)	As Found (kPa)	Increasing (kPa)		Decreasing (kPa)		Uncertainty (kPa)
		Reading	Correction	Reading	Correction	
400		400	0.0	400	0.0	±3.3
800		800	0.0	800	0.0	±3.3
1200		1,195	+5.0	1,195	+5.0	±3.3
1600		1,595	+5.0	1,595	+5.0	±3.3

OVERLOAD TEST: The overload test was not performed.

CONCLUSION: The pressure gauge complied with the specification requirements

RECOMMENDED DATE OF NEXT CALIBRATION: 10 August 2006 (1 Year)

Signed

A. TIEDEMANN

Approved Signatory

AUSTRALIAN CALIBRATING SERVICES (A'SIA) PTY LIMITED



NATA Accredited Laboratory Number 1239

The tests, calibrations or measurements covered by this document have been performed in accordance with NATA requirements, which include the requirements of ISO/IEC 17025, and are traceable to national standards of measurement. This report shall not be reproduced except in full.

5-1035 - 17 10/1



COMMON LOGIC Pty Ltd
Specialist Electrical Contractors

Site Acceptance Tests

Subject: Switchboard Pre-Commissioning SAT for Patrick Lane Pump Station

Sheet: 5
Of: 13

Section
3

Page Revision No: 0 Date: 29/07/05

Manual Issue No: 0 Date: 29/07/05

3.0 INSULATION RESISTANCE/ HIGH POT TEST

3.1 Insulation Resistance Test

Insulation resistance of whole or part of an installation must be a minimum of 1 Meg/ohm (AS/NZS 3000:2000)

- ☐ Insulation test conducted on all internal circuits
- ☐ Insulation test conducted on all busbar
- ☐ Insulation test conducted on all motors
- ☐ Insulation test conducted on L&P circuits

- All Selector Switches, Isolators and CB's are in the off position
- Surge Diverter Disconnected
- Remove MEN LINK before insulation test
- All electronic equipment susceptible to high voltage damage to be isolated.

3.2 Low Voltage Switchboards Insulation Test

MEGGAR VOLTAGE 500 VOLTS

INSTRUMENT DETAILS SK-3005 SIEMENS

Switchboard and mains.

ACROSS	RESULT (M.OHM)	High Pot
Join Red, White & Blue Phases and Neutral, Test to Earth	200	
Red Phase to White, Blue & N	200	
White Phase to Red, Blue and N	200	
Blue Phase to Red, White & N	200	
N to Red, White & Blue	200	

Sewage Pumps

ACROSS	PUMP 1 RESULT (M.OHM)	PUMP 2 RESULT (M.OHM)
Red Phase to White, Blue & E	V1-600 V2-500	V1-800 V2-700
White Phase to Red, Blue and E	V1-600 V2-500	V1-700 V2-750
Blue Phase to Red, White & E	W1-620 W2-400	W1-700 W2-750

W. WONG *[Signature]*

21/07/2005

Test Carried out by... R. BURKE

Signed... *[Signature]* Date... 21/07/05

Test witnessed by... W. WONG

Signed... *[Signature]* Date... 21/07/05

Authorised By:

Prüfzertifikat

für Druckmessumformer

Test certificate for pressure transmitters

VEGA

Core Pro
Gravity Sensor



VEGA bestätigt, dass die zur Qualitätsprüfung des Erzeugnisses eingesetzten Messmittel gültig kalibriert und auf nationale Normale der Physikalischen Technischen Bundesanstalt (PTB) rückführbar sind.
VEGA confirms that all instruments used to assure the quality of our products are calibrated and traceable to national standards of PTB (Physikalischen Technischen Bundesanstalt)

VEGA Grieshaber KG, Am Hohenstein 113, 77761 Schiltach, Tel. 0 78 36/50-0, Fax. 0 78 36/50 201


Druckmessumformer / Pressure transmitter:	WELL72	Kundennummer	44741
Messbereich / Measuring range:	0 bis/to 1 bar rel. 0 bis/to 100 kPa rel.	Customer ID	
Seriennummer / Series no.:	14028316	Auftragsnummer	1156693
Ausgang / Output:	4 ... 20mA, HART	Order number	
Zulassungen / Approvals:	OHNE	Auftragsposition	2
		Order position	

Kennwerte / Characteristics: 0,000 bis/to 1,000 bar rel.
4,007 bis/to 19,999 mA

Kennliniencharakteristik / Output characteristics:

max. zul. Abweichung bezogen auf Messbereich: < 0,25 %
/ Dev. in linearity rel. to measuring range

Ref.-Druck / Ref. pressure [bar]:	0,000	0,250	0,500	0,750	1,000
Soll-Ausgang / Ideal output [mA]:	4,007	8,006	12,003	15,999	19,999
Ist-Ausgang / Real output [mA]:	4,007	8,005	11,999	15,999	19,999
Abweichung / Accuracy [%]:	0,00	0,00	-0,02	0,00	0,00



Temperatureinfluss

/ Temperature influence:

Temperaturfehler bei 0 bar rel.

/ Temperature accuracy at 0 bar rel.

bezogen auf den Messbereich / Related to the measuring range

Bezugstemperatur 20 °C / Ref. temperature 20 °C

Temperatur [°C] Temperature	0	20	60	100
Ist-Ausgang [mA] Real output	4,003	4,007	3,997	3,999
Abweichung [%] Accuracy	-0,03	0,00	-0,06	-0,05

Datum / Date: 09.08.2004

Unterschrift / Signature:

VEGA**Prüfzertifikat****für Druckmessumformer**

Test certificate for pressure transmitters

Patrick Lane
Wet Well

VEGA bestätigt, dass die zur Qualitätsprüfung des Erzeugnisses eingesetzten Messmittel gültig kalibriert und auf nationale Normale der Physikalischen Technischen Bundesanstalt (PTB) rückführbar sind.
VEGA confirms that all instruments used to assure the quality of our products are calibrated and traceable to national standards of PTB (Physikalischen Technischen Bundesanstalt)

VEGA Grieshaber KG, Am Hohenstein 113, 77761 Schiltach, Tel. 0 78 36/50-0, Fax. 0 78 36/50 201

Druckmessumformer / Pressure transmitter:	WELL72	Kundennummer / Customer ID	44741
Messbereich / Measuring range:	0 bis/to 1 bar rel. 0 bis/to 100 kPa rel.	Auftragsnummer / Order number	1156693
Seriennummer / Series no.:	14028319	Auftragsposition / Order position	2
Ausgang / Output:	4 ... 20mA, HART		
Zulassungen / Approvals:	OHNE		

Kennwerte / Characteristics: 0,000 bis/to 1,000 bar rel.
4,003 bis/to 19,998 mA

Kennliniencharakteristik / Output characteristics:

max. zul. Abweichung bezogen auf Messbereich: < 0,25 %
/ Dev. in linearity rel. to measuring range

Ref.-Druck / Ref. pressure [bar]:	0,000	0,250	0,500	0,750	1,000
Soll-Ausgang / Ideal output [mA]:	4,003	8,002	12,000	15,997	19,998
Ist-Ausgang / Real output [mA]:	4,003	7,999	11,996	15,993	19,998
Abweichung / Accuracy [%]:	0,00	-0,02	-0,02	-0,02	0,00

%

0.5

-0.5

0.000 0.250 0.500 0.750 1.000 P / bar

Temperatureinfluss

/ Temperature influence:

Temperaturfehler bei 0 bar rel.

/ Temperature accuracy at 0 bar rel.

bezogen auf den Messbereich / Related to the measuring range

Bezugstemperatur 20 °C / Ref. temperature 20 °C

Temperatur [°C]

Temperature

Ist-Ausgang [mA]

Real output

Abweichung [%]

Accuracy

0	20	60	100
3,993	4,003	3,996	3,993
-0,06	0,00	-0,05	-0,06

Datum / Date: 09.08.2004**Unterschrift / Signature:**

Prüfzertifikat

für Druckmessumformer

Test certificate for pressure transmitters

VEGA

VEGA bestätigt, dass die zur Qualitätsprüfung des Erzeugnisses eingesetzten Messmittel gültig kalibriert und auf nationale Normale der Physikalischen Technischen Bundesanstalt (PTB) rückführbar sind.
VEGA confirms that all instruments used to assure the quality of our products are calibrated and traceable to national standards of PTB (Physikalischen Technischen Bundesanstalt)

VEGA Grieshaber KG, Am Hohenstein 113, 77761 Schiltach, Tel. 0 78 36/50-0, Fax. 0 78 36/50 201

Druckmessumformer / Pressure transmitter:	BAR64	Kundennummer / Customer ID	44741
Messbereich / Measuring range:	-1 bis/to 5,0bar rel. -100 bis/to 500 kPa rel.	Auftragsnummer / Order number	1207381
Seriennummer / Series no.:	14315134	Auftragsposition / Order position	1
Ausgang / Output:	4 ... 20mA, HART		
Zulassungen / Approvals:	OHNE		

Kennwerte / Characteristics: -0,970 bis/to 5,000 bar rel.

0,51 bis/to 100,01 %

Kennliniencharakteristik / Output characteristics:

max. zul. Abweichung bezogen auf Messbereich: < 0.08 %
/ Dev. in linearity rel. to measuring range

Ref.-Druck / Ref. pressure [bar]:	-0,970	0,498	1,998	3,499	5,000
Soll-Ausgang / Ideal output [%]:	0,51	24,98	49,98	74,98	100,01
Ist-Ausgang / Real output [%]:	0,51	24,96	49,97	74,98	100,01
Abweichung / Accuracy [%]:	0,00	-0,02	-0,01	0,00	0,00

%

1

-1

-0.970 0.498 1.998 3.499 5.000 P / bar

Temperatureinfluss

/ Temperature influence:

Temperaturfehler bei 0 bar rel.

/ Temperature accuracy at 0 bar rel.

Bezogen auf den Messbereich / Related to the measuring range

Bezugstemperatur 20 °C / Ref. temperature 20 °C.

Temperatur [°C] Temperature	0	20	60	100
Ist-Ausgang [%] Real output	16,85	16,83	16,85	16,82
Abweichung [%] Accuracy	0,02	0,00	0,02	-0,01

Datum / Date: 10.06.2005

Unterschrift / Signature:



**AUSTRALIAN
CALIBRATING
SERVICES (A'SIA) PTY. LTD.**

A.B.N 33 823 153 726

126 Oxford Street, Collingwood
P.O. Box 1174, Collingwood, Vic. 3066, Australia
Phone: +61 3 9417 5688, Fax: +61 3 9417 1578

File No: Q.AC/635-E-2

Issue Date: 12 Aug 2005

Page: 1 of 1

CALIBRATION REPORT AN INDUSTRIAL PRESSURE GAUGE

FOR: HVAC CONSTRUCTIONS
101 COBALT STREET
CAROLE PARK
QLD 4300

LOCATION: ACS Brisbane

TEST DATE: 10 August 2005

EQUIPMENT DETAILS: Gauge Details

Maker:	WIKA	
Model:	1600 x 20 kPa	
Serial Number:	69911	Capacity: 1600 kPa
Plant Number:	Nil	Resolution: 20 kPa

TEST DETAILS: Australian Standard AS1349:1986
"Bourdon Tube Pressure and Vacuum Gauges"
Section 4. Performance and Testing

- The pressure gauge was calibrated in a vertical position with increasing and decreasing pressure. The case of the pressure gauge was lightly tapped before each reading.
- The pressure medium was mineral oil.
- The Ambient Temperature during calibration was 20 °C
- Reference Equipment: Q.AC/1000-3F
- Uncertainty Confidence Level = 95%; Coverage Factor k = 2

COMMENTS: Prior to taking final readings, the pressure gauge was repaired and adjusted.

PERFORMANCE TABLE:

Applied Pressure (kPa)	As Found (kPa)	Increasing (kPa)		Decreasing (kPa)		Uncertainty (kPa)
		Reading	Correction	Reading	Correction	
400		400	0.0	400	0.0	±3.3
800		800	0.0	800	0.0	±3.3
1200		1,195	+5.0	1,195	+5.0	±3.3
1600		1,595	+5.0	1,595	+5.0	±3.3

OVERLOAD TEST: The overload test was not performed.

CONCLUSION: The pressure gauge complied with the specification requirements

RECOMMENDED DATE OF NEXT CALIBRATION: 10 August 2006 (1 Year)

Signed

A. TIEDEMANN

Approved Signatory

AUSTRALIAN CALIBRATING SERVICES (A'SIA) PTY LIMITED



NATA Accredited Laboratory Number 1239

The tests, calibrations or measurements covered by this document have been performed in accordance with NATA requirements, which include the requirements of ISO/IEC 17025, and are traceable to national standards of measurement. This report shall not be reproduced except in full.



**AUSTRALIAN
CALIBRATING
SERVICES (A'SIA) PTY. LTD.**

ABN 33 623 153 736

126 Oxford Street, Collingwood
P.O. Box 1174, Collingwood, Vic. 3066, Australia
Phone: +61 3 9417 5688, Fax: +61 3 9417 1578

File No: Q.AC/635-E-2

Issue Date: 12 Aug 2005

Page: 1 of 1

CALIBRATION REPORT AN INDUSTRIAL PRESSURE GAUGE

FOR: HVAC CONSTRUCTIONS
101 COBALT STREET
CAROLE PARK
QLD 4300

LOCATION: ACS Brisbane

TEST DATE: 10 August 2005

EQUIPMENT DETAILS: Gauge Details

Maker:	WIKA		
Model:	1600 x 20 kPa		
Serial Number:	69911	Capacity:	1600 kPa
Plant Number:	Nil	Resolution:	20 kPa

TEST DETAILS: Australian Standard AS1349:1986
"Bourdon Tube Pressure and Vacuum Gauges"
Section 4. Performance and Testing

- The pressure gauge was calibrated in a vertical position with increasing and decreasing pressure. The case of the pressure gauge was lightly tapped before each reading.
- The pressure medium was mineral oil.
- The Ambient Temperature during calibration was 20 °C
- Reference Equipment: Q.AC/1000-3F
- Uncertainty Confidence Level = 95% Coverage Factor k = 2

COMMENTS: Prior to taking final readings, the pressure gauge was repaired and adjusted.


PERFORMANCE TABLE:

Applied Pressure (kPa)	As Found (kPa)	Increasing (kPa)		Decreasing (kPa)		Uncertainty (kPa)
		Reading	Correction	Reading	Correction	
400		400	0.0	400	0.0	±3.3
800		800	0.0	800	0.0	±3.3
1200		1,195	+5.0	1,195	+5.0	±3.3
1600		1,595	+5.0	1,595	+5.0	±3.3

OVERLOAD TEST: The overload test was not performed.

CONCLUSION: The pressure gauge complied with the specification requirements

RECOMMENDED DATE OF NEXT CALIBRATION: 10 August 2006 (1 Year)

Signed 
A. TIEDEMANN
Approved Signatory

AUSTRALIAN CALIBRATING SERVICES (A'SIA) PTY LIMITED



NATA Accredited Laboratory Number 1239

The tests, calibrations or measurements covered by this document have been performed in accordance with NATA requirements, which include the requirements of ISO/IEC 17025, and are traceable to national standards of measurement. This report shall not be reproduced except in full.