



☐ Electrical ☐ Mechanical ☐ Water Meters
5 Bunya Street Eagle Farm Q 4009
Ph. (07) 3403 1849
Fx. (07) 3403 1898

Brisbane Water Engineering Services

9 FEBRUARY 1996

OPERATING MANUAL FOR:

ILLAWEENA STREET TRUNK MAINS CATHODIC PROTECTION SYSTEM

CLIENT:

DEPARTMENT OF WATER SUPPLY AND SEWERAGE
WATER MAINTENANCE SECTION

MANUAL CONTENTS

(1.0)	Introduction
(2.0)	Corrosion and Cathodic Protection
(3.0)	Mains Details
(4.0)	Cathodic Protection
(4.1)	Type of System
(4.2)	Rectifier
(4.3)	Cathode
(4.4)	Anodes
(4.5)	Test Points
(4.6)	Associated Drawings
(4.7)	Associated Standards
(4.8)	Government Regulations
(5.0)	Performed Testing
(6.0)	Conclusion
(7.0)	Maintenance

DRAWINGS

486/6/25-AA1C0021E	Standard Rectifier Wiring Diagram
(No Number)	Monthly Maintenance Program

(1.0) INTRODUCTION

Steel when immersed or covered in water has a tendency to corrode (or rust) as the oxidized form is more stable than the metal.

Because of this, precaution must be taken to stop or minimize the corrosion reaction to an acceptable level consistent with the design life of the structure. This is normally achieved by the use of protective coatings which control the corrosion reaction by isolating the steel from its surrounding environment.

However, it is not practical to achieve a perfect coating and coating damage will always occur with time. Because of this, corrosion may occur at imperfections in the paint coating, causing further deterioration in the coating as well as loss of metal.

As a result of this, the coating defects must be rectified by periodic maintenance or an additional method of protection used to prevent this deterioration and corrosion occurring. This additional protection is achieved by the cathodic protection system.

(2.0) CORROSION AND CATHODIC PROTECTION

Corrosion is an electrochemical process in that it is accompanied by a flow of electrical current.

Corrosion occurs on the surface of metals at active areas known as anodes, which are electrically continuous with less active or passive areas known as cathodes. The electric current flows from the anode through the electrolyte to the cathode, with the circuit being completed by the electrical continuity between the cathode and anode. In practice anodes and cathodes are generally part of the same metallic surface and individual anodic areas may be small.

In applying cathodic protection and external current is applied to the surface so that the entire surface to be protected acts as a cathode. This involves the use of an auxiliary anode and when the current flow from this anode is sufficient, no part of the structure acts as an anode.

An external source of direct current such as a transformer rectifier is used in conjunction with an anode consisting of material with a very slow corrosion rate.

While it is the flow of current which achieves the cathodic protection of the surface it is impractical to measure these currents over individual anodic areas to determine when cathodic protection has been achieved. However, with the flow of cathodic protection current, the structure becomes more negative with respect to the surrounding electrolyte. Because of this, it is possible to state values of metal/electrolyte potential at which corrosion does not occur. This metal/electrolyte potential is generally measured against a standard reference electrode which allows a reproducible potential at which corrosion does not occur to be quoted.

Size: New Dia 755 mild steel cement lined. Existing 600 and 470 Dia mild steel cement lined.

Coating: Medium Density Fusion Bonded Polyethylene

Length: Appox 4 Km (New 755 Dia-1.72 Km)

Location: Cnr Tamarisk Way and Illaweenah Street, Drewvale to Wembley Road Reservoir, Bligh Place, Drewvale.

Construction

Drawings:

486/6/6-SA1C0039E Illaweenah Street C.P. System
to
486/6/6-SA1C0041E

2/13.323 Standard Flange Adapters to BCC Standard Drillings

486/4/6-W10040LO Logan Water Supply Scheme,
to Kuraby to Illaweenah Street Reservoir,
486/4/6-W10049LO Bulk Supply Main.

(4.1) Type of Cathodic Protection: Impressed Current.

(4.2) Rectifier: Special 32 Volt, 10 amp direct current output enclosed in a stainless steel switchboard. Rectifier has a 240V supply from within the main switchboard located opposite No 403 ,Illaweena St, Drewvale.

(4.3) Cathode: The cathode point is located on the 755 Dia and 600 Dia mains, in their respective valve pits, behind the existing flowmeter switchboard. The cathode point is where the cabling from the rectifier is attached to the structure under cathodic protection.

(4.4) Anodes: Two 1500 x 75mm silicone iron anodes were installed approximately 200 metres from the trunk mains in a vertical bed. The anodes were firstly packaged with cokebreeze thereby improving anode – ground resistance. The anodes are identified by a marker post and label.

(4.5) Test Points: Test points are installed on cathodically protected structures to enable testing to ensure full protection of the mains. On these mains five test points have been installed on the new 755 Dia, five test points on the existing 600 Dia and six on the existing 470 Dia mains. In total, the system has 10 test points which can be identified from the layout drawing.

(4.6) Associated Drawings:

Cathodic Protection Details	- 2/14.213
Cathodic Protection Test Point Details	- 2/14.199
Standard Rectifier Wiring Diagram	- 486/6/25-AA1C0021E
Standard Vertical Groundbed Details	- 486/6/25-AA1C0024E

(4.7) Associated Standards:

AS 3000 1986 Australia Wiring Rules

AS 2832.1 1985 Pipes, Cables, Ducts, Guide to Cathodic Protection, Part One.

(4.8) Government Regulations:

Queensland Electricity Acts and Regulations.

- (1) Natural Potential Survey.
- (2) Testing of Insulated Flanges, Joints.
- (3) Soil Resistance Testing.
- (4) Current Drain Survey.
- (5) Pipe Coating Anomaly Survey.
- (6) Rectifier Loop Resistance.
- (7) Foreign Structure Interference Survey and Mitigation.
- (8) Final Potential Survey and Commissioning.

(6.0) **CONCLUSION**

Full Cathodic protection has been achieved on this section of trunk mains. The cathodic protection system is registered with the Queensland Electricity Commission and has approval to operate.

(7.0) **MAINTENANCE**

The cathodic protection system is maintained on a monthly basis after commissioning. These checks involve testing rectifier operation and recording of pipe to soil potentials.

CPS Monthly Maintenance Details.

Required:

- 1/ Notify plant operator and/or sign entry logs where necessary.
- 2/ Have appropriate keying.

Labour:

One tradesperson, one vehicle. 20 minutes per site.

Procedure:

- 1/ Identify installation.
- 2/ Check system for operation.
- 3/ Record voltmeter.
- 4/ Record ammeter.
- 5/ Comments.
- 6/ Log entry.

CPS 6 Monthly Maintenance Details.

Required:

- 1/ Notify plant operator and/or sign entry logs where necessary.
- 2/ Have appropriate keying.
- 3/ Set of tools. (Electricians)
- 4/ Multimeter.
- 5/ DC clampmeter.
- 6/ Copper sulphate reference cell and leads.
- 7/ Cleaning equipment.
- 8/ Gatic cover lifters.

Labour:

One tradesperson electrical, one laborer, one vehicle.
Two hours per site.

Procedure:

- 1/ Identify system.
- 2/ Check system for operation.
- 3/ Record voltmeter.
- 4/ Record ammeter.
- 5/ Record "on" potentials for all test points.
- 6/ Record "instant off" potentials for all test points.
- 7/ Record "off" potentials for all test points.
- 8/ Perform loop resistance and record.
- 9/ Check and record anode string currents.
- 10/ Comments.
- 11/ Log entry.

CPS 60 Monthly Maintenance Details.

Required:

- 1/ Notify plant operator and/or sign entry logs where necessary.
- 2/ Have appropriate keying.
- 3/ Set of tools. (Electricians)
- 4/ Multimeter.
- 5/ DC clampmeter.
- 6/ Copper sulphate reference cell and leads.
- 7/ Cleaning equipment.
- 8/ Gatic cover lifters.
- 9/ Rectifier load bank.
- 10/ PCS2000 Detection Equipment.

Labour:

One tradesperson electrical, one laborer, one vehicle.
Eight hours per site.

Procedure:

- 1/ Identify system.
- 2/ Check system for operation.
- 3/ Record voltmeter.
- 4/ Record ammeter.
- 5/ Record "on" potentials for all test points.
- 6/ Record "instant off" potentials for all test points.
- 7/ Record "off" potentials for all test points.
- 8/ Perform loop resistance and record.
- 9/ Check and record anode string currents.
- 10/ Load test rectifier for 10 minutes.
- 11/ Check all switchboard and testpoint terminals for tightness.
- 12/ Check all switchboard and testpoints are labelled and I.D. tags attached.
- 13/ Check plans are correctly drawn and modify if necessary.
- 14/ Remove and inspect anodes.
- 15/ Recheck all interference (CPS) bleeds.
- 16/ Pipecamp structure if applicable.
- 17/ Apply for "continue to operate" permit if applicable.

Brisbane Water Engineering Services

Electrical Engineering Unit


Date: 12th February 1996

System: Illaweena Street Trunk Mains

Cathodic Protection System reference potential and earth resistivity graph.(755 Dia only)

Test Point number	Distances to T.P. (metres)	Potentials to CuSO4			Resistivities at 2 metres (ohm.metres)
		Natural (mV)	Off (mV)	On (mV)	
1	0	-729	-885	-1114	5.53
2	579	-780	-756	-1320	55.29
3	947	-715	-740	-1178	41.47
4	1027	-1085	-811	-1189	41.97
5	1720	-306	-523	-645	81.68

Graph of potentials and resistivity vs pipelength



Brisbane Water Engineering Services

Ph. 34031838 Fx. 34031839

Electrical Engineering Unit5 Bunya Street
Eagle Farm Q 4009**Cathodic Protection System Loop Resistance**

Date 12th February 1996

Cathodic Protection System:

Illaweena Street Trunk Mains.

System Operating Volts:

2


System Operating amps

1

Test Voltage:		Test Current:	
(volts)		(amps)	
2		0.9	
4		1.5	
6		2.1	
8		2.9	
10		3.2	

Loop Resistance (ohms)

3.478261

Graph of System voltage vs current.

TESTED BY

M.McCORMICK

03/22/96

LOOPILLA.WK4

INDUCTION TESTS**PROJECT:-** Illaweena Street**DATE:-** 22 February 1996**LENGTH OF MAIN**

Appox 1Km

DIAMETER OF MAIN

755

LOCATION OF MAIN

Illaweena Street, Drewvale

D.C. OUTPUT

Nominated Voltage	Actual Voltage	Forward Current	Actual Voltage	Reverse Current
6	6.3	0.031	6	0.03
9	9.49	0.027	9.52	0.0287
12	12.62	0.025	12.67	0.0249

A.C. OUTPUT

Nominated Voltage	Actual Voltage	Forward Current	Actual Voltage	Reverse Current
6	6.05	2.7	6.5	0.6
9	8.5	3.65	9.29	0.96
12	12.02	4.8	13.46	1.4

PERFORMED BY :-

M. McCormick

Brisbane Water Engineering Services

CP Form No. 28

Electrical Engineering Unit

Cathodic Protection Bleed Point Details FormProject ILLAWEEENA StDate 24-12-96Bleed Location QEC TowerCPB No. 54FOREIGN STRUCTURE OWNER: QECF.S. LOCATION: ILLAWEEENA ST QEC TOWER LEG

F.S. IDENTIFICATION: _____

REFERENCE POTENTIALS TO F.S. PRIOR TO BLEED CONNECTION:REFERENCE TYPE: CUSO₄POTENTIAL OFF: -584 mV ON: 558 mV SW: +26BLEED TYPE: Sacrificial anode 2.9 Ω to groundBLEED MATERIAL: ZN Rod 1500


BLEED WEIGHT: _____

BLEED O/C POTENTIAL: 479 mVBLEED CURRENT OFF: 90 mV ON: 90 mV**REFERENCE POTENTIALS AFTER CONNECTION TO FOREIGN STRUCTURE:**

Bond Off (Rectifier Off)			Bleed On			Resultant Swing
Bleed Off	Bleed On	Swing	Bond Off	Bond On	Swing	
-583	-745	-162	-745	-729	+16	-146

FOREIGN STRUCTURE OWNER AGREEABLE WITH MITIGATION? (Y/N) YesIDENTIFICATION TAG INSTALLED? (Y/N) Yes**COMMENTS:**Unit 3V 2AmpINSTALLED / TESTED BY P. SMYTH

Revision 09/28/95



TYPICAL TOWER CONNECTION

NOTES

1. ANODE CABLE TO BE BURIED AT A DEPTH OF 300mm TO A DISTANCE OF 1500mm FROM TOWER LEG AND 600mm THEREAFTER.
2. ANODE CABLE TO BE PROTECTED BY A FLEXIBLE CONDUIT FIRMLY ATTACHED TO TOWER STUB AND CONCRETE FOUNDATION RUNNING ON INSIDE OF TOWER LEG.
3. TO ALLOW FOR DIFFERENTIAL TOWER SOIL MOVEMENT ALL RISES SHALL CONTAIN APPROXIMATELY 300mm SLACK.
4. CABLE TO ANODE CONNECTION TO BE MADE BY BOLTED LUG OR CATHWELD AND ENCAPSULATED BY A SUITABLE TWO PACK EPOXY RESIN AND FITTED WITH A MASTIC LINED POLYETHYLENE HEAT SHRINK CAP.
5. SACRIFICIAL ANODE TO BE INSTALLED AT A MINIMUM DEPTH OF 500mm IN CARBONACEOUS BACKFILL WITH THE FOLLOWING NUMERICAL COMPOSITION:

CARBON	72.5%
SULPHUR	3.4%
ASH	2.0%
SILICON	0.1%

5	FLEXIBLE CONDUIT	AS REQD	METAL PREFERRED
4	GROUNDING CLAMP	AS REQD	ALUM TYPE STG-15 OR EQUIVALENT
3	HEX BOLT & NUT M12 x LG TO SUIT	AS REQD	WITH FLAT AND SPRING WASHER SS
2	SACRIFICIAL ANODE	AS REQD	ZINC ROD 1900x55x35 OR SIMILAR - TO AS 2239
1	ANODE CABLE	AS REQD	50mm ² PVC INSULATED COPPER

PT NO	DESCRIPTION	NO OFF	DRG NO	REMARKS	STORES CAT NO
MATERIAL LIST					
CHECKED		SUBMITTED		Powerlink	
DRAWN	B.C. [Signature]	RECOMM	[Signature]	LOCATION	CONT/ORDER
ORIGIN	L&C	APPROVED	[Signature]	TLDS	
SACRIFICIAL ANODE CONNECTION TO LATTICE STEEL TOWERS				PROJECT	
				A1	
				NEXT SHEET	
CIRCULATION				A2-H-114457-01	
				B	

5	6	7	8
---	---	---	---

Electrical Engineering Unit

Cathodic Protection Interference Survey Results Form

Project ILLAWEEENA ST MAIN
755 MM.Unit Reading 50V at 2.5ADate 26-3-96

	Reading	Test Point I. D.	Location	Swing
On	-396 mV		QEC TOWER	
Off	-396 mV	LEG 802	EASEMENT	NIL
On	-431 mV		QEC TOWER	
Off	-427 mV	LEG 804	EASEMENT	- 4 mV
On	-287 mV		QEC TOWER	
Off	-290 mV	LEG 804	BLIGH PLACE	+ 3 mV
On	-285 mV		QEC TOWER	
Off	-288 mV	LEG 802	BLIGH PLACE	+ 3 mV
On	-446 mV		QEC TOWER	
Off	-470 mV	LEG 802	ILLAWEEENA ST CORNER	+24 mV
On	-467 mV		QEC TOWER	
Off	-493 mV	LEG 804	ILLAWEEENA ST CORNER	+24 mV
On	-400 mV		QEC TOWER	
Off	-395 mV	LEG 802	ILLAWEEENA ST. OPP. RECTIFIER	-5 mV
On	-361 mV		QEC TOWER	
Off	-350 mV	LEG 804	ILLAWEEENA ST OPP RECTIFIER	-11 mV
On	-1145 mV			
Off	-1145 mV	GAS	QEC. EASEMENT	NIL
On	-435 mV	MEN	SEQEB POLE 2254	
Off	-366 mV		ILLAWEEENA ST	-69 mV
On	-292 mV		SEQEB POLE 2247	
Off	-283 mV	MEN	TRANSF LOGAN M'WAY	- 9 mV
On	-557 mV		SEQEB POLE 410698	
Off	-553 mV	MEN	DANIELSEN ST	- 4 mV
On	-337 mV		SEQEB POLE 27231	
Off	-337 mV	MEN	ILLAWEEENA ST	NIL
On	-358 mV		SEQEB POLE 27235	
Off	-358 mV	MEN	ILLAWEEENA ST	NIL
On	-361 mV		SEQEB POLE 27236	
Off	-361 mV	MEN	ILLAWEEENA ST	NIL

TESTED BY M. M'CORMICK.

Electrical Engineering Unit

Cathodic Protection Interference Survey Results Form

Project ILLAWEEENA ST.Unit Reading 5.0V at 2.5ADate 26-3-96

	Reading	Test Point I. D.	Location	Swing
On	-331mV	MEN	SEQEB POLE 27240	NIL
Off	-331mV		ILLAWEEENA ST	
On	-337mV	MEN	SEQEB POLE 27242	NIL
Off	-337mV		GOWAN RD.	
On	-472mV	MEN	SEQEB POLE 31392	NIL
Off	-472mV		ILLAWEEENA ST	
On	-852mV	MEN	SEQEB POLE 33254	NIL
Off	-852mV		ILLAWEEENA ST.	
On				
Off				
On				
Off				
On				
Off				
On				
Off				
On				
Off				
On				
Off				
On				
Off				
On				
Off				
On				
Off				
On				
Off				

TESTED BY M. MCCORMICK

Electrical Engineering Unit

Standard Cathodic Protection Test Point Data Gathering Form

Project ILLAWARRA STREET

Date 12/12/25

T P Location REC EASEMENT

T P No. 3

Mains Size 755 & 60

T P Type R

POTENTIAL TESTING

CATHODE TO CATHODE RETURN (RESISTANCE)

755

600

0.1Ω

0.1Ω

ZINC REFERENCE TO PIPE

+437mV

+451mV

CuSo4 REFERENCE TO PIPE

-115mV

-185mV

ZINC TO CuSo4

-1157mV

-1177mV

EARTH TESTING

TEST NO. 1

PIN SPACING

2M

RESISTIVITY 41.47 ΩM

MEGGER READING

3.3

TEST NO 2

PIN SPACING

5M

RESISTIVITY 40.84 ΩM

MEGGER READING

1.3


TEST NO 3

PIN SPACING

RESISTIVITY

MEGGER READING

COMMENTS / LOCATION DRAWING




INSTALLED BY Murray McCormick

Brisbane Water Engineering Services

CP Form No. 16

Electrical Engineering Unit

Site Plan Drawing Sheet

Project ILLAWARRA STREET.....Date 1-02-95.....


Revision 09/28/95

Brisbane Water Engineering Services

CP Form No. 16

Electrical Engineering Unit

Site Plan Drawing Sheet

Project LOGAN MOTORWAY CROSSING. (ILLAWARRA ST.)Date 18.12.95COMPILED BY L. Groves

Revision 09/28/95


Cathodic Protection System - Illaweena Street - Trunk Water Main - OM Manual

Brisbane City Council
Dept of Water Supply and Sewerage
Eagle Farm Pump Station
Electrical Workshop

Date: 25-08-95

Site Plan for:

ILLAWEENA STREET



D:\123r3cp\siteplan

STUDY
on
ELECTRICAL HAZARDS
PERTAINING TO THE 755 dia.
M/S TRUNK WATER MAIN
FROM KURABY TO ILLAWEENA STREET
DUE TO THE PROXIMITY OF
A Q.E.C. 275KV TRANSMISSION SYSTEM
for
THE BRISBANE CITY COUNCIL
DEPARTMENT OF WATER SUPPLY
AND SEWERAGE

by B.M. BYRNE
2. 1. 1995

B.M. Byrne, B.E.E., C.Eng., R.P.E.Q., M.I.E.E.
Registered Professional Electrical Engineer
Consulting in
 . Plant Protection
 . Electrical Overvoltage
 Protection
 . Personnel/Electrical Safety
 . Corrosion Control

118 Central Avenue
Indooroopilly, Qld. 4068

Telephone: (07) 870 1155

The Manager
Capital Projects Section
Mechanical & Electrical Services Branch
Brisbane City Council
GPO Box 1434
BRISBANE QLD 4001

Attention: Mr. J. Say

Dear Sir,

HIGH VOLTAGE, LOW FREQUENCY INDUCTION (L.F.I.) and EARTH POTENTIAL RISE (E.P.R.) STUDY, KURABY TO ILLAWEENA STREET RESERVOIR BULK SUPPLY MAIN

Foreword:

This study is made on the assumption that the subject Bulk Supply Main will be installed in the manner and in the position described in Brisbane City Council (B.C.C.) drawings 486/4/6 - W100 LOLO and 486/4/6 - W100 4IP to 486/4/6 - W100 48GD.

Scope:

The study is prepared in response to B.C.C. letter of 2 November 1994, ref. J.S. Illweena, requiring "identification of any hazards due to induction and EPR due to QEC operation current, Q.E.C. fault condition or lightning strike occurrence". The existing trunk mains are taken into consideration accordingly, and some aspects affecting these are covered in "Discussion" at the end of the report. The overall length of the pipeline, scaled off the above drawings is 1380m.

The matter of precautions during construction are also addressed, and the essentials of this matter have been advised to Mr. Say, in advance, by telephone. Comments are offered regarding the interaction of Cathodic Protection (CP) on the older trunk water main, and the protection earthing on both the proposed and existing mains, and its effect on C.P. on the new main.

The findings include the specifications required for protection earthing. This is listed in the "Discussion" at the end of the document.

Appendix 1 lists several references, and formulae required for calculations in this study.

Appendix 2 lists specific data and measurements necessary for the study, and the origin thereof.

The Findings:

- (a) The level of load current induction is of no consequence whatever.
- (b) The fault current induction level, calculated at the worst case condition is severe enough - nearly 500 volts - to require mitigation action. This action is detailed in the L.F.I. study and referred to under "Discussion". The effect on Cathodic Protection is also discussed.
- (c) Earth Potential Rise from L.F.I. is not of major concern, for valves, test points and the like more than 20m from any transmission tower. A figure of 50m tower isolation is preferred for lightning protection.
- (d) Some adjustment to protective arrangements on existing trunk mains would be to advantage. This is referred to in "Discussion".
- (e) Earthing arrangements during construction will be necessary. This is detailed in the Study.
- (f) Some aspects of lightning effects are discussed.

The L.F.I. Study:

- (a) **General:** The exposure of the 755mm main to L.F.I. exists over the whole length of the construction, even though it diverts from the power transmission corridor some 160m from the Wembley Road Reservoir.

The power transmission line is actually two separate three phase feeders - one from the Belmont Substation, and one from Mt. England Substation. Both feeders are tied in to the Q.E.C. mesh on either end, with the result that fault current will flow from either end of either feeder in the event of a faulted tower.

- (b) **Load Current Induction:** The Q.E.C. has adopted a careful and well engineered approach with the design of both its E.H.V. mesh and with the use of dual feeders. Each route with dual feeders has the system so arranged that the rated load current on the pair of feeders on either side of a sequence of towers is approximately equal. In addition, the arrangement of conductors/phases are in electromagnetic inverse in each pair of feeders. Thus the feeder on one side of the tower string will be (e.g.) A.B.C. phases, from top to bottom, all in a vertical plane. On the other side of the tower string, the phases would thus be C, B, A from top to bottom. Long feeders are divided into three lengths, and the phases are transposed at these third points (at quite some cost). One such transposition can be viewed at about the mid point of the Illaweena Street/Wembley Road Reservoir exposure. A similar phase balance is preserved between the two

feeders after each transposition.

The result of the foregoing exercise is that an incredibly small electromagnetic field is achieved at ground level. This has three effects: (i) a superior power transmission efficiency result; (ii) coupling into "foreign" conductors (such as the Water Main) is minimised; and (iii) the environmental effect is virtually nil.

In this exposure, QEC quotes the residual magnetic field at ground level as 10 milligauss, with both feeders operating at rated current. Conversion of this to induced voltage is merely an application of Faraday's Law:

$$E = K \frac{d\phi}{dt}$$

As the quoted magnetic flux is in CGS units, the formula becomes (App.1 Ref.11):

$$E \text{ (voltage, per km)} = B \text{ (flux)} \times 10^5 \text{ (cms/km)} \times V \text{ (} 2 \pi f \text{ flux cutting rate)} \times 10^{-8}$$

$$\begin{aligned} \text{i.e. } E &= .01 \times 10^5 \times 314 \times 10^{-8} \text{ Volts/km} \\ &= 3.14 \text{ millivolts per km.} \end{aligned}$$

This is trifling in the extreme. It would be difficult to test for technically, let alone to be concerned by the possibility of its being detected by the most sensitive staff fingers. This is fortunate as there is no Australian Standard for this limit. Even internationally, limits vary. In various countries, and even between States in North America, limits are variously 15 V.RMS, 30 V.RMS, and unspecified. None of these aligns with the provisions of I.E.C. publication 479/1 (Effect of Electric Current on the human body) either.

- (c) **Fault Current Induction:** This is the most serious part of the study. The fault clearance time of both the 275kv feeders is stated by QEC to be 100m.sec. The feeders are Category A, that is, the fault incidence is "a few" earth faults per 100km per annum. The significance of these aspects will be considered in "Discussion" below.

The highest zero sequences (phase to earth) fault current on any of the four feeder directions is 3.9 kA. (From Q.E.C. App.2.) on feeder 804. The faulted tower would necessarily be beyond the exposure to have maximum effect. Q.E.C. advises that the customary calculation figure of 10 ohms earth resistance has been incorporated in this fault current calculation. An allowance for arc path resistance (usually about 4 ohms) has not been made.

By combining this fault current figure with the deep resistivity figures provided by B.C.C.'s Mr. Say, and the juxtaposition of the two services (power and water) shown on the B.C.C. plan, it is possible to derive an induced voltage, using the formulae and process listed in Appendix 1. The "deep" resistivity figures will only be an approximation, but on experiences in the Brisbane area, will be a sufficiently appropriate indication of the effect of geological conditions pertinent to the current return path.

The exposure has been subdivided into four lengths, shown as (a), (b), (c), (d) in the table below. (a), (b) and (d) are parallel sections, but (c) is a 45° divergence between the services. A geometric mean distance "D" has been derived for the equivalent spacing for this angled section. It is listed in Table 1, Col.4.

Distances shown are scaled from the B.C.C. plans. A shielding factor of 0.9 has been quoted by Q.E.C. for the overhead earth wires (O.H.E.W.S.). A further shielding factor of 0.5 has been included for the presence of the ferrous existing water main(s). Some comments are made under "Discussion" on this matter.

The coupling factor, "C", in the sample equation below, is derived from the material and references in App.1, ref.7.

Section	Length, Metres	Map Location	Spacing D metres	Resistivity ohm & metres 20m pin spacing	OHEW shielding	Environmental shielding	C Derived
(a)	420	Illaweenaa St.	39	27	.9	.5	.16
(b)	670	Q.E.C. Easement	32	68	.9	.5	.21
(c)	160	Q.E.C.easement to foot of Reservoir Hill	72	353	.9	.5	.2
(d)	130	Up hill to Reservoir	200	643	.9	.5	.17

Table 1. Induction Parameters for the several Exposure Sections, with the derived coupling factors.

A sample calculation, for (a) above:

$$\begin{aligned}
 \text{(a) } E \text{ (voltage)} &= \text{C.I.L.K. (Ref.7, App.1)} \\
 &= \text{Coupling Factor} \times \text{Amps} \times \text{Kms} \times \text{Shielding factors} \\
 &= .16 \times 3900 \times .42 \times .5 \times .9 \text{ volts} \\
 &= 117 \text{ volts}
 \end{aligned}$$

$$\begin{aligned}
 \text{Similarly (b)} &= 247 \text{ volts} \\
 \text{(c)} &= 70 \text{ volts} \\
 \text{(d)} &= \underline{60 \text{ volts}}
 \end{aligned}$$

$$\text{Total} = \underline{494 \text{ volts}}$$

It will be observed that the coupling factors are fairly uniform, due to the resistivity fortuitously increasing as the separation increases at the reservoir end.

This uniformity means that it is a simple matter to prescribe safety working length for construction staff, as induced voltage will be in almost linear relation to the pipe length. The induction per 100 metres is 38.6 volts. See "Discussion".

Reduction of the extent of exposed voltage from the total of 494 volts can be achieved

by causing the electrical condition on the pipeline to change from static to dynamic conditions. This requires the installation of and connection of a low resistance earth electrode at each end of the pipe. When this is done, a substantial current will flow, under the influence of the induced voltage, being limited only by the resistance of the earth electrodes (in series) and the reactance of the pipeline. The resistance of the pipe steel is negligible, (See App.1 Ref.10) at about .0006 ohms/km.

The reactance of a ferrous pipe, with an existing ferrous pipe adjacent is uncertain. It will be greater than the figure for a single pipe, and would be worth measuring (see "Discussion") for future calculations.

An inductance of 10 mH/km, based on earlier measurement experience, will be used to derive approximate circuit impedance.

The reactance in ohms, of an inductive component is given by the formula $R_L = 2 \pi f.L$

where L has been assigned the figure of .01 Henry

$$\begin{aligned} &= 2 \times 3.14 \times 50 \times .01 \text{ ohms/km} \\ &= 3.14 \text{ ohm/km} \end{aligned}$$

Due to the very high earth resistivity of the Reservoir hill, it will be impractical to install a low resistance earth electrode there. The nearest location where it may be achieved is at the foot of the hill where the Trunk Main and Power transmission lines separate. This is about 1100m from the Illaweena Street commencement of the project. The reactance of the pipe over this length would be 3.45 ohms. The induced voltage would be about 434 Volts (60 V on hill section excluded).

Considering the total circuit impedance for three pairs of earth electrodes (of R ohms):

- (i) 1 ohm each end
- (ii) 2 ohms each end
- (iii) 3 ohms each end

$$\text{The impedance } Z = \sqrt{R^2 + R_L^2} \text{ ohms}$$

$$\begin{aligned} \text{i.e. } Z_{(i)} &= \sqrt{2^2 + 3.45^2} \\ &= \sqrt{4 \times 11.9} \\ &= 4 \text{ ohms} \end{aligned}$$

$$\text{Similarly } Z_{(ii)} = 5.3 \text{ ohms}$$

$$Z_{(iii)} = 5.9 \text{ ohms}$$

The current in each case would be

$$I = \frac{E}{Z}$$

$$I_{(i)} = \frac{434}{4 \text{ Amps}}$$

$$= 108.5 \text{ A}$$

$$\text{Similarly } I_{(ii)} = 81.9 \text{ A}$$

$$I_{(iii)} = 73.6 \text{ A}$$

The Voltage appearing on the pipeline E_o at each end would be

$$E_o = I.R.$$

$$(i) E_o = 108.5 \times 1 = 108.5 \text{ volts} \quad (1)$$

$$(ii) E_o = 81.9 \times 2 = 163.8 \text{ volts} \quad (2)$$

$$(iii) E_o = 73.6 \times 3 = 220.8 \text{ volts} \quad (3)$$

In addition, at the reservoirs, because the proposed earth electrode is at the foot of the hill, the 60 volts induction from the electrode site must be added to the above figures, for the pipe at the reservoir end.

These voltages are for the period of the power line fault duration (see "Discussion" for significance).

A further point is that these figures are "worst case" - and not the likely arc path fault condition which would reduce the fault current to about 3.55kA. This would in turn reduce all voltages calculated above by about 10%. Some considerations of this matter are made under "Discussion".

Earth Potential Rise (EPR):

This condition occurs when a current discharge from the Transmission Line Earthing System occurs. The common - even nearly exclusive - mechanism is pursuant to a lightning flash attachment to the O.H.E.W. of the line. The lightning current, in the range from 10kA to 200kA, but commonly about 30kA, then proceeds to ground via the nearest tower, or pair of towers if the flash attaches at a mid span point. The surge does not effectively proceed further than to the nearest tower as the rise time of the wave is very short, in the order of a microsecond. Longer paths to other towers present too high an impedance for any significant current dispersion.

The initial effect is to cause a very high voltage to appear at the top of the discharge tower, which voltage may or may not be sufficient to flash over the line insulators, normally to an uppermost phase wire.

This has two possible effects:

- (i) The lightning current itself discharging to ground causes an enormous momentary E.P.R. around the tower, in accordance with the formula (App. 1 Ref.9) $V = \frac{I \rho}{2 \pi d}$

V is Voltage in Volts

I is Current in Amps (Lightning)

ρ is Soil Resistivity in ohm metres

d is the distance from the injection point, in metres.

The tower is considered to be a point, provided d is more than 5 times the diagonal of the tower footings. For lesser distances a more detailed analysis is necessary for accuracy. Variation in ρ in the earth also leads to some inaccuracies.

- (ii) The follow through current from the transmission line conductor along the lightning generated arc path occurs. Because the 50Hz supply is far less subject to minor reactance figures in the O.H.E.W., this current is distributed over some dozen or more towers on each side of the fault, as well as along the O.H.E.W. back to the substation. The maximum tower current, nearest the originating lightning flash would be in the range 5% - 10% of the calculated total fault arc path current. The figure reduces as the distance from the substation reduces.

For this exposure, calculations have been made on a tower current of 300 amps (8.5% of total).

The figures for ρ for calculating EPR are those derived from the 4m pin spacings. These figures give the averaged resistivity at 3m depth. This equates approximately to both the tower footing base conditions, as well as to the pipeline current level conditions.

The main variation in EPR lightning hazard in a power line corridor over the open field situation is that the lightning flashes in the corridor are virtually all intercepted by the O.H.E.W's. This in turn leads to all flash current appearing at the nearest tower. Thus the incidence of current discharges to earth per unit area adjacent to a tower is about fifteen times that of the open country figure.

Step potential may now be calculated at the worst (highest surface earth resistivity) tower location which is near the C.P. rectifier on the existing trunk main.

(a) Lightning, at a fairly nominal 30kA flash current:-

From App.1 ref 9,

$$V = \frac{I \rho}{2 \pi d}$$

$$\begin{aligned} \text{at } d = 20\text{m, } V &= \frac{30,000 \times 170}{6.28 \times 20} \text{ volts} \\ &= 40605 \text{ V (for several microseconds)} \end{aligned}$$

$$\text{at } d = 21\text{m } V = 38672 \text{ V (for several microseconds)}$$

The step potential is thus 1933 volts per metre. This figure is unsafe, and clearly indicates that 20m proximity from a tower during a local thunderstorm is to be avoided.

It might be noted that well insulated work boots would withstand this figure. The security of the pipeline, at 20m approx. spacing would appear to be adequate, as the coating would have a withstand of upwards of 50kV. Also, the earth resistivity falls away to a much lower value with depth, at the C.P. rectifier site. The probability is that the majority of the discharge would proceed downwards, i.e. away from the pipe, thus reducing the electrical stress on the coating.

(b) The follow through transmission line current was noted above as 300 amps per tower, for a duration of about 100ms - protection operate time. At the worst surface resistivity figure of 170 ohm metres near the C.P. rectifier, this results in a 20m E.P.R. of:

$$\begin{aligned} V &= \frac{I \rho}{2 \pi d} \\ &= \frac{300 \times 170 \text{ Volts}}{6.28 \times 20} \\ &= 406 \text{ Volts} \end{aligned}$$

This is of no consequence to the pipeline coating. However operatives engaged in C.P. testing should be aware of the circumstances, particularly if engaged in running out test cables to earth stakes in a radial direction from the nearest transmission tower.

Step potential at 20m would be only about 20 v/metre.

Construction staff might also exercise caution in the layout of long pipe lengths in directions radial to any nearby tower. The matter is developed further in "Discussion.

Discussion:**(A) LFI - Fault Current**

It is always a point of concern whether to calculate worst possible induction figures - that is, a fault current in the worst position relative to the exposure, combined with a conductor to tower fault. This almost never happens - except perhaps in a cyclone when a complete metal roof structure is hurled through a transmission line. As the prospect of anyone working on a trunk main in a cyclone is virtually nil, the figures in the L.F.I. fault study above are about 10% higher than the "worst-likely" situation. Further, the incidence of phase to ground faults on Category A (or Category 1) high security transmission lines is of the order of "a few" per 100km per annum - scarcely a very high risk situation. This of course refers to the whole length of transmission feeders - the exposure concerned will suffer the induction from a fault 10, or 50, or more kilometres distant.

The great majority of phase to ground faults are lightning initiated, with an arc flash over the line insulators. This provides a path for the E.H.V. supply to flow to earth. By inference, the risk is during thunderstorms - even those over the horizon - through which the transmission line passes.

As a construction project such as this may well take a few months, the likelihood is that a fault surge will occur during this time, on one of the feeders concerned. Consequently, a length of jointed pipeline will undergo induction and a worst case in the study yielding 38V/100mm. There is no co-ordination Australian standard, so the limit suggested is derived from AS3859 (The Effect of Electric Current through the Human Body) (App.1, Ref 12).

At 50Hz, with a current duration of 100 mS max., the fibrillation danger condition occurs for a 1000 ohm hand to hand path at about 400 mA. Adopting a factor of safety of 2, plus the possibility of a lower resistance path - i.e. both hands to torso, the suggested limit is around 100-150 volts, for construction activity.

This limit will be reached on a 300m length of pipe. If the installed pipe is not jointed to any earthed object at either end, it will have an inherent electrostatic capacity to ground of perhaps 1 microfarad - depending on the coating type. This corresponds to a reactance of 3000 ohms, which would materially reduce the body current to ground. However, it would seem unwise to rely on the continued isolation of such a pipelength. Indeed the time would arise when it had to be jointed to existing mains at one end, thus producing a maximum hazard at the other.

Consequently, it is recommended that any jointed lengths of pipe of 300m be earthed to temporary electrodes of 2 ohms or less at each end. These electrodes could be left permanently if desired, but see comment on Cathodic Protection below.

All earthing cables, temporary or permanent should be 35mm² and insulated.

The final construction would also need electrodes at each end, in accordance with the calculations in the study above (see equations (1), (2), (3) in the LFI Study). Whilst one ohm electrodes would be preferred, to reduce the shock energy to personnel, two ohm electrodes would suffice. In addition, the electrodes on the existing whole exposure length trunk main could well be checked, and if over two ohms, be supplemented to

achieve two ohms. The effect of two parallel pipelines with loop current protection is synergistic - each lends a measure of electric field suppression to the other. Indeed, with two pipes thus served, the third pipe, which is only along portion of the exposure, would be adequately protected without further action.

The matter of installing earth electrodes impinges on the cathodic protection design. Whilst polarisation cells can be installed in series with the earth electrodes to contain the C.P. current, yet pass the induced fault current, there are some negatives to this procedure. The long term performance, durability, robustness and resistance to vandalism is a matter for maintenance concern. If on the other hand, earth electrodes are left directly connected to the ends of the pipeline (and perhaps "temporary" intermediate ones as well), the effect on the C.P. design will not generally be of much concern.

The C.P. system will depress the natural pipe potential by something in the order of one quarter of a volt. Ignoring polarisation, this will cause each one ohm electrode to pass about a quarter of an amp (or two ohm electrode, each one eighth of an amp). If, say four electrodes, each of 2 ohm resistance to earth are left in situ then the total drain on the C.P. system is only half an amp. As impressed current C.P. is the norm, this is of no consequence. Indeed two pluses occur: (i) The earth electrodes are now under cathodic protection and (ii) The current demand on a relatively short exposure (1.3km in this case) of the well coated pipeline is in the order of a few milliamps, which is difficult to regulate on the C.P. rectifier. The appearance of a holiday in the coating - for example by excavating machinery - will place a demand of perhaps ten times the pipeline initial current. This may well go unnoticed unless the C.P. system has a potential alarm. However, if there is a "ballast" load of half an amp to the earth electrodes, such extra demand will be in the order of 5% only - not enough to even justify resetting the rectifier.

Grading Rings (Partial Faraday Cages). The only location where a grading ring would be necessary is at the reservoir end of the pipeline. This is because the loop current protection would cease at the foot of the hill, and the total LFI/fault voltage appearing on the pipe would be in the order of 260 Volts (worst case). If however, the pipe is bonded or jointed into other pipes or a metal reservoir, this grading ring would be unnecessary.

(B) The load current induction, as noted in the survey, is of no consequence.

(C) **Earth Potential Rise** was calculated to be of serious note from lightning flashes, when proximate to one or other of the transmission line towers. As the likelihood of work proceeding on the pipeline during a local thunderstorm seems remote, this is of not much concern. Nevertheless, the need to take cover, e.g. in a rubber tyred vehicle, during such local storms is emphasised. If on foot, paradoxically the lowest hazard area will be found directly beneath the line conductors in mid span. Nowhere in an exposed site of course is totally safe from the enormous energy levels in lightning flashes.

The EPR level from current follow through on towers after an arc occurs across insulators would appear to be only of concern to staff running test leads for electrical measurements, with leads of 20m or so, radial to transmission towers. Again, this would be only in the vicinity of a local thunderstorm, and consequently not of great concern.


Grading rings, for E.P.R. protection, would only be required on scour valves and associated fittings, if within 20m of any tower. It would be preferred practice to site no metal access devices connected to the pipe within 50m if possible, to minimise lightning E.P.R. conditions also.

Other Hazards

1. The construction aspects of handling long pipe sections adjacent to E.H.V. electrical transmission lines has not been addressed. Obviously, construction designers would be acutely aware of the physical hazards. Nevertheless, it is desired to raise the statistic that over 10% of the several dozen (average) annual electrical incident fatalities in Australia, relate to contact with overhead conductors by metal pipes being manipulated under power lines.

2. Electrostatics

The presence of an insulated conductor i.e. on a rubber tyred vehicle) near a power line will be sufficient to induce, capacitively, some voltage. Provided the distance is several metres, this will not be of personnel concern. However, contact of the charged pipe with earthed objects can give rise to a spark sufficient to ignite spilled fuel. It can also cause secondary accidents, if such a discharge involves personnel in precarious positions. It is assumed that construction precautions in this environment have not been called for in this study.



2. 1. 95

Appendix 1

Written References pertinent to Induction Studies and Earth Potential Rise Calculations; also relevant formulae and their derivation.

1. Sunde, E.D. "Earth Conduction Effects in Transmission Systems". Van Nostrand. New York, 1949.
2. Westinghouse Electric Corporation, U.S.A. "Electrical Transmission and Distribution Handbook" 1950.
3. "Application Guide for the Low Frequency Induction Code" by the Central Joint Committee for the Co-ordination of Power and Telecommunications Systems. 1981.
4. Code of Practice for the Protection of Personnel and Equipment against Earth Potential Rise caused by High Voltage Power System Faults - same origin as (1) above. 1984.
5. Australian Standard AS2832.1 - Guide to the Protection of Metals, Pipes, Cables and Ducts.
6. Australian Standard AS3859 - Effect of Electric Current Through the Human Body.
7. $E = CILK$. This is the traditional induction earth fault current formula, from Reference 3 page 8. It will be found in other texts, e.g. Ref. 2, page 41.

E	=	The induced longitudinal voltage between the ends of the exposure (volts)
C	=	The mutual impedance per length of exposure, without shielding, at 50Hz - see below.
I	=	The inducing (zero sequence in this case) current, in amps
L	=	Length of exposure (possibly Cosine θ if the paths are not parallel) in kilometres
K	=	The shielding factor ($0 < K < 1$) due to the presence of modifying conduction.

C is a complex quantity and is expanded to:

$$C = 2\pi f \left[\log_e \left(1 + \frac{6 \times 10^5 \rho}{d^2 f} \right) \right] \times 10^{-4} \text{ henries/km}$$

f is frequency (50Hz)

ρ is soil resistivity in ohm. metres

d is spacing in metres between earth return circuits.

There are other derivations possible. However it is customary to utilise a nomogram (e.g. Reference 3, Page 19) to derive C.

8. Resistivity of copper at 20°C is 1.72×10^{-8} ohm/metre (from A.E. Knowlton, Electrical Engineers Handbook Section 4).

$$9. \quad d = \frac{l\rho}{2\pi V} \quad \text{or} \quad V = \frac{l\rho}{2\pi d}$$

This is the traditional formula to indicate the relationship between resistivity (ρ) Current (I), Voltage (V) at distance (d) from a current injection point into uniform soil. It will be found in AS2832.1, Reference 6, and other Standards.

10. The resistivity for mild steel is 14×10^{-8} ohm/metre (from A.E. Knowlton, Electrical Engineers Handbook Section 4).

11. Adaption from Faraday's Law for CMF induced in a conductor in an alternating magnetic field (A.E. Knowlton, Electrical Engineers Handbook, Section 2)

$$e = B I V 10^{-8} \text{ Volts (CGS units)}$$

$$B = \text{flux level in gauss}$$

$$l = \text{length in cm}$$

$$V = \text{flux cutting rate}$$

$$= \omega$$

$$= 2 \pi f \text{ (frequency)}$$

$$= 314.$$

12. Australian Standard AS3859 - The Effect of Electric Current in the Human Body.

APPENDIX 2**Data specific to job, and source of same**

1. Resistivity of earth at various depths and locations, in ohm metres.

Pin Spacing Metres	<u>Location 1</u> Illaweena St end of section (Drg 486/4/6- W10041P	<u>Location 2</u> Illaweena St near C.P. Rectifier	<u>Location 3</u> QEC Easement at foot of Reservoir Hill	<u>Location 4</u> At Wembley St Reservoir
4m	9.5 *	170 *	75 *	3200 *
10m	18	36	114	3397
20m	27	68	353	643

* weighted average of two readings at right angles. Weighting approx. x 2 for pipeline direction.

Resistivity figures from Mr. J. Say, B.C.C. Dept. of W.S. & S.

2. Effect of Power Line Load Current - both feeders operating at rated level: Electromagnetic field at ground level, under Phase wires: 10 milligauss (Line is Dual 275 kV 3 phase part of QEC, S.E.Qld. Mesh)

Data from Mr. T. Tuting, QEC

3. Power Line Zero Sequence (phase to earth) Fault Current at Illaweena Street (No appreciable difference along exposure)
O.H.E.W. shielding factor 0.9
Feeder 802 - 5.69 kA (3.3kA from Belmont, 2.3kA from Mt. England)
Feeder 804 - 6.86 kA (3.9kA from Swanbank, 2.97kA from Belmont)
i.e. 3.9kA is the worst case, with the fault beyond the exposure.

From Mr. F. Tuting, QEC

achieve two ohms. The effect of two parallel pipelines with loop current protection is synergistic - each lends a measure of electric field suppression to the other. Indeed, with two pipes thus served, the third pipe, which is only along portion of the exposure, would be adequately protected without further action.

The matter of installing earth electrodes impinges on the cathodic protection design. Whilst polarisation cells can be installed in series with the earth electrodes to contain the C.P. current, yet pass the induced fault current, there are some negatives to this procedure. The long term performance, durability, robustness and resistance to vandalism is a matter for maintenance concern. If on the other hand, earth electrodes are left directly connected to the ends of the pipeline (and perhaps "temporary" intermediate ones as well), the effect on the C.P. design will not generally be of much concern.

The C.P. system will depress the natural pipe potential by something in the order of one quarter of a volt. Ignoring polarisation, this will cause each one ohm electrode to pass about a quarter of an amp (or two ohm electrode, each one eighth of an amp). If, say four electrodes, each of 2 ohm resistance to earth are left in situ then the total drain on the C.P. system is only half an amp. As impressed current C.P. is the norm, this is of no consequence. Indeed two pluses occur: (i) The earth electrodes are now under cathodic protection and (ii) The current demand on a relatively short exposure (1.3km in this case) of the well coated pipeline is in the order of a few milliamps, which is difficult to regulate on the C.P. rectifier. The appearance of a holiday in the coating - for example by excavating machinery - will place a demand of perhaps ten times the pipeline initial current. This may well go unnoticed unless the C.P. system has a potential alarm. However, if there is a "ballast" load of half an amp to the earth electrodes, such extra demand will be in the order of 5% only - not enough to even justify resetting the rectifier.

Grading Rings (Partial Faraday Cages). The only location where a grading ring would be necessary is at the reservoir end of the pipeline. This is because the loop current protection would cease at the foot of the hill, and the total LFI/fault voltage appearing on the pipe would be in the order of 260 Volts (worst case). If however, the pipe is bonded or jointed into other pipes or a metal reservoir, this grading ring would be unnecessary.

(B) The load current induction, as noted in the survey, is of no consequence.

(C) **Earth Potential Rise** was calculated to be of serious note from lightning flashes, when proximate to one or other of the transmission line towers. As the likelihood of work proceeding on the pipeline during a local thunderstorm seems remote, this is of not much concern. Nevertheless, the need to take cover, e.g. in a rubber tyred vehicle, during such local storms is emphasised. If on foot, paradoxically the lowest hazard area will be found directly beneath the line conductors in mid span. Nowhere in an exposed site of course is totally safe from the enormous energy levels in lightning flashes.

The EPR level from current follow through on towers after an arc occurs across insulators would appear to be only of concern to staff running test leads for electrical measurements, with leads of 20m or so, radial to transmission towers. Again, this would be only in the vicinity of a local thunderstorm, and consequently not of great concern.


Grading rings, for E.P.R. protection, would only be required on scour valves and associated fittings, if within 20m of any tower. It would be preferred practice to site no metal access devices connected to the pipe within 50m if possible, to minimise lightning E.P.R. conditions also.

Other Hazards

1. The construction aspects of handling long pipe sections adjacent to E.H.V. electrical transmission lines has not been addressed. Obviously, construction designers would be acutely aware of the physical hazards. Nevertheless, it is desired to raise the statistic that over 10% of the several dozen (average) annual electrical incident fatalities in Australia, relate to contact with overhead conductors by metal pipes being manipulated under power lines.

2. **Electrostatics**

The presence of an insulated conductor i.e. on a rubber tyred vehicle) near a power line will be sufficient to induce, capacitively, some voltage. Provided the distance is several metres, this will not be of personnel concern. However, contact of the charged pipe with earthed objects can give rise to a spark sufficient to ignite spilled fuel. It can also cause secondary accidents, if such a discharge involves personnel in precarious positions. It is assumed that construction precautions in this environment have not been called for in this study.



2. 1. 95

Appendix 1

Written References pertinent to Induction Studies and Earth Potential Rise Calculations; also relevant formulae and their derivation.

1. Sunde, E.D. "Earth Conduction Effects in Transmission Systems". Van Nostrand. New York, 1949.
2. Westinghouse Electric Corporation, U.S.A. "Electrical Transmission and Distribution Handbook" 1950.
3. "Application Guide for the Low Frequency Induction Code" by the Central Joint Committee for the Co-ordination of Power and Telecommunications Systems. 1981.
4. Code of Practice for the Protection of Personnel and Equipment against Earth Potential Rise caused by High Voltage Power System Faults - same origin as (1) above. 1984.
5. Australian Standard AS2832.1 - Guide to the Protection of Metals, Pipes, Cables and Ducts.
6. Australian Standard AS3859 - Effect of Electric Current Through the Human Body.
7. $E = CILK$. This is the traditional induction earth fault current formula, from Reference 3 page 8. It will be found in other texts, e.g. Ref. 2, page 41.

- E = The induced longitudinal voltage between the ends of the exposure (volts)
- C = The mutual impedance per length of exposure, without shielding, at 50Hz - see below.
- I = The inducing (zero sequence in this case) current, in amps
- L = Length of exposure (possibly Cosine θ if the paths are not parallel) in kilometres
- K = The shielding factor ($0 < K < 1$) due to the presence of modifying conduction.

C is a complex quantity and is expanded to:

$$C = 2\pi f \left[\log_e \left(1 + \frac{6 \times 10^5 \rho}{d^2 f} \right) \right] \times 10^{-4} \text{ henries/km}$$

- f is frequency (50Hz)
- ρ is soil resistivity in ohm. metres
- d is spacing in metres between earth return circuits.

There are other derivations possible. However it is customary to utilise a nomogram (e.g. Reference 3, Page 19) to derive C .

8. Resistivity of copper at 20°C is 1.72×10^{-8} ohm/metre (from A.E. Knowlton, Electrical Engineers Handbook Section 4).

$$9. \quad d = \frac{l\rho}{2\pi V} \quad \text{or} \quad V = \frac{l\rho}{2\pi d}$$

This is the traditional formula to indicate the relationship between resistivity (ρ) Current (I), Voltage (V) at distance (d) from a current injection point into uniform soil. It will be found in AS2832.1, Reference 6, and other Standards.

10. The resistivity for mild steel is 14×10^{-8} ohm/metre (from A.E. Knowlton, Electrical Engineers Handbook Section 4).

11. Adaption from Faraday's Law for CMF induced in a conductor in an alternating magnetic field (A.E. Knowlton, Electrical Engineers Handbook, Section 2)

$$e = B I V 10^{-8} \text{ Volts (CGS units)}$$

$$B = \text{flux level in gauss}$$

$$I = \text{length in cm}$$

$$V = \text{flux cutting rate}$$

$$= \omega$$

$$= 2 \pi f \text{ (frequency)}$$

$$= 314.$$

12. Australian Standard AS3859 - The Effect of Electric Current in the Human Body.

APPENDIX 2**Data specific to job, and source of same**

1. Resistivity of earth at various depths and locations, in ohm metres.

Pin Spacing Metres	<u>Location 1</u> Illaweena St end of section (Drg 486/4/6- W10041P	<u>Location 2</u> Illaweena St near C.P. Rectifier	<u>Location 3</u> QEC Easement at foot of Reservoir Hill	<u>Location 4</u> At Wembley St Reservoir
4m	9.5 *	170 *	75 *	3200 *
10m	18	36	114	3397
20m	27	68	353	643

* weighted average of two readings at right angles. Weighting approx. x 2 for pipeline direction.


Resistivity figures from Mr. J. Say, B.C.C. Dept. of W.S. & S.

2. Effect of Power Line Load Current - both feeders operating at rated level: Electromagnetic field at ground level, under Phase wires: 10 milligauss (Line is Dual 275 kV 3 phase part of QEC, S.E.Qld. Mesh)


Data from Mr. T. Tuting, QEC

3. Power Line Zero Sequence (phase to earth) Fault Current at Illaweena Street (No appreciable difference along exposure)
O.H.E.W. shielding factor 0.9
Feeder 802 - 5.69 kA (3.3kA from Belmont, 2.3kA from Mt. England)
Feeder 804 - 6.86 kA (3.9kA from Swanbank, 2.97kA from Belmont)
i.e. 3.9kA is the worst case, with the fault beyond the exposure.

From Mr. F. Tuting, QEC



O	11.4.95	ISSUED FOR CONSTRUCTION	R:L.	MANAGER		DIRECTOR OF PLANNING & DESIGN		DESIGN	J.SAY	11.4.95	PROJECT ILLAWEENA ST., TRUNK MAIN CATHODIC PROTECTION
				DATE:		DATE:		DRAWN	R.LISTON	11.4.95	
				DIRECTOR OF CONSTRUCTION	DIRECTOR OF M & E SERVICES	DIRECTOR OF SEW. OPERATIONS/W.S. DISTRIBUTION	CHECKED	ENGINEER IN CHARGE		TITLE ILLAWEENA STREET C.P. SYSTEM	
											SUPERVISING ENGINEER
No	DATE	AMENDMENT	BY	DATE:	DATE:	DATE:	CADD FILE No. 66C0041-				

 Brisbane City		BRISBANE CITY COUNCIL DEPARTMENT OF WATER SUPPLY AND SEWERAGE MECHANICAL & ELECTRICAL SERVICES	
SCALE: N.T.S.		No. 3 OF 3 SHEETS	
DRAWING No. 486/6/6-SA1C0041		AMEND. 0	

NOTES


A	8.96	MODIFIED
D	3.96	ISSUED FOR APPROVAL
No	DATE	AMENDMENT
		INITIALS

AMENDMENT & ISSUE REGISTER

MANAGER	DIRECTOR OF TECHNOLOGY SERVICES
DATE:	DATE:
DIRECTOR OF PLANNING & DESIGN	DIRECTOR OF WATER SUPPLY
DATE:	DATE:
DIRECTOR OF CONSTRUCTION	DATE:

DESIGN	J.S.	21.3.96	ENGINEER IN CHARGE
DRAWN	O.L.P.	21.3.96	SUPERVISING ENGINEER
TRACED			
CHECKED			A2 REDUCED

REFERENCES	COPYRIGHT © 1996
CADD FILE No. 66T0010A	No reproduction is permitted in whole or in part without the express consent of
THIS DRAWING WAS PRODUCED USING QIKDRAW	BRISBANE CITY COUNCIL BRISBANE WATER




BRISBANE CITY COUNCIL
BRISBANE WATER
TECHNOLOGY SERVICES BRANCH
TECHNICAL SERVICES

PROJECT:
**CATHODIC PROTECTION
470 DIA. TRUNK WATER MAIN**


TITLE:
**CATHODIC PROTECTION SYSTEM
ILLAWEEENA STREET**

SCALE:	No. 1 OF 1 SHEETS
DRAWING No.	AMEND.
486/6/6-SA1T0010E	A



RECTIFIER UNIT

FIELD



BRISBANE
CITY COUNCIL
DEPARTMENT OF WATER
SUPPLY & SEWERAGE
MECHANICAL & ELECTRICAL SERVICES

PROJECT
STANDARD
CATHODIC PROTECTION


TITLE
RECTIFIER UNIT
WITH DATA LOGGING FACILITIES
WIRING DIAGRAM

DRAWN	NAME	DATE	SUPER ENG.	NAME	DATE	SCALE	SIZE
DESIGN	J.S.	3.8.93	SENIOR ENG.		25.8.93		A3
CHECKED	J.S.	25.8.93	ELECT. ENG.				AMEND
DRAWING NO.	486/6/25-AA100021E						A
ACAD12 FILE NO. A625C21							


NOTES


- 1 CABINET TO BE MANUFACTURED FROM 2.0mm 316-2B STAINLESS STEEL
- 2 UNLESS SPECIFIED SUPPLY CABINET WITH PLINTH. (MOUNT PLINTH TO CABINET USING STAINLESS STEEL SCREWS)
- 3 MOUNTING PANELS, ESCUTCHEON PLATES & DB HAT SECTION TO BE ZINC PLATED MILD STEEL POWDER COATED ORANGE.
- 4 PROVIDE STAINLESS STEEL EARTH STUOS TO DOOR AND SWITCHBOARD CABINET.
- 5 DEGREE OF WEATHER PROTECTION - IP55
- 6 DOORS TO BE STIFFENED AND FITTED WITH 3 POINT LOCKING, LOCKWOOD BARRELS, EMKA SWING HANDLES (MOUNTED VERTICALLY) CHROME TYPE (PADLOCKABLE)
- 7 INSULATION TO BE 25mm THICK FIBREGLASS THERMAL INSULATION IN ALUMINIUM SANDWICH INSULATION TO BE SECURELY FASTENED TO INSIDE OF CUBICLE BY MEANS OTHER THAN ADHESIVE.
- 8 TOP SUNSHIELD TO BE MADE OF 316 STAINLESS STEEL SHEETING 2.0mm THICK WITH A POLISHED 2B FINISH. TOP SUNSHIELD SHALL BE SUPPORTED BY 316 S.S. "Z" SECTIONS WHICH SHALL BE WELDED TO THE TOP SKIN OF THE SWITCHBOARD. THE SUNSHIELD SHALL BE BOLTED TO THESE SUPPORTS.
- 9 SOCKETS PROVIDED TO ALLOW 10mm EYEBOLTS TO BE SCREWED IN FROM TOP OF SWITCHBOARD AND REMOVED AFTER INSTALLATION. SOCKETS SHALL NOT ALLOW INGRESS OF WATER, DUST & VERMIN TO SWITCHBOARD.

100x75 HOT DIPPED GALVANISED CHANNEL




O	21.10.94	ISSUED FOR CONSTRUCTION	R.L.	MANAGER		DIRECTOR OF PLANNING & DESIGN		DESIGN	J.SAY	30.8.94	PROJECT ILLAWEEENA STREET TRUNK MAIN
				DATE:		DATE:		DRAWN	R.LISTON	30.8.94	
				DIRECTOR OF CONSTRUCTION		DIRECTOR OF M & E SERVICES		CHECKED	<i>B.</i>	24.10.94	
				DATE:		DATE:		ENGINEER IN CHARGE			
No	DATE	AMENDMENT	BY	DATE	DATE	DATE	SUPERVISING ENGINEER		<i>M. Fisher</i>	CADD FILE No. 66C021-	TITLE SWITCHBOARD GENERAL ARRANGEMENT

		BRISBANE CITY COUNCIL	
		DEPARTMENT OF WATER SUPPLY AND SEWERAGE	
		MECHANICAL & ELECTRICAL SERVICES	
SCALE: NTS		No. 1 OF 1 SHEETS	
DRAWING No.		AMEND.	
486/6/6-SA1C0021E		0	



O	2.12.93	ISSUED FOR CONSTRUCTION	R.L.	MANAGER		DIRECTOR OF PLANNING & DESIGN		DESIGN			PROJECT STANDARD CATHODIC PROTECTION		
				DATE:		DATE:		DRAWN	R.LISTON	2.12.93			
				DIRECTOR OF CONSTRUCTION		DIRECTOR OF M & E SERVICES		DIRECTOR OF SEW. OPERATIONS/W.S. DISTRIBUTION		CHECKED			
				DATE:		DATE:		DATE:		ENGINEER IN CHARGE			
No	DATE	AMENDMENT	BY	DATE:		DATE:		DATE:		SUPERVISING ENGINEER		TITLE VERTICAL GROUND BED DETAILS	
CADD FILE No. A625C024E													

		BRISBANE CITY COUNCIL	
DEPARTMENT OF WATER SUPPLY AND SEWERAGE		MECHANICAL & ELECTRICAL SERVICES	
SCALE: NTS		No. 1 OF 1 SHEETS	
DRAWING No.		AMEND.	
486/6/25-AA1C0024E		Page 46 of 50	

Q-Pulse Id TMS1264

Active 21/07/2015



TRANSFORMER OUTPUT CURRENT & VOLTAGE
TO SUIT APPLICATION PROVIDING SUITABLE
RESOLUTION & CONTROL

AMMETER & VOLTMETER TO PROVIDE
SUITABLE RESOLUTION FOR SYSTEM

- + POSITIVE WIRING TO BE RED
- NEGATIVE WIRING TO BE BLACK
- L.V. AC WIRING TO BE 4mm2 BLUE/WHITE
- DC WIRING TO BE 4mm2
- 240V AC WIRING TO BE 1.5mm2-BROWN/BLACK
- REFERENCE WIRING TO BE 1.5mm2-GRAY

LEGEND

K1 - 240V RELAY
K2,K3, & K4 - 24V DC RELAYS
R1 - SHUNT RESISTOR (SIZED TO PRODUCE A 1V DROP AT FULL LOAD).
R2,R3 - VOLTAGE DIVIDER (SIZED TO PRODUCE A VOLTAGE OF 1V ACROSS R2 AT MAX. OUTPUT VOLTAGE)
R4,R5 - BLEED RESISTORS (IF REQUIRED)
+VE AND -VE DC FUSES TO BE SIZED APPROX. 5AMPS ABOVE NORMAL OUTPUT CURRENT

REFERENCE DRAWINGS

SWITCHBOARD GENERAL ARRANGEMENT REF DRG No.486/6/6-SAIC0021E
RTU & PRESS. TRANSM. SCHEMATIC DIAGRAM REF DRG No.486/6/6-SAIC0032E
SWITCHBOARD TERMINATION DIAGRAMS REF DRGS No.486/6/6-SAIC0033E TO SAIC0036E

Page 47 of 55



SCALE: NTS	No. 1 OF 5 SHEETS	A3
DRAWING No. 486/6/6-SA1C0032E		AMEND A


SWITCHBOARD**24VDC INTERFACE
TERMINAL STRIP**

(NOTE 1)

**REMOTE TELEMETRY UNIT
MIXED I/O MODULE No.1**TYPE FRN1490A
(NOTE 2)**NOTES**

1 FUSES ARE 100mA RATED

2 MIXED I/O MODULE CONFIGURATION INDICATIVE ONLY


**REFERENCE DRAWINGS**SWITCHBOARD GENERAL ARRANGEMENT REFER
DRG No. 486/6/6-SA1C0021ESWITCHBOARD SCHEMATIC DIAGRAM REFER
DRG No. 486/6/6-SA1C0032E**LEGEND**

Δ TERMINAL IN CATHODIC PROTECTION UNIT

$\text{---} \text{---} \text{---}$ INSTRUMENT EARTH

CONTINUED ON DRG No.486/6/6-SA1C0034E

A	12.4.95	MTR2 ADDED	R.L.	MANAGER		DIRECTOR OF PLANNING & DESIGN		DESIGN	J.S.	25.1.95	PROJECT	ILLAWEEENA ST. TRUNK MAIN CATHODIC PROTECTION		
				DATE:		DATE:		DRAWN	R.LISTON	23.1.95				
				DIRECTOR OF CONSTRUCTION		DIRECTOR OF M & E SERVICES		DIRECTOR OF SEW. OPERATIONS/W.S. DISTRIBUTION		CHECKED	J.S.	25.1.95	TITLE	SWITCHBOARD TERMINATION DIAGRAM
				DATE:		DATE:		DATE:		ENGINEER IN CHARGE				
O	23.1.95	ISSUED FOR CONSTRUCTION	R.L.					SUPERVISING ENGINEER		M.JUKES	CADD FILE No. 66C033A			
No	DATE	AMENDMENT	BY	DATE:	DATE:	DATE:								



BRISBANE CITY COUNCIL

DEPARTMENT OF WATER SUPPLY
AND SEWERAGE

MECHANICAL & ELECTRICAL SERVICES

SCALE: NTS

No. 2 OF 5 SHEETS

DRAWING No.

486/6/6-SA1C0033E

AMEND.

A

**BRISBANE CITY COUNCIL**DEPARTMENT OF WATER SUPPLY
AND SEWERAGE

Brisbane City

MECHANICAL & ELECTRICAL SERVICES

SCALE: NTS

No. 2 OF 5 SHEETS

DRAWING No.

486/6/6-SA1C0033E

AMEND.


A

24VDC INTERFACE
TERMINAL STRIP
(NOTE 1)

REMOTE TELEMETRY UNIT
MIXED I/O MODULE No.1
TYPE FRN1490A
(NOTE 2)

24VDC INTERFACE
TERMINAL STRIP
(NOTE 1)

SWITCHBOARD



NOTES

- 1 FUSES ARE 100mA RATED
- 2 MIXED I/O MODULE CONFIGURATION INDICATIVE ONLY.

REFERENCE DRAWINGS


SWITCHBOARD GENERAL ARRANGEMENT
REF DRG No. 486/6/6-SA1C0021E
SWITCHBOARD SCHEMATIC DIAGRAM
REF DRG No. 486/6/6-SA1C0032E

LEGEND

- △ TERMINAL IN CATHODIC PROTECTION UNIT
⊥ INSTRUMENT EARTH

CONTINUED ON DRG No. 486/6/6-SA1C0035E


				MANAGER		DIRECTOR OF PLANNING & DESIGN		DESIGN	<i>AS</i>	25.1.95	PROJECT	
				DATE:		DATE:		DRAWN	R.LISTON	23.1.95	ILLAWEEA ST. TRUNK MAIN CATHODIC PROTECTION	
				DIRECTOR OF CONSTRUCTION		DIRECTOR OF M & E SERVICES		CHECKED	<i>AS</i>	25.1.95	TITLE	
				DATE:		DATE:		ENGINEER IN CHARGE			SWITCHBOARD TERMINATION DIAGRAM	
				DATE:		DATE:		SUPERVISING ENGINEER		<i>[Signature]</i>	CADD FILE No. 66C034-	
				DATE:		DATE:		DATE:			SCALE: NTS	
O	23.11.95	ISSUED FOR CONSTRUCTION	R.L.	DATE:		DATE:		DATE:			No. 3 OF 5 SHEETS	
No	DATE	AMENDMENT	BY	DATE:		DATE:		DATE:			DRAWING No. 486/6/6-SA1C0034E	
				DATE:		DATE:		DATE:			AMEND. 0	



BRISBANE CITY COUNCIL
DEPARTMENT OF WATER SUPPLY AND SEWERAGE
MECHANICAL & ELECTRICAL SERVICES

SCALE: NTS
DRAWING No. 486/6/6-SA1C0034E
No. 3 OF 5 SHEETS
AMEND. 0

MASTER Page 50 of 55



CONTINUED ON DRG No. 486/6/6-SA1C0036E

A	12.4.95	BUFFER TERMINALS ADDED	R.L.	MANAGER		DIRECTOR OF PLANNING & DESIGN		DESIGN	J.S.	25.1.95	PROJECT ILLAWEENA ST. TRUNK MAIN CATHODIC PROTECTION
	23.1.95	ISSUED FOR CONSTRUCTION	R.L.	DATE:		DATE:		DRAWN	R.LISTON	23.1.95	
				DIRECTOR OF CONSTRUCTION		DIRECTOR OF M & E SERVICES		CHECKED	J.S.	25.1.95	
				DATE:		DATE:		ENGINEER IN CHARGE			
No	DATE	AMENDMENT	BY	DATE:	DATE:	DATE:		SUPERVISING ENGINEER	M.JUKES	CADD FILE No. 66C035A	TITLE SWITCHBOARD TERMINATION DIAGRAM




BRISBANE CITY COUNCIL
DEPARTMENT OF WATER SUPPLY
AND SEWERAGE
MECHANICAL & ELECTRICAL SERVICES

SCALE: NTS
DRAWING No. 486/6/6-SA1C0035E
No. 4 OF 5 SHEETS
AMEND. A


24VDC INTERFACE

TERMINAL STRIP

(NOTE 1)



REMOTE TELEMETRY UNIT
ANALOG INPUT MODULE No.3
TYPE FRN1421A





NOTES

1 FUSES ARE 100mA RATED

REFERENCE DRAWINGS

CATHODIC PROTECTION UNIT REFER DRG No. 486/6/6-SA1C0031E
SWITCHBOARD GENERAL ARRANGEMENT REFER DRG No. 486/6/6-SA1C0021E
SWITCHBOARD SCHEMATIC DIAGRAM REFER DRG No. 486/6/6-SA1C0032E


		MANAGER		DIRECTOR OF PLANNING & DESIGN		DESIGN	<i>AS</i>	25.1.95	PROJECT		ILLAWEEENA ST. TRUNK MAIN CATHODIC PROTECTION		 BRISBANE CITY COUNCIL DEPARTMENT OF WATER SUPPLY AND SEWERAGE MECHANICAL & ELECTRICAL SERVICES		
		DATE:		DATE:		DRAWN	R.LISTON	23.1.95	TITLE		SWITCHBOARD TERMINATION DIAGRAM			SCALE: NTS	No. 5 OF 5 SHEETS
		DIRECTOR OF CONSTRUCTION		DIRECTOR OF M & E SERVICES		CHECKED		<i>AS</i>	25.1.95	CADD FILE No. 66C036-		DRAWING No.		AMEND.	
0	23.1.95	ISSUED FOR CONSTRUCTION		R.L.		ENGINEER IN CHARGE						486/6/6-SA1C0036E		0	
No	DATE	AMENDMENT		BY		DATE:		DATE:		DATE:					



ILLAWEENA ST.

CONTINUED ON DRAWING No. 486/6/6-SA1C0040E


				MANAGER		DIRECTOR OF PLANNING & DESIGN		DESIGN	J.SAY	11.4.95	PROJECT		
				DATE:		DATE:		DRAWN	R.LISTON	11.4.95	ILLAWEENA ST. TRUNK MAIN CATHODIC PROTECTION		
				DIRECTOR OF CONSTRUCTION		DIRECTOR OF M & E SERVICES		CHECKED			TITLE		
						DIRECTOR OF SEW. OPERATIONS/W.S. DISTRIBUTION		ENGINEER IN CHARGE			ILLAWEENA STREET C.P. SYSTEM		
				DATE:		DATE:		SUPERVISING ENGINEER			CADD FILE No. 66C0039-		
0	11.4.95	ISSUED FOR CONSTRUCTION	R.L.									BRISBANE CITY COUNCIL DEPARTMENT OF WATER SUPPLY AND SEWERAGE MECHANICAL & ELECTRICAL SERVICES	
No	DATE	AMENDMENT	BY	DATE:	DATE:	DATE:					SCALE: N.T.S. No. 1 OF 3 SHEETS		
												DRAWING No. 486/6/6-SA1C0039E	
												AMEND. 0	



LEGEND

(C) REFERENCE

(R) COUPON TYPE REFERENCE

				MANAGER		DIRECTOR OF PLANNING & DESIGN		DESIGN	J.SAY	11.4.95	PROJECT		 BRISBANE CITY COUNCIL DEPARTMENT OF WATER SUPPLY AND SEWERAGE MECHANICAL & ELECTRICAL SERVICES	
				DATE:		DATE:		DRAWN	R.LISTON	11.4.95	ILLAWEENA ST., TRUNK MAIN CATHODIC PROTECTION			
				DIRECTOR OF CONSTRUCTION		DIRECTOR OF M & E SERVICES		CHECKED	18	12.4.95	TITLE			
				DATE:		DATE:		ENGINEER IN CHARGE			ILLAWEENA STREET C.P. SYSTEM		SCALE: N.T.S.	No. 2 OF 3 SHEETS
O	11.4.95	ISSUED FOR CONSTRUCTION	R.L.	DATE:		DATE:		SUPERVISING ENGINEER			CADD FILE No. 66C0040-		DRAWING No.	AMEND.
No	DATE	AMENDMENT	BY	DATE:		DATE:		M. Fisher.					486/6/6-SA1C0040E	0



BRISBANE CITY COUNCIL

DEPARTMENT OF WATER SUPPLY
AND SEWERAGE

MECHANICAL & ELECTRICAL SERVICES

SCALE: N.T.S.


No. 2 OF 3 SHEETS

DRAWING No.

486/6/6-SA1C0040E


AMEND.

0




SECTIONAL DETAIL OF FLANGE ADAPTER

NOTES: Bolts and Nuts to be Galvanised Mild Steel.
Thread length in all cases to be Dia. + 2 (minimum)
For Bolts & Studs for John & Wattersley Valves
see Drawing No. 2/13.205.



WELDED LIFTING EYES
WELD TO TOP OF EACH FLANGE

To be fitted to all Flange Adapters
except 300 & 225
Alternatively each may be tapped & fitted
with 12 screwed Eye Bolts.




BOLTS FOR 1370 & 1530FA.
FOR STEEL FLANGES

TABLE OF DIMENSIONS																				
DIA:	R DIA:	T ₁ T ₂		A DIA:	B DIA:	C	D DIA:	E	F	G	H	J	K	L ₁ L ₂ (L Sq.)	M	NUMBER OF BOLTS.	LD. OF RUBBER RING.	P	Ø CROSS SECTION OF RING	
225	273 ⁺⁰ ₋₁	38	16	37	34	6	20	23	324	368	279	80	48	18 12	152	8	260	5	△ 12	
300	337 ⁺⁰ ₋₁	25		37	34	6	20	23	406	457	343	71	57	18 12	152	12	324	10	25	
385	415 ⁺⁰ ₋₁	25		37	34	6	24	27	495	552	421	80	60	18 14	164	12	402	10	25	
410	445 ⁺⁰ ₋₁	25		43	40	8	24	27	521	578	451	80	60	18 14	166	12	432	10	25	
470	510 ⁺⁰ ₋₁	25		43	40	8	24	27	584	641	516	85	60	18 14	171	12	495	10	25	
510	548 ⁺⁰ ₋₁	25		43	40	8	24	27	641	705	552	85	60	18 14	171	16	530	△ 10	25	
540	575 ⁺⁰ ₋₁	28		43	40	8	24	27	673	736	581	90	65	18 14	181	16	560	△ 10	25	
600	635 ⁺⁰ ₋₁	32		43	40	10	24	27	756	825	641	102	70	18 14	200	16	620	△ 16	32	
765	800 ⁺⁰ ₋₁	41		53	50	10	30	33	927	997	806	120	83	18	231	20	785	16	32	
910	960 ⁺⁰ ₋₁	48		53	50	10	30	33	1092	1175	966	140	90	18	258	24	945	16	32	
1060	1125 ⁺⁰ ₋₁	51		53	50	10	30	33	1251	1334	1131	150	93	18	271	28	1111	△ 16	32	
1220	1290 ⁺⁰ ₋₁	61		53	50	10	30	33	1410	1492	1296	155	95	18	278	32	1270	△ 16	32	
1370	1440 ⁺⁰ ₋₁	54		53	50	10	30	33	1575	1651	1446	165	96	18	289	36	1422	△ 16	32	
1530	1600 ⁺⁰ ₋₁	57		64	60	12	36	39	1740	1829	1606	175	105	21	313	40	1588	△ 16	32	
1670	1750 ⁺⁰ ₋₁	64		64	60	12	36	39	1892	1994	1756	165	112	21	310	40	1740	△ 16	32	
1840	1915 ⁺⁰ ₋₁	70		64	60	12	36	39	2083	2184	1921	175	122	21	330	44	1892	△ 16	32	

The length 'J' and the thread length are based on the thickness of cast iron Flanges being as follows:

910	-	60
1060	-	67
1220	-	70
1370	-	76
1530	-	80
1670	-	84
1840	-	70

Where M.S. Flanges are used, the Dimension 'J' should be decreased by the difference in thickness between the two types of Flanges.



TAIL PIPE
TO BE SUPPLIED WITH FLANGE ADAPTER
WHEN ORDERED

N.B. Circularity of Machined End to be maintained within 2:1:5 for all pipes.

THIS DRAWING IS AN AMENDED
AND METRIC VERSION OF DRAWING No. 2/13-290

ALL DIMENSIONS ARE METRIC



BRISBANE CITY COUNCIL DEPT. OF WATER SUPPLY & SEWERAGE		STANDARD FLANGE ADAPTERS TO B.C.C. STANDARD DRILLINGS.	
No. DATE A 2017 1.D of Rubber Ring altered 1162 P. dimensions altered. # 12 rubber ring substituted. C 2018 3 symbol added		INITIALS J.E.B. J.E.B.	
DESIGN DRAWN: J.E.B. CHECKED: S.C. A.H. DATUM		REFERENCES 2-9-75 LEVEL BOOK FIELD BOOK	
ENGINEER FOR DESIGN CONSTRUCTION ENGINEER ARCH. & ELECT. ENGINEER		ENGINEER IN CHARGE ASST. ENG. SURVEYED	
Active 21/07/2015		Page 55 of 55 2/13-323	