

Wynnum STP Manufacturers Data Report and O&M

Contract No: C1314-20

Evoqua Ref: 1515-000002-MDR-001

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 1 of 120



ISSUE	DESCRIPTION	ISSUED BY	DATE	APPROVED BY	DATE
0	First Issue	JJ	8/05/2015	EA	15/05/2015

1515-000002-QUU Wynnum STP RO and UF Membrane Replacement

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 2 of 120



TABLE OF CONTENTS

SECTION	SUB-SECTION	DESCRIPTION
		Introduction
		RO - Membrane
Α		Inspection Reports
	A-1	Inspection and Test Plans
В		Certificates
	B-1	Dow - Certificate
		UF - Membrane
С		Inspection Reports
	C-1	Inspection and Test Plans
D		Certificates
	D-1	Membrane - Data Sheets
	D-2	Installation Map
	D-3	Certificates
		Wynnum STP
E		Reports
	E-1	QUU Wynnum Membrane Replacement Report
	E-2	RO Autopsy Report
	E-3	UF Membrane Autopsy Report
F		Miscellaneous
	F-1	Protec Pressure Vessel Drawing and Data Sheet

1515-000002-QUU Wynnum STP RO and UF Membrane Replacement

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 3 of 120



1 Introduction

Wynnum Water Reclamation MF/RO Plant was commissioned and put into operation from early 2008.

Plant produces high purity water from clarified secondary effluent. It does this by combining Memcor's CP system with Reverse Osmosis. The product water from the reclamation plant is sent to the Caltex Oil Refinery to be used as process water.

Secondary effluent is pumped from the waste water treatment plant to two balance tanks. These tanks contain a recirculation pump to prevent sedimentation at the bottom of the tank. The MF feed pump takes water from either of the two balance tanks and directs it into a common feed manifold for the Memcor CP Units. Upstream of the CP Units is a Mono Chloramine dosing point (2-5 mg/L) and two MF Pre-Screens.

The feed pumps are controlled by a VSD which is controlled by a PID control loop to maintain a pressure set-point in the feed manifold. The filtration flow rate in each MF Unit is controlled by a Flow Control Valve (FCV-92x-01) which is controlled by a PID control loop that uses the instantaneous filtration flow rate as a set-point. The filtrate produced from each CP Unit is combined in a common filtrate manifold, is pH adjusted (with Sulphuric Acid) and fed into the RO Feed Tank.

The Wynnum Memcor CP System consists of two MEMCOR® CP Units with 90 L20V membranes and is designed to produce 7.1 MLD of filtrate. Each Unit has a block with 15 banks of 6 modules which is equivalent to 90 modules. Each Unit has all the required valves and ancillary equipment required to perform a Backwash, PDT, Sonic Test, Drain down, Maintenance Clean and CIP.

The backwash waste from each Unit drained into a waste pit, which is then pumped back to the head of the Wynnum Waste Water treatment plant. The CIP waste from each unit is drained into a Neutralisation Pit, where it is neutralised and slowly transferred into the Waste Pit.

It was decided to replace L20V module with L20N and OR membrane to maintain the performance of tertiary water treatment system. Evoqua Water Technologies carried site work and re-commissioned both RO& MF system in March 2015 upon modules being replaced. This document details module factory QA certificate, as well as data report, retired membrane autopsy results and ITPs.

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 4 of 120



RO – Membrane Replacement

A-1 Inspection and Test Plan

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 5 of 120

											_
O	PROJECT: Replacement of MF,RO Membranes & Min Treatment Plants			w.v	END:	Аррпиче					
evoqua	COMPONENT/PROCESS: Membrane Replacement		-			Visual Check Review					
roqua Water Technologies Pty Ltd B.N. \$2 165 060 168	CONTRACT NO:	C1314-20				Surveitance Po	nt	_			-
	EWT REFERENCE:	1515-000002			D-63	tt	3	DOCUMENT (
NOTES: 1. CUENT TO ADVISE HOLD/MITNESS POINT PRIOR TO START: 2. ACCEPTANCE OUTCOME COLUMN TO BE INITIALLED BY IN: 3. RELEVANT EWT AND CLIENT SPECS TO BE READ IN CONJ.	ISPECTOR FOLLOWING COMPLETION OF EACH ACTIVITY.					ATE DI 2/2015 First Revi	SCRIPTION sion	PREPARED	APPROVED EA	Barrison 0	1
io INSPECTION ACTIVITY	INSPECTION PROCEDURE	APLICABLE STANDARD, SPEC, DRAWING	ACCEPTANCE CRITERIA	INSPEC	TION :	_	NSPECT	ON APPROVA	AL / BIGN OFF	REMARKS	1
		SPEC, UNIVERS	CRITERON	End User	TWE	End U	er Clent	EWT	Subcont		
Good Receival								1939	13.0	- 3	
1 Specification	Review Specification and Scope of Works	Contract C1314-20	Scope of works defined		R			115			
2 Place Order for RO and UF Membranes	Order mebranes. Check Order confirmation	Relevant Purchase Order	Orders as per scope of works					145			1
	Check delivery for any visisble faults or damage. Check against order	Relevant Purchase Order	Membranes in good condition and as per order		v			MS			1
4 Receive MF Membranes.	against order. Check temperature log and shock switches if	Relevant Purchase Order	Membranes in good condition and as per order		v			MS			1
UF Membrane Change	Interest			40 30			1			100,000	
1 Collect MF Performance Data	Data to be provided to EWT from SCADA logs and manual logs	per QUU Standard	Data in useable format		R		T	TINT			1
Perform CIP on MF Membranes	Clean UF membranes directly prior to removal	MF Unit Standard Operation	Verification of CIP		s			AC			1
Remove MF Modules (Keep 2 for Autopsy)	Remove and Dispose of UF Membranes	MGS00omm01_05	Modules Removed		8			15			1
5 Replace MF Modules	Replace Modules as per installation guide	MGS00cmm01_05	Modules replaced as per Memcor installation guide		8			X		Design Francisco	1
7 Run MF Check PDT and other critical processes	Recommission UF Units	MF Unit Standard Operation	UF Operating to expected parameters	W	-			ATT		PDT 0.19 &	40
								J			1
RO Membrane Change								3	-		
1 Collect RO Performance Data	Data to be provided to EWT from SCADA logs and manual logs.	per QUU Standard	Outs in useable format		R			14-5			1
2 Perform CIP on RO Membranes	Clean UF membranes directly prior to removal	RO Unit Operation	Verification of CIP	W	1			FA			
A Remove RO Modules	Remove and Dispose of UF Membranes	Filmtec Data Sheet BW 30 400FR	Modules Removed		s			15			
.5 Replace RO Modules	Replace Modules	Filmitec Data Sheet BW 30 400FR	Modules replaced as per Memcor installation guide		s			NS			
7 Restart RO	Restart RO and check pressure dorp and permeate conductivity	RQ Unit Operation	UF Operating to expected parameters	w				17-3			
4 Disposal			1/10					1/4.)			
1 Dispose of all membranes in approved landfill	Disposal off site to be by liscenced contractor	79 1	1 1 -110	1	s			A.5			1
2. Receive goods disposal confirmation	Receive document confirming propoer disposal	72	Cocurant Received		s					NA	1

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 6 of 120



B-1

RO – Membrane Replacement DOW Certificates

1515-000002-QUU Wynnum STP RO and UF Membrane Replacement

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 7 of 120



Telephone: 952-897-4200

Fax: 952-838-3999 (Administration) Fax: 952-835-4996 (Customer Service)

FILMTEC is a registered brand of the Dow Corporation

CERTIFICATE OF CONFORMANCE

CUSTOMER : DOW CHEMICAL (AUSTRALIA) PTY

CUSTOMER PO :

DELIVERY # : 803609861

SAP ORDER # : 4000855437

TOTAL SHIPPED QTY : 336

MODEL : BW30FR-400

GMID : 202684

SHIP DATE : 12/9/2014 10:59:09 PM

COUNTRY OF ORIGIN : USA

The products listed below meet the specifications requirements:

Davil Lysla

Released By:

NORMALIZED TEST CONDITIONS:

FEED COMPOSITION : NaCl

FEED CONCENTRATION (ppm) : 2000

FEED CONDUCTIVITY (umhos) : 3865

TEMPERATURE (C) : 25

APPLIED PRESSURE (PSI) : 225

SPECIFICATIONS:

FLOW LIMITS (GPD) MIN : 9,775.0

MAX : 14,375.0

| Serial Number: |
|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|
| F7885988 | F9468883 | F9468885 | F9468896 | F9468898 | F9468967 | F9468976 | F9468985 | F9468987 |
| F9469053 | F9469064 | F9469076 | F9469078 | F9469145 | F9469167 | F9469174 | F9469177 | F9469220 |
| F9469222 | F9469223 | F9469266 | F9515125 | F9515131 | F9515136 | F9515138 | F9515142 | F9515143 |
| F9515145 | F9515146 | F9515147 | F9515148 | F9515149 | F9515150 | F9515151 | F9515152 | F9515153 |
| F9515155 | F9515157 | F9515159 | F9515160 | F9515161 | F9515162 | F9515163 | F9515164 | F9515165 |
| F9515166 | F9515167 | F9515168 | F9515169 | F9515170 | F9515171 | F9515173 | F9515174 | F9515177 |
| F9515178 | F9515179 | F9515182 | F9515193 | F9515194 | F9515195 | F9515197 | F9515198 | F9516086 |



Telephone: 952-897-4200

Fax: 952-838-3999 (Administration) Fax: 952-835-4996 (Customer Service)

FILMTEC is a registered brand of the Dow Corporation

CERTIFICATE OF CONFORMANCE

CUSTOMER : DOW CHEMICAL (AUSTRALIA) PTY

CUSTOMER PO :

DELIVERY # : 803609861

SAP ORDER # : 4000855437

TOTAL SHIPPED QTY : 336

MODEL: BW30FR-400

GMID : 202684

SHIP DATE : 12/9/2014 10:59:09 PM

COUNTRY OF ORIGIN : USA

The products listed below meet the specifications requirements:

Danil Lysla

Released By:

NORMALIZED TEST CONDITIONS:

FEED COMPOSITION : NaCl

FEED CONCENTRATION (ppm) : 2000

FEED CONDUCTIVITY (umhos) : 3865

TEMPERATURE (C) : 25

APPLIED PRESSURE (PSI) : 225

SPECIFICATIONS:

FLOW LIMITS (GPD) MIN : 9,775.0

MAX : 14,375.0

| Serial Number: |
|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|
| F9516141 | F9516150 | F9516152 | F9516315 | F9516362 | F9516452 | F9516464 | F9516472 | F9516508 |
| F9516514 | F9516522 | F9516528 | F9516534 | F9516538 | F9516541 | F9516542 | F9516603 | F9516664 |
| F9516673 | F9516678 | F9516679 | F9516689 | F9516744 | F9516752 | F9516755 | F9516757 | F9516758 |
| F9516766 | F9516851 | F9516855 | F9516865 | F9516869 | F9516904 | F9516907 | F9516939 | F9516956 |
| F9517003 | F9517028 | F9517043 | F9517046 | F9517089 | F9517112 | F9517120 | F9517123 | F9517198 |
| F9517221 | F9517223 | F9517225 | F9517314 | F9517339 | F9517352 | F9517355 | F9517363 | F9517420 |
| F9517422 | F9517428 | F9517505 | F9521942 | F9521947 | F9521949 | F9521968 | F9522200 | F9522204 |
| F9522229 | F9522241 | F9522289 | F9522291 | F9522326 | F9522396 | F9522488 | F9522490 | F9522501 |



Telephone: 952-897-4200

Fax: 952-838-3999 (Administration) Fax: 952-835-4996 (Customer Service)

FILMTEC is a registered brand of the Dow Corporation

CERTIFICATE OF CONFORMANCE

CUSTOMER : DOW CHEMICAL (AUSTRALIA) PTY

CUSTOMER PO :

DELIVERY # : 803609861

SAP ORDER # : 4000855437

TOTAL SHIPPED QTY : 336

MODEL : BW30FR-400

GMID : 202684

SHIP DATE : 12/9/2014 10:59:09 PM

COUNTRY OF ORIGIN : USA

The products listed below meet the specifications requirements:

Davil Lysla

Released By:

NORMALIZED TEST CONDITIONS:

FEED COMPOSITION : NaCl

FEED CONCENTRATION (ppm) : 2000

FEED CONDUCTIVITY (umhos) : 3865

TEMPERATURE (C) : 25

APPLIED PRESSURE (PSI) : 225

SPECIFICATIONS:

FLOW LIMITS (GPD) MIN : 9,775.0

MAX : 14,375.0

| Serial Number: |
|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|
| F9522503 | F9522688 | F9522691 | F9522695 | F9522709 | F9522796 | F9522798 | F9522800 | F9522802 |
| F9523042 | F9523056 | F9523061 | F9523064 | F9523140 | F9523147 | F9523150 | F9523151 | F9523235 |
| F9523237 | F9523239 | F9523932 | F9524107 | F9524282 | F9524286 | F9524296 | F9524305 | F9524736 |
| F9524741 | F9524758 | F9524772 | F9524817 | F9524821 | F9524822 | F9524845 | F9524929 | F9525062 |
| F9525074 | F9607101 | F9607102 | F9607106 | F9607109 | F9607186 | F9607192 | F9607194 | F9607195 |
| F9607271 | F9607275 | F9607276 | F9607283 | F9607363 | F9607364 | F9607365 | F9607374 | F9607447 |
| F9607448 | F9607449 | F9607457 | F9607546 | F9607547 | F9607548 | F9607549 | F9607630 | F9607633 |
| F9607634 | F9607635 | F9607721 | F9607722 | F9607723 | F9607724 | F9637138 | F9637147 | F9637158 |



Telephone: 952-897-4200

Fax: 952-838-3999 (Administration) Fax: 952-835-4996 (Customer Service)

FILMTEC is a registered brand of the Dow Corporation

CERTIFICATE OF CONFORMANCE

CUSTOMER : DOW CHEMICAL (AUSTRALIA) PTY

CUSTOMER PO :

DELIVERY # : 803609861

SAP ORDER # : 4000855437

TOTAL SHIPPED QTY : 336

MODEL : BW30FR-400

GMID : 202684

SHIP DATE : 12/9/2014 10:59:09 PM

COUNTRY OF ORIGIN : USA

The products listed below meet the specifications requirements:

Davil Lysla

Released By:

NORMALIZED TEST CONDITIONS:

FEED COMPOSITION : NaCl

FEED CONCENTRATION (ppm) : 2000

FEED CONDUCTIVITY (umhos) : 3865

TEMPERATURE (C) : 25

APPLIED PRESSURE (PSI) : 225

SPECIFICATIONS:

FLOW LIMITS (GPD) MIN : 9,775.0

MAX : 14,375.0

| Serial Number: |
|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|
| F9637160 | F9637195 | F9637218 | F9637222 | F9637226 | F9637282 | F9637559 | F9637569 | F9637573 |
| F9637578 | F9637642 | F9637657 | F9637658 | F9637664 | F9637707 | F9637735 | F9637736 | F9637748 |
| F9637749 | F9637822 | F9637825 | F9637852 | F9637855 | F9637920 | F9637924 | F9637930 | F9637941 |
| F9637992 | F9638022 | F9638023 | F9638024 | F9638094 | F9638098 | F9638113 | F9638114 | F9638189 |
| F9638193 | F9638197 | F9638199 | F9638268 | F9638286 | F9638288 | F9638291 | F9638369 | F9638370 |
| F9638372 | F9638374 | F9638468 | F9638469 | F9638479 | F9638522 | F9638552 | F9638567 | F9638574 |
| F9638618 | F9638629 | F9638640 | F9638643 | F9638646 | F9638652 | F9638681 | F9638733 | F9638738 |
| F9638740 | F9638744 | F9638822 | F9638823 | F9638825 | F9638829 | F9638874 | F9638878 | F9638908 |



Telephone: 952-897-4200

Fax: 952-838-3999 (Administration) Fax: 952-835-4996 (Customer Service)

FILMTEC is a registered brand of the Dow Corporation

CERTIFICATE OF CONFORMANCE

CUSTOMER : DOW CHEMICAL (AUSTRALIA) PTY

CUSTOMER PO :

DELIVERY # : 803609861

SAP ORDER # : 4000855437

TOTAL SHIPPED QTY : 336

MODEL: BW30FR-400

GMID : 202684

SHIP DATE : 12/9/2014 10:59:09 PM

COUNTRY OF ORIGIN : USA

The products listed below meet the specifications requirements:

Davil Lysla

Released By:

NORMALIZED TEST CONDITIONS:

FEED COMPOSITION : NaCl

FEED CONCENTRATION (ppm) : 2000

FEED CONDUCTIVITY (umhos) : 3865

TEMPERATURE (C) : 25

APPLIED PRESSURE (PSI) : 225

SPECIFICATIONS:

FLOW LIMITS (GPD) MIN : 9,775.0

MAX : 14.375.0

| Serial Number: |
|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|
| F9638941 | F9638946 | F9638947 | F9638949 | F9638951 | F9638970 | F9638974 | F9638976 | F9639032 |
| F9639082 | F9639109 | F9639115 | F9639117 | F9639174 | F9639179 | F9639201 | F9639203 | F9639213 |
| F9639216 | F9639281 | F9639286 | F9639347 | F9639349 | F9639375 | F9639376 | F9702102 | F9702103 |
| F9702105 | F9702106 | F9702186 | F9702189 | F9702200 | F9702201 | F9702272 | F9702276 | F9702278 |
| F9702288 | F9764326 | F9764340 | F9764342 | F9764344 | F9764420 | F9764421 | F9764422 | F9764426 |
| F9764510 | F9764520 | F9764521 | F9764523 | F9764695 | F9764699 | F9764701 | F9764703 | F9764757 |
| F9764771 | F9764798 | F9764803 | | | | | | |



UF – Membrane Replacement

C-1 Inspection and Test Plan

1515-000002-QUU Wynnum STP RO and UF Membrane Replacement

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 13 of 120

											_
O I	PROJECT: Replacement of MF,RO Membranes & Min Treatment Plants			w.v	END:	Аррпиче					
evoqua	COMPONENT/PROCESS: Membrane Replacement		-			Visual Check Review					
roqua Water Technologies Pty Ltd B.N. \$2 165 060 168	CONTRACT NO:	C1314-20				Surveitance Po	nt	_			-
	EWT REFERENCE:	1515-000002			D-63	tt	3	DOCUMENT (
NOTES: 1. CUENT TO ADVISE HOLD/MITNESS POINT PRIOR TO START: 2. ACCEPTANCE OUTCOME COLUMN TO BE INITIALLED BY IN: 3. RELEVANT EWT AND CLIENT SPECS TO BE READ IN CONJ.	ISPECTOR FOLLOWING COMPLETION OF EACH ACTIVITY.					ATE DI 2/2015 First Revi	SCRIPTION sion	PREPARED	APPROVED EA	Barrison 0	1
io INSPECTION ACTIVITY	INSPECTION PROCEDURE	APLICABLE STANDARD, SPEC, DRAWING	ACCEPTANCE CRITERIA	INSPEC	TION :	_	NSPECT	ON APPROVA	AL / BIGN OFF	REMARKS	1
		SPEC, UNIVERS	CRITERON	End User	TWE	End U	er Clent	EWT	Subcont		
Good Receival								1939	13.0	- 3	
1 Specification	Review Specification and Scope of Works	Contract C1314-20	Scope of works defined		R			115			
2 Place Order for RO and UF Membranes	Order mebranes. Check Order confirmation	Relevant Purchase Order	Orders as per scope of works					145			1
	Check delivery for any visisble faults or damage. Check against order	Relevant Purchase Order	Membranes in good condition and as per order		v			MS			1
4 Receive MF Membranes.	against order. Check temperature log and shock switches if	Relevant Purchase Order	Membranes in good condition and as per order		v			MS			1
UF Membrane Change	Interest			40 30			1			100,000	
1 Collect MF Performance Data	Data to be provided to EWT from SCADA logs and manual logs	per QUU Standard	Data in useable format		R		T	TINT			1
Perform CIP on MF Membranes	Clean UF membranes directly prior to removal	MF Unit Standard Operation	Verification of CIP		s			AC			1
Remove MF Modules (Keep 2 for Autopsy)	Remove and Dispose of UF Membranes	MGS00omm01_05	Modules Removed		8			15			1
5 Replace MF Modules	Replace Modules as per installation guide	MGS00cmm01_05	Modules replaced as per Memcor installation guide		8			X			1
7 Run MF Check PDT and other critical processes	Recommission UF Units	MF Unit Standard Operation	UF Operating to expected parameters	W	-			ATT		PDT 0.19 &	40
								J			1
RO Membrane Change								3	-		
1 Collect RO Performance Data	Data to be provided to EWT from SCADA logs and manual logs.	per QUU Standard	Outs in useable format		R			14-5			1
2 Perform CIP on RO Membranes	Clean UF membranes directly prior to removal	RO Unit Operation	Verification of CIP	W				FA			
A Remove RO Modules	Remove and Dispose of UF Membranes	Filmtec Data Sheet BW 30 400FR	Modules Removed		s			15			
.5 Replace RO Modules	Replace Modules	Filmitec Data Sheet BW 30 400FR	Modules replaced as per Memcor installation guide		s			NS			
7 Restart RO	Restart RO and check pressure dorp and permeate conductivity	RQ Unit Operation	UF Operating to expected parameters	w				17-3			
4 Disposal			1/10					1/4.)			
1 Dispose of all membranes in approved landfill	Disposal off site to be by liscenced contractor	2 2	1 1 -110	1	s			A.5			1
2. Receive goods disposal confirmation	Receive document confirming propoer disposal	72	Cocurant Received		s					NA	1

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 14 of 120



UF – Membrane Replacement

D-1 Membrane Data Sheet

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 15 of 120






MEMCOR® L20N MEMBRANE FILTRATION MODULE SPECIFICATION

L20N MODULE SPECIFICATIONS

Parameter	Details
Module Operating Process	Pressurized Ultrafiltration
Typical Applications	General Applications
Membrane Type	Hollow Fiber
Filtration Flow Direction	Outside to Inside
Backwash Type	Air Scour with Liquid Backwash
Membrane Material	PVDF (Polyvinylidene Fluoride)
Other Wetted Module Components	Polyurethane, Polyethylene, Polyamide, EPDM
Other Wetted Module Components Nominal Membrane Pore Size	, , , , ,
	EPDM
Nominal Membrane Pore Size	EPDM 0.04 μm
Nominal Membrane Pore Size Nominal Membrane Area	EPDM 0.04 μm 34.8 m² / 375 ft²
Nominal Membrane Pore Size Nominal Membrane Area Nominal Module Length (Overall)	EPDM 0.04 μm 34.8 m² / 375 ft² 1800 mm / 70.9 in



Q-Pulse Id: TMS1440

Active: 12/10/2015

MEMCOR is an Evoqua brand

MC-L20N-MQ-DUIE- ALI-SPEC 20714

L20N MODULE OPERATING SPECIFICATIONS

Details
$>$ 0 to 35 $^{\circ}$ C $/>$ 32 to 95 $^{\circ}$ F (Must not be exposed to freezing conditions)
Preferred range 5 to 25 °C / 41 to 77 °F Allowable range > 0 to 35 °C / > 32 to 95 °F (shipment/storage in a temperature controlled container (or reefer) at 20 °C / 68 °F recommended). Modules must not be exposed to freezing conditions and must remain moist at all times.
6.0 – 9.0 pH ^{Note i}
2.0 – 10.0 pH typical ^{Note ii}
140 kPa / 20 psi ^{Note iii}
\pm 150 kPa / \pm 22 psi @ \leq 30 °C / 86 °F \pm 120 kPa / \pm 17 psi @ > 30 °C / 86 °F
500 kPa / 75 psi
50 – 200 mg/L @ 25 °C / 50 – 200 ppm @ 77 °F ^{Note iv}
1000 mg/L @ 25 °C / 1000 ppm @ 77 °F Note iv
500,000 mg.h/L @ 25 °C / 500,000 ppm.h @ 77 °F Note iv
< 1 mg/L average, < 5 mg/L maximum, pH > 6.5 @ 25 °C < 1 ppm average, < 5 ppm maximum, pH > 6.5 @ 77 °F 100,000 mg.h/L @ 25 °C / 100,000 ppm.h @ 77 °F Note iv
< 2.5 mg/L average, < 5 mg/L maximum, pH > 6.5 @ 25 $^{\circ}$ C < 2.5 ppm average, < 5 ppm maximum, pH > 6.5 @ 77 $^{\circ}$ F 150,000 mg.h/L @ 25 $^{\circ}$ C / 150,000 ppm.h @ 77 $^{\circ}$ F $^{\circ}$ F Note iv

Notes:

- i. Exposure to chlorine or chloramines is not recommended in feeds below 6.5 pH.
- ii. Occasional brief exposure during chlorine cleans to pH 10.5 is acceptable.
- iii. Maximum recommended filtration TMP for a particular application is usually feed dependent. The actual recommended value may vary from the value shown.
- iv. Please consult Evoqua Water Technologies for additional guidance on exposure limits and for operation at different temperatures.

The information provided in this literature contains merely general descriptions or characteristics of performance which in actual case of use do not always apply as described or which may change as a result of further development of the products.

Evoqua Water Technologies Membrane Systems Pty Ltd

15 Blackman Crescent South Windsor NSW 2756 Australia An obligation to provide the respective characteristics shall only exist if expressly agreed in the terms of the contract. Additional operating information, storage instructions and warranty terms may apply. Please contact Evoqua Water Technologies for more information.

Tel: +61 (0)2 4577-6800 Fax: +61 (0)2 4577-0078

Email: memcorasia.au@evoqua.com Internet: http://www.evoqua.com



UF – Membrane Replacement

D-2 Installation Map

1515-000002-QUU Wynnum STP RO and UF Membrane Replacement

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 18 of 120

Module Mapping

Version 1.0.13

(This sheet is part of the design of this interface, please do not modify or delete it)

Wynnum WRP (SiteID:201200)

6x15 6x15

Operations

Select a Module Operation	-
Select an Unit Operation	$\overline{}$
Select a Find or Show Operation	-

Block ID: Unit1_32024

Columns: 6 Rows: 15

	A	В	С	D	E	F
1	WSF1891E	WSF1913G	WSF1833E	WRF1D543	WSF11213	WRF19841
2	WNEBE32H	WSF18440	WRF1874A	WRF1B11C	WMF1A62A	WRF1D424
3	WMF1854R	WRF1A61-	WSF1843Z	WSF1113Y	WRF1B13R	WSF1743S
4	WRF18835	WSF18923	WRF1831X	WSF1B124	WSF1A118	WRF1A12V
5	WSF1882J	WSF1881U	WMF18531	WRF1133-	WRF1982N	WSF1823U
6	WRF1881R	WPECV834	WSF19145	WMF1951U	WRF1764J	WSF1982Q
7	WRF1843W	WRF1832M	WSF19111	WSF1B22P	WRF1A71K	WRF1D41F
8	WRF1861M	WRF18340	WRF1833B	WPECVA4Z	WRF1B121	WSF1B243
9	WRF1A62P	WSF1912R	WRF19142	WMF1A63-	WRF1A73Z	WSF1B11F
10	WSF1744H	WSF1884Y	WRF18426	WRF1D52P	WSF1B14J	WMF1931P
11	WRF1B23B	WMF1843H	WRF1873L	WRF1D43U	WSF1B23E	WSF1741D
12	WPECV82F	WRF1872W	WSF18838	WMF17235	WRF1D51-	WRF11449
13	WRF1A729	WRF1D44J	WRF1B22M	WMF1734F	WMF1952J	WRF1981Y
14	WRF1A74O	WSF17422	WSF1B21-	WRF1B14G	WMF1811D	WRF1823R
15	WSF1A12Y	WRF1D53E	WRF1B21X	WMF1722G	WMF1954Y	WRF1A115

Module Mapping

Version 1.0.13

(This sheet is part of the design of this interface, please do not modify or delete it)

Wynnum WRP (SiteID:201200)

6x15 6x15

Operations

Select a Module Operation	~
Select an Unit Operation	•
Select a Find or Show Operation	-

Block ID: Unit2_32025

Columns: 6 Rows: 15

	A	В	С	D	E	F
1	WSE4724A	WPE46320	WNEAJ41K	WRF16242	WMF1A510	WSF1A53X
2	WMEAJ12H	WNEAJ43Z	WSE47216	WRF17539	WRF1A42K	WRF1A44Z
3	WREAH631	WPE4633Q	WNEAJ440	WRF1611E	WRF1A439	WRF16123
4	WSF1824J	WRF1821C	WSE4722W	WSF1922B	WSF1752N	WRF1763U
5	WSF19810	WSF1A14C	WSE4723L	WRF1761F	WSF1761I	WRF18716
6	WSF1A13N	WRF1983C	WPE4634F	WSF17627	WMF1733Q	WSF1924Q
7	WSF19844	WRF1A13K	WRF1A41V	WRF17624	WSF1A527	WRF1862B
8	WSF18224	WMF1A52Q	WMF1721R	WSF1A817	WRF1882G	WPECV84U
9	WRF18221	WSF1A51I	WSF1763X	WRF19228	WSF1A731	WSF1753C
10	WRF1743P	WRF1752K	WRF1432V	WSF1894I	WSF1841K	WMF1852C
11	WRF1824G	WSF1764M	WMF1731B	WMF1A544	WPECVA1V	WMF1851N
12	WSF1A84B	WRF1741A	WSF1A82X	WRF1924N	WSF1874D	WRF1A63E
13	WRF1744E	WSF1751Y	WSF1A71N	WSF1893T	WPECVA2K	WRF1A643
14	WSF1A72C	WMF1A53F	WSF1A54M	WSF18429	WRF1884V	WSF1872Z
15	WMF18446	WSF1A74R	WSF19230	WRF1864Q	WPECV81Q	WRF1844L




UF – Membrane Replacement

D-3 Certificates

1515-000002-QUU Wynnum STP RO and UF Membrane Replacement

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 21 of 120


MFI







Form QA 104 Issue 11

Size and Length



Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 22 of 120






Australia 2756 Australia 2756 Tel: 61 (02) 4577 0001 Fax: 61 (02) 4577 0002 Yes Batch No. 1467436 Grease Only Chirayu Mehta	Memcor Products A,B.N 36 166 784 694 15 Blackman Cresent South Windsor NSW Australia 2756 Tel: 61 (02) 4577 0001 Fax: 61 (02) 4577 0002 Type Batch No L20N 1467436 one Grease Only y Chirayu Mehta	### Serial No. Part No. L20N 1467436 Pass Fail Tested By Chirayu Mehta	SUA utficate oride Membra serial No. 856279 Rings with Pass. Pass.	Module Test Certificate Polyvinylidenefluoride Membrane Module ID Module ID Serial No. WRF1861M 856279 1 Lubricate O-Rings with Sup Pass Fa Integrity Test (DAF)	EWT Membrane Systems Pty Ltd Memcor Products A.B.N 36 166 784 694 15 Blackman Cresent South Windsor NSW Australia 2756 Tel: 61 (02) 4577 0001 Fax: 61 (02) 4577 0002 Type Batch No. Type Batch No. L20N 1467436 ed By Chirayu Mehta	EWT Membrane Systems P Memcor Products A.B.N 36 166 784 69 15 Blackman Cresent South Windsor NSW Australia 2756 Tel: 61 (02) 4577 0001 Fax: 61 (02) 4577 0001 Fax: 61 (02) 4577 0001 Silicone Grease Only Silicone Grease Only
12	D F1R4	Crate ID		Flow Test Visual Check	2	Crate ID F1R4
ru Mehta 2015				Integrity Test (D	Mehta 015	
se Only	one Greas	Supplied Silic	Rings with	Lubricate O-	Only	cone Grease
Batch No. 1467436	Type L20N	Part No. 120408	Serial No. 856279	Module ID WRF1861M	Batch No. 1467436	Type L20N
(2) 4577 0001 (2) 4577 0002	Tel: 61 (0. Fax: 61 (0				4577 0001	Tel: 61 (02) Fax: 61 (02)
findsor NSW alia 2756	15 Blackr South Wi Austr	ane	oride Membr	Polyvinylideneflu	n Cresent Isor NSW	15 Blackma South Wind
Trosont	A.B.N 36		tificate	Modulo Test Cer	66 784 694	A B N 36 1
A.B.N 36 166 784 694	Memco		2UA	9009	systems Pty Ltd	VT Membrane S

Integrity Test (DAF)


Size and Length Visual Check Flow Test

EWT Membrane Systems Pty Ltd Memcor Products A.B.N 36 166 784 694 15 Blackman Cresent South Windsor NSW Australia 2756 Tel: 61 (02) 4577 0001 Fax: 61 (02) 4577 0002 Type Batch No. L20N 1467436 Ilicone Grease Only ad By Marvin Romero Date 28/01/2015 ste ID F1R4 Form QA 104 Issue 11	EWT Membrane Systems Pty Ltd Memcor Products A.B.N 36 166 784 694 15 Blackman Cresent South Windsor NSW Australia 2756 Tel: 61 (02) 4577 0002 Fax: 61 (02) 4577 0002 Chiravu Mehta
Part No. 20408 aiii Teste	Part No. 120408
Module Test Certificate Module Test Certificate Module Test Certificate Polyvinylidenefluoride Membrane Module ID Serial No. Part No. Type Batch Module ID Serial No. Part No. L20N 1467 vsr. 61 (02) 4577 00 Fax: 6	Module Test Certificate Module Test Certificate Module Test Certificate Module ID Serial No. Part No. L20N 1467 Lubricate O-Rings with Supplied Silicone Grease Only

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 23 of 120




EWT Membrane Systems Pty Ltd Memcor Products	A.B.N 36 166 784 694	15 Blackman Cresent South Windsor NSW	Australia 2756 Tel: 61 (02) 4577 0001 Fax: 61 (02) 4577 0002	Batch No. 1467436	se Only	Chirayu Mehta	2015		Form QA 104 Issue 11
T Membra Mem	A.B.N	South South	Aus Tel: 61 Fax: 61	Type L20N	ne Grea	Chira	27/01/2015	F1R4	ш
AREW		9		Part No. 120408	Lubricate O-Rings with Supplied Silicone Grease Only	Fail Tested By	Date	Crate ID	1
SUA ocodes	tificate	oride Membrar		Serial No. 856193	Rings with Su	Pass	3	35]
eVOQUA water technologies	Module Lest Certificate	Polyvinylidenefluoride Membrane		Module ID WPECV82F	Lubricate O-F	Integrity Test (DAF)	Flow Test	Visual Check Size and Length	




Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 24 of 120












Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 25 of 120

MK








Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 26 of 120





EWT Membrane Systems Pty Ltd Memcor Products A.B.N 36 166 784 694	15 Blackman Cresent South Windsor NSW Australia 2756 Tel: 61 (02) 4577 0001 Fax: 61 (02) 4577 0002	Batch No. 1467436	Marvin Romero 28/01/2015 F1R4
T Membra Memc A.B.N 3	15 Black South W Aust Tel: 61 (0	Type L20N	Marvin Rol 28/01/2015 F1R4
Bs ew	ane	Part No. 120408	Lubricate O-Rings with Supplied Silicone Grease Only Pass Fail tegrity Test (DAF)
QUA vologies rtificate	Joride Membr	Serial No. 856259	Rings with S
WATER TECHNOLOGIES Module Test Certificate	Polyvinylidenefluoride Membrane	Module ID WSF1912R	Lubricate O-Ring Integrity Test (DAF) Flow Test Visual Check Size and Length




Q-Pulse Id: TMS1440 Active: 12/10/2015 Form QA 104 Issue 11

Crate ID

Size and Length

Visual Check

Flow Test



1467436

Iliowne Grease Only Chirayu Meht


Chirayu Mehta

Batch No.

EWT Membrane Systems Pty Ltd

15 Blackman Cresent South Windsor NSW Australia 2756 Tel: 61 (02) 4577 0001 Fax: 61 (02) 4577 0002

Memcor Products



1467436

Chirayu Mehta

Page 2

27/01/2015

F1R4

ilicone Grease Only

Batch No.

Type L20N

Form QA 104 Issue 11


EWT Membrane Systems Pty Ltd


15 Blackman Cresent South Windsor NSW Australia 2756 Tel: 61 (02) 4577 0001 Fax: 61 (02) 4577 0002

Memcor Products

Form QA 104 Issue 11








Form QA 104 Issue 11

F1R4


Crate ID

Size and Length

Visual Check



Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 29 of 120




15 Blackman Cresent South Windsor NSW


Australia 2756

Polyvinylidenefluoride Membrane

Module Test Certificate


evogua WATER TECHNOLOGIES







Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 30 of 120

TIL







Q-Pulse Id: TMS1440

Active: 12/10/2015

27/01/2015

Crate ID


Size and Length

Visual Check


Flow Test

Tested By

Integrity Test (DAF)









Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 32 of 120







Form QA 104 Issue 11

Crate ID

Size and Length


Visual Check



Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 33 of 120


Form QA 104 Issue 11


ME



1467438 Batch No.

Australia 2756





Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 34 of 120

Integrity Test (DAF)

WSF1B124

Module ID

Size and Length

Visual Check

Flow Test

EWT Membrane Systems Pty Ltd

Memcor Products A.B.N 36 166 784 694

15 Blackman Cresent


South Windsor NSW

olyvinylidenefluoride Membrane

lodule Test Certificate WATER TECHNOLOGIES

evogua

Australia 2756



EWT Membrane Systems Pty Ltd Memcor Products	A.B.N 36 166 784 694	15 Blackman Cresent South Windsor NSW	Australia 2756 Tel: 61 (02) 4577 0001 Fax: 61 (02) 4577 0002	No. Type Batch No. 1467438	Lubricate O-Rings with Supplied Silicone Grease Only	Tested By Robert Finch	Date 02/02/2015	Crate ID F1S3	Form OA 104 feeting 44
E	2 / 2 ege	e Membrane		Serial No. Part No. 857369 120408	s with Supplied	Pass Fail		P	
eVOQUA water technologies	Module Test Certificate	Polyvinylidenefluoride Membrane		Module ID S	Lubricate O-Ring	Integrity Test (DAF)	Flow Test	Visual Check	Size and Length

1467438

Lype L20N

Part No. 120408

Serial No.

857397

WRF1D43U

Module ID

Lubricate O-Rings with Supplied Silicone Grease Only

Pass

ntegrity Test (DAF)

Size and Length

Visual Check

Flow Test

Robert Finch

Tested By Date Crate ID

02/02/2015

F1S3

Batch No.

Tel: 61 (02) 4577 0001 Fax: 61 (02) 4577 0002

Form QA 104 Issu



Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 35 of 120

EWT Membrane Systems Pty Ltd

Memcor Products

15 Blackman Cresent South Windsor NSW


olyvinylidenefluoride Membrane

Jodule Test Certificate

EVOQUA



Q-Pulse Id: TMS1440



Polyvinylidenefluoride Membrane South Windsor NSW Australia 2756 Module ID Serial No. Type Batch No. WRF1B14G 857296 120408 L20N 1467438 Lubricate O-Rings with Supplied Silicone Grease Only Pass Fail Tested By Nathan Refalo Integrity Test (DAF) Flow Test Check Crate ID F1S3	Memcor Products A.B.N 36 166 784 694
Serial No. Part No. Type 857296 120408 L20N O-Rings with Supplied Silicone Grease C Pass Fail Tested By Nathan R (DAF) Date 02/02/201	77 0002
Pass Fail Tested By	Batch No. 467438
Pass Fail Tested By	nly
Crate ID	falo
Size and Length	

Batch No. 1467438

Type L20N

Part No. 120408

Serial No. 857243

WMF1722G

Module ID

Tested By Nathan Refalo

02/02/2015

Date Crate ID

F1S3

Lubricate O-Rings with Supplied Silicone Grease Only

Pass

Integrity Test (DAF)

Size and Length


Visual Check


Flow Test


Tel: 61 (02) 4577 0001 Fax: 61 (02) 4577 0002


Australia 2756

Form QA 104 Issue 11









Q-Pulse Id: TMS1440 Active: 12/10/2015 Form QA 104 Issue 11

F1S3


Crate ID

Size and Length

Visual Check

Flow Test





EWT Membrane Systems Pty Ltd Memcor Products A.B.N 36 166 784 694	15 Blackman Cresent South Windsor NSW Australia 2756 Tel: 61 (02) 4577 0001 Fax: 61 (02) 4577 0002	Type Batch No. L20N 1467438	one Grease Only	Tested By Robert Finch	02/02/2015	Crate ID F1S3	Form QA 104 Issue 11
(78 =	rane	Part No. 120408	Supplied Silico		Oate	Crate D	
WATER TECHNOLOGIES Module Test Certificate	Polyvinylidenefluoride Membrane	Module ID Serial No. WRF1B121 857305	Lubricate O-Rings with Supplied Silicone Grease Only	est (DAF)	Flow Test	Size and Length	
ibrane Systems Pty Ltd emcor Products I.N 36 166 784 694	tth Windsor NSW Australia 2756 61 (02) 4577 0001 61 (02) 4577 0002	N 1467438	ease Only	2/2015	3	Form QA 104 Issue 11	

02/02/2015

Date


F1S3

Crate ID

Size and Length


Visual Check


Flow Test



Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 38 of 120

ST.





Form QA 104 Issue 11


F1S3

Crate ID

Size and Length


Visual Check


Flow Test



Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 39 of 120

ZI







Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 40 of 120

EWT Membrane Systems Pty

15 Blackman Cresent South Windsor NSW


Polyvinylidenefluoride Membrane

Module Test Certificate

evogua WATER TECHNOLOGIES Australia 2756

Memcor Products

ME



WATER TECHNOLOGIES Module Test Certificate Polyvinylidenefluoride Membrane Module ID Serial No. Pa WRF1A12V 856495 120 Lubricate O-Rings with Suppli Pass Fail Integrity Test (DAF) Flow Test Visual Check Size and Length	EWT Membrane Systems Pty Ltd Memcor Products A.B.N 36 166 784 694	15 Blackman Cresent South Windsor NSW Australia 2756 Tel: 61 (02) 4577 0001 Fax: 61 (02) 4577 0002	Part No. Type Batch No. 120408 L20N 1467438	Lubricate O-Rings with Supplied Silicone Grease Only	Tested By Chirayu Mehta	Date 28/01/2015	Crate ID F1S3	Form QA 104 Issue 11
	WATER TECHNOLOGIES Module Test Certificate	Polyvinylidenefluoride Membrane		ings with Suppli	Pass		20	

1467438

Chirayu Mehta

28/01/2015

Date Tested By

Crate ID

Size and Length

Visual Check

Flow Test

Lubricate O-Rings with Supplied Silicone Grease Only

Fail

Pass

Integrity Test (DAF)

Form QA 10

Batch No.

Type L20N

120408

Serial No.

856476

WSF1823U


Module ID

Tel: 61 (02) 4577 0001 Fax: 61 (02) 4577 0002




Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 41 of 120

MEI









Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 42 of 120

ME










Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 43 of 120

ME





MFY





Form QA 104 Issue 11


EB44

Crate ID

Size and Length Visual Check

Flow Test

Date



Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 45 of 120

EWT Membrane Systems Pty Ltd

Memcor Products A.B.N 36 166 784 694

WATER TECHNOLOGIES evoqua

15 Blackman Cresent South Windsor NSW Batch No. 1467437

Type L20N

120408

Serial No. 856463

WSF18224

Module ID

Chirayu Mehta

28/01/2015

Date Tested By

Crate ID

Size and Length

Visual Check

Flow Test

Lubricate O-Rings with Supplied Silicone Grease Only

Pass

Integrity Test (DAF)

Tel: 61 (02) 4577 0001 Fax: 61 (02) 4577 0002


Australia 2756

MFZ

EWT Membrane Systems Pty Ltd

15 Blackman Cresent South Windsor NSW

Memcor Products



1467437

Type L20N

Part No. 120408

Serial No. 856484

WSF19810

Module ID

Chirayu Mehta

Tested By Date

Integrity Test (DAF)

28/01/2015

F1S1

Crate ID

Size and Length

Visual Check

Flow Test


Lubricate O-Rings with Supplied Silicone Grease Only

Fail

Batch No.

Tel: 61 (02) 4577 0001 Fax: 61 (02) 4577 0002

Australia 2756





Polyvinylidenefluoride Membrane


Module Test Certificate

evogua


Form QA 104 Issue 11

Form QA 104 Issue 11

MFZ





EWT Membrane Systems Pty Ltd	Memcor Products	A.B.N 36 166 784 694	15 Blackman Cresent South Windsor NSW	Australia 2756 Tel: 61 (02) 4577 0001 Fax: 61 (02) 4577 0002	Type Batch No. L20N 1467437	ase (Tested By Marvin Romero	Date 28/01/2015	Crate ID F1S1	
	<	T			Part No. 120408	Supplied Si	Fail Teste		Crat	
AUA	OLOGIES	tificate	oride Membra		Serial No. 856426	Rings with S	Pass	<u> </u>	5	>
evoqua	WATER TECHNOLOGIES	Module Test Certificate	Polyvinylidenefluoride Membrane		Module ID WSF1A84B	Lubricate O-F	Integrity Test (DAE)	Flow Test	Visual Check	Size and Length




Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 47 of 120

MIL









Q-Pulse Id: TMS1440

Active: 12/10/2015

IL









Form QA 104 Issue 11 467437 Batch No. Chirayu Mehta Lubricate O-Rings with Supplied Silicone Grease Only 28/01/2015 F1S1 Type L20N Tested By Date Crate ID Part No. 120408 Pass 856467 Integrity Test (DAF) Size and Length Visual Check WRF1821C Module ID Flow Test

Q-Pulse Id: TMS1440

Active: 12/10/2015








Form QA 104 Issue 11



Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 50 of 120

NFZ






Form QA 104 Issue 11

F1S1

Crate ID

Size and Length

Visual Check



Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 51 of 120

EWT Membrane Systems Pty Ltd

A.B.N 36 166 784 694 Memcor Products


15 Blackman Cresent South Windsor NSW

Polyvinylidenefluoride Membrane

Module Test Certificate

evogua WATER TECHNOLOGIES

MILL





1417340

Type L20N

120408

Serial No. 816695

WSE47216 Module ID

Greg Horrigan

19/06/2014

Date Fested By

E6J2

Crate ID

Size and Length

Visual Check

Flow Test

Lubricate O-Rings with Supplied Silicone Grease Only

Fail

Pass


Integrity Test (DAF)

Batch No.

Tel: 61 (02) 4577 0001 Fax: 61 (02) 4577 0002

Australia 2756


Form QA 104 Issue 11



Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 52 of 120







Form QA 104 Issue 11

E6J2


Crate ID


Size and Length

Visual Check



Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 53 of 120









Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 54 of 120

MFL









Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 55 of 120

272









Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 56 of 120

MFZ






F1S1

Crate ID


Size and Length

Visual Check




Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 57 of 120

24/2








Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 58 of 120

MFZ









Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 59 of 120

27/W





Form QA 104 Issue 11

Crate ID

Size and Length


Visual Check


Flow Test



Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 60 of 120

1952









Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 61 of 120

MFZ





Form QA 104 Issue 11

F1R4

Crate ID

Size and Length Visual Check

Date



Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 62 of 120


Memcor Products A.B.N 36 166 784 694


15 Blackman Cresent

South Windsor NSW

Australia 2756

MFZ





WPECV81Q

Module ID


Batch No. 1467437

Tel: 61 (02) 4577 0001 Fax: 61 (02) 4577 0002

Form QA 104 Issue 11

Visual Check

Flow Test



19F2




EWT Membrane Systems Pty Ltd Form QA 104 Issue 11 Batch No. 1467437 Memcor Products A.B.N 36 166 784 694 Tel: 61 (02) 4577 0001 Fax: 61 (02) 4577 0002 15 Blackman Cresent South Windsor NSW Marvin Romero Australia 2756 Lubricate O-Rings with Supplied Silicone Grease Only 28/01/2015 L20N Tested By Date Crate ID Part No. 120408 Polyvinylidenefluoride Membrane Serial No. 856352 Pass Module Test Certificate evoqua WATER TECHNOLOGIES Integrity Test (DAF) Size and Length WRF18716 Visual Check Module ID Flow Test



Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 64 of 120


MFZ





Form QA 104 Issue 11

Size and Length





Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 65 of 120

MFZ









Q-Pulse Id: TMS1440

Active: 12/10/2015

B							7
EWT Membrane Systems Pty Ltd	Memcor Products A.B.N 36 166 784 694	15 Blackman Cresent South Windsor NSW Australia 2756 Tel: 61 (02) 4577 0001 Fax: 61 (02) 4577 0002	Batch No. 1467436	ease Only	Chirayu Mehta 27/01/2015	25	Form QA 104 Issue 11
/T Mem	Me A.B	Sou Sou Tel: Fax:	Type L20N	ne Gr		F1R4	
EW		FII	Part No. 120408	Lubricate O-Rings with Supplied Silicone Grease Only	Fall Tested By	Crate ID	
QUA	WATER TECHNOLOGIES Test Certificate	Polyvinylidenefluoride Membrane	Serial No. 856205	-Rings with S	DAF)	عُلَال	
● evoqua	Module Test Certificate	Polyvinylidene	Module ID WRF1844L	Lubricate	Integrity Test (DAF)	Visual Check Size and Length	
stems Pty Ltd	784 694 resent	NSW 56 7 0001 7 0002	atch No. 467436	ylı.	hta	A 104 Issue 11	
Membrane Systems Pty Ltd	A.B.N 36 166 784 694 15 Blackman Cresent	South Windsor NSW Australia 2756 Tel: 61 (02) 4577 0001 Fax: 61 (02) 4577 0002	Type Batch No. L20N 1467436	e Grease Only	Chirayu Mehta 27/01/2015	F1R4 Form QA 104 Issue 11	
EWT Membrane Systems Pty Ltd Memoor Products		FE	3	upplied Silicone Grease Only Fail	Tested By Chirayu Mehta Date 27/01/2015	Crate ID F1R4 Form QA 104 Issue 11	
EWT Membrane Systems Pty Ltd water FECHNOLOGIES Memory Products			Type L20N	Lubricate O-Rings with Supplied Silicone Grease Only Pass Fail	Integrity Test (DAF) Tested By Chirayu Mehta Flow Test	F1R	

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 67 of 120



Wynnum STP

E-1 QUU Wynnum Membrane Replacement Report

1515-000002-QUU Wynnum STP RO and UF Membrane Replacement

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 68 of 120



QUU WYNNUM MEMBRANE REPLACEMENT REPORT

18th May 2015

Contract No: C1314-20

Evoqua Water Technologies Pty Ltd 160 Herring Road, Macquarie Park, NSW, 2113, Australia

A.B.N: 52 165 060 168 www.evoqua.com.au

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 69 of 120



Evoqua Water Technologies Pty Ltd 1515-000002

1 EXECUTIVE SUMMARY

The MF and RO membranes were replaced at Wynnum STP. The membranes had been in operation for 7 years, and an examination of the performance data and the membranes themselves found no evidence of damage other than typical ageing.

In order to increase MF filtration time between CIPs a trial of increased ration of dual CIPs could be conducted. PDT records should also be kept and regular MF maintenance performed if Pressure Decay Rates begin to increase.

2 INTRODUCTION

EWT attended site at QUU Wynnum from the 2nd to the 15th of March 2015 to replace the MF and RO membrane modules in the tertiary treatment plant. This report details what was noted during this change out, the results of the Membrane Autopsy and recommendations for operation of the plant.

The water treatment plant has been in operation since March 2008, meaning that both the RO and MF membrane module are around 7 years old. This is at or above the design lifetime for both RO, indicating the plant has been operated well.

3 REMOVAL NOTES

3.1 MF Modules

The MF modules removed were in relatively good condition given their age. A small amount of black substance was visible at the top and bottom of the module. A number of the pots had swelled slightly making removal difficult. A fine sand like grit was apparent around the module housing threads and O-rings. All O-rings showed signs of deterioration due to chloramine exposure.



Figure 1 MF Membrane Condition



Figure 2 MF O-Ring Degradation

1515-000002 Membrane Replacement Report

Page 2 of 8

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 70 of 120



Evoqua Water Technologies Pty Ltd 1515-000002

3.2 RO Modules

The feed spacer of the first membrane for both Stage 1 and Stage 2 was fouled with a large amount of particulate matter, both rust and plastic. A large metal tool bit (potentially a thread tapping bit) was found in the feed spacer of RO2 Vessel 1A. However, due to the large space in the feed cavity there was no indication that the fouling was causing any significant issues.







Figure 4 Installation tool found in pressure tube.

The second stage membranes on both skids were noticeably dirtier, likely due to the fact that the second stage isn't cleaned as often as the first stage. The membrane fouling also increased along each vessel indicating a less adequate CIP flow distribution in the tail end modules.

4 PERFORMANCE SUMMARY

4.1 MF System

Q-Pulse Id: TMS1440

The MF system has been operating for 7 years and was showing signs of age prior to membrane replacement. The MF system has been run with high TMPs which can increase the wear and tear on the membrane module.

CIP frequency had increased, with filtration time between CIPs decreasing to as low as 1-2 days in some cases. It was noted that dual CIPs tended to give longer filtration intervals until another CIP was required. Given the increased effectiveness of the dual CIP, it may be worthwhile attempting a trial on 1 MF unit of increasing the ration of dual CIPs from the current ratio of 4:1 chlorine to acid to 2:1 or a similar ratio. It should be noted that any increase in filtration interval between CIPs will need to be evaluated against the increased costs of the dual CIP.



Evoqua Water Technologies Pty Ltd 1515-000002

In addition the resistance of the units was quite high however once the membranes were replaced the resistance dropped to expected levels. The level of resistance build up was consistent with aged membranes in a waste water treatment plant.




Figure 5: MF 1 Operating Data

Figure 5 and Figure 6 show the MF operation before and after membrane change out. It can be seen that Resistance dropped from the high levels seen prior to change out.

The PDT results for the MF plant indicated a loss of membrane integrity. Historical progression of PDT data was not available during membrane replacement. As the membranes ages individual fibres can become damaged. Integrity can be restored by undertaking pinning of the membrane module. It is important that regular maintenance including pinning of the MF system is undertaken. EWT are able to offer scheduled or occasional MF maintenance under a service agreement.

Q-Pulse Id: TMS1440



Evoqua Water Technologies Pty Ltd 1515-000002




Figure 6: MF2 Operating Data

4.2 RO System

The RO System operating data was examined. The normalised permeate flow was relatively stable for the majority of the operating life of the plant. The normalised permeate flow gives an indication of membrane fouling and the resistance to flow. It was noted that data received for the two RO racks was very similar.

Q-Pulse Id: TMS1440




Figure 7: RO-1 Normalised Permeate Flow




Figure 8: RO-2 Normalised Permeate Flow

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 74 of 120



Evoqua Water Technologies Pty Ltd 1515-000002

The normalised salt passage was also examined. The normalised salt passage can be seen to increase slowly over time. There rate of salt passage increased towards the end of the membrane life, however this is not abnormal based on aging of the membrane.




Figure 9: RO-1 Normalised Salt Passage

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 75 of 120

Evoqua Water Technologies Pty Ltd 1515-000002




Figure 10: RO-2 Normalised Salt Passage

5 MEMBRANE AUTOPSIES

The RO and MF autopsies are attached to this report. The MF Autopsy found that the membranes were generally in good condition with a slight swelling of the pots but the fibres clean and in good condition. The performance and fouling were found to be typical of an aged membrane.

The RO autopsy found evidence of biofouling in the RO module but no physical damage. Given that pressure drops and NPF remained stable, there was no indication that the fouling is out of control. The autopsy found no evidence of oxidative damage to the membranes and concluded that the salt passage increase was typical of membrane ageing.

Q-Pulse Id: TMS1440



Wynnum STP E-2 RO Autopsy Report

1515-000002-QUU Wynnum STP RO and UF Membrane Replacement

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 77 of 120




THE FUTURE IS CLEAR



Reverse Osmosis Membrane Autopsy Report



Evoqua Water Technologies









29th April 2015

Job Number: FS15179



Unit 6/120 Bluestone Ct, Seventeen Mile Rocks QLD Australia 4073, Phone: +61 (0)7 3715 8168, Fax: +61 (0)7 3715 8170 Email: info@wwfutures.com

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 78 of 120

Phone: +61 (0)7 3715 8168, Fax: +61 (0)7 3715 8170 Email: info@wwfutures.com

DOCUMENT CONTROL

EVOQUA WATER TECHNOLOGIES:

AUTOPSY REPORT FOR REVERSE OSMOSIS MEMBRANES

Prepared For	Evoqua Water Technologies Pty Ltd		
Prepared By	Wastewater Futures Pty Ltd		

Membrane Futures	Document: EvoquaApr15		
Unit 6, 120 Bluestone Circuit			
Seventeen Mile Rocks 4073	Job Number: FS15179		
Queensland Australia			
	Project Manager: Jason Dwyer		
Tel: +61 7 3715 8168			
Fax: +61 7 3715 8170	Client: Evoqua Water Technologies Pty Ltd		
ABN 93 085 246 699	Client Contact: Edina Aganovic		
	Edina.aganovic@evoqua.com		
www.membranefutures.com	0447 319 146		

Title: Evoqua Water Technologies: Autopsy Report for RO Membranes

Contributors: Julien Reungoat, David Reynolds & Jason Dwyer

Synopsis: Standard Autopsy


Evoqua Water Technologies: RO Autopsy

Revision History

Revision No	Date Issued	Checked By		Issue	ed By
Version 1	29/04/2015	JND	29/4/2015	JR	29/04/2015
Version 2	05/05/2015			JR	05/05/2015

2 of 31

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 79 of 120



Unit 6/120 Bluestone Ct, Seventeen Mile Rocks QLD Australia 4073, Phone: +61 (0)7 3715 8168, Fax: +61 (0)7 3715 8170 Email: info@wwfutures.com

EXECUTIVE SUMMARY

Membrane Futures received two reverse osmosis (RO) elements from Evoqua Water Technologies for autopsy. The elements were from Wynnum advanced water treatment plant that treats tertiary effluent from a municipal wastewater treatment plant. The elements were both brackish water Dow BW30-400/34i-FR from Stage 1 – Lead (S1L) and Stage 2 – Tail (S2T) positions. The reason for autopsy was that the elements were at the end of their life and in the process of being replaced because of increased salt passage. The membranes were seven years old. The aim of the autopsy was to perform a health check and identify possible cause(s) of increased salt passage.

Parameter	Methods	Results
Performance and integrity	Vacuum decay test Visual inspection Fujiwara test	<u>S1L.</u> No sign of physical damage. No sign of high differential pressure. No sign of delamination. No sign of chemical oxidation. Connector O-ring degraded.
	. ajiwara toot	<u>S2T.</u> No sign of physical damage. No sign of high differential pressure. No sign of delamination. No sign of chemical oxidation.
Fouling levels and distribution	Visual inspection Loss on ignition	<u>S1L.</u> Brown deposit visible on surface, higher concentration towards the lead end, also caught in spacer mesh. Easy to scrape off, sludge like substance, contains large amount of small particles. Amount of solids was 4,230 mg/m² at the lead (89% organics/11% inorganics) and 1,573 mg/m² at the tail (88% organics/12% inorganics). This was a significant to high level of fouling.
		<u>S2T.</u> Brown deposit visible on surface with darker patches. Some caught in spacer mesh. Thick brown sludge easily removed when scraped off. Amount of solids was 1,032 mg/m² at the lead (85% organics/15% inorganics) and 682 mg/m² at the tail (82% organics/18% inorganics). This was a significant level of fouling.
Nature of inorganic	SEM-EDS	S1L. Low magnification showed an apparently clean surface but high magnification revealed the presence of diatoms.
fouling		<u>S2T.</u> Low magnification showed an apparently clean surface but high magnification revealed the presence of diatoms at the lead, the tail sample was clean.

There was no obvious damage to the element or to the membrane surface that would explain the increased salt passage. There was a medium to high amount of fouling on both elements. The amount decreased in the direction of the flow. More than 80 % of the solids mass was organic matter, the level of inorganic fouling was low except at the lead of the Stage 1 – Lead element. Given that the plant treats tertiary effluent from a wastewater treatment plant, it was reasonable to assume that the organic matter presence was due to biofouling. Biofouling typically leads to increased differential pressure and sometime to a drop in flux but it does not usually affect salt

Evoqua Water Technologies: RO Autopsy

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 80 of 120

3 of 31



Unit 6/120 Bluestone Ct, Seventeen Mile Rocks QLD Australia 4073,
Phone: +61 (0)7 3715 8168, Fax: +61 (0)7 3715 8170 Email: info@wwfutures.com

rejection. The SEM-EDS analysis showed the presence of diatoms on the membrane. Diatoms have a hard cell wall made of silica that could lead to abrasion of the membrane surface. The increase in salt passage had been gradual over the years so it was not due to a single event. Membrane Futures opinion is that the increase in salt passage was caused by membrane ageing and possibly abrasion caused by the diatoms.

The diatoms were approximately 10 μ m in size and should be removed by ultrafiltration. Membrane Futures recommends reviewing the pre-treatment of the plant. The high pH CIP appeared to have kept biofouling development under control. If possible, cleaning in the reverse direction of the flow is preferable as it prevents pushing the fouling material further in the process.

4 of 31

Evoqua Water Technologies: RO Autopsy


Q-Pulse ld: TMS1440 Active: 12/10/2015 Page 81 of 120



Unit 6/120 Bluestone Ct, Seventeen Mile Rocks QLD Australia 4073, Phone: +61 (0)7 3715 8168, Fax: +61 (0)7 3715 8170 Email: info@wwfutures.com

TABLE OF CONTENTS

Docur	ment Control2
Execu	itive Summary3
Table	of Contents5
Figure	es and Tables6
1.0	Background7
2.0	Results
2.1	Vacuum Decay Test10
2.2	Visual Inspection10
2.3	Sampling Regime21
2.4	Loss on Ignition (LOI)
2.5	Scanning Electron Microscopy – Energy Dispersive X-ray Spectroscopy (SEM-EDS) 23
2.6	Fujiwara Analysis27
3.0	Conclusions
Apper	ndix30
A.1	Vacuum Decay Test30
A.2	Visual Inspection30
A.3	Loss on Ignition (LOI)
A.4	Scanning Electron Microscopy - Energy Dispersive X-ray Spectroscopy (SEM-EDS) 30
A.5	Fujiwara Test



Phone: +61 (0)7 3715 8168, Fax: +61 (0)7 3715 8170 Email: info@wwfutures.com

FIGURES AND TABLES

Figure 1	RO elements received for autopsy.	7
Figure 2	Normalised permeate flow and salt passage (SP)	8
Figure 3	Vacuum decay test results	10
Figure 4	External inspection of the Stage 1 – Lead element.	12
Figure 5	Internal inspection of Stage 1 – Lead element.	14
Figure 6	Stereomicroscope inspection of Stage 1 – Lead element	15
Figure 7	External inspection of the Stage 2 – Tail element.	17
Figure 8	Internal inspection of Stage 2 – Tail element.	19
Figure 9	Stereomicroscope inspection of Stage 2 – Tail element	21
Figure 10	Average fouling levels	23
Figure 11	SEM images and EDS analysis of Stage 1 – Lead, lead sample	24
Figure 12	SEM images and EDS analysis of Stage 1 – Lead, tail sample	25
Figure 13	SEM images and EDS analysis of Stage 2 – Tail, lead sample	26
Figure 14	SEM images and EDS analysis of Stage 2 – Tail, tail sample	27
Figure 15	Fujiwara results	28
Table 1	Sampling regime	21
Table 2	Results of solids content on the membranes	22

Unit 6/120 Bluestone Ct, Seventeen Mile Rocks QLD Australia 4073,
Phone: +61 (0)7 3715 8168, Fax: +61 (0)7 3715 8170 Email: info@wwfutures.com

1.0 BACKGROUND

Membrane Futures received two reverse osmosis (RO) elements from Evoqua Water Technologies (Figure 1) for autopsy. The elements were from the Wynnum advanced water treatment plant. The elements were both brackish water Dow BW30-400/34i-FR from:

- Stage 1, vessel D5, lead position: #F2743304
- Stage 2, vessel D5, tail position: #F2743272

The reason for autopsy was that the elements were at the end of their life and in the process of being replaced because of increased salt passage (Figure 2). The membranes were seven years old. The aim of the autopsy was to perform a health check and identify possible cause(s) of increased salt passage.



Evoqua Water Technologies: RO Autopsy



7 of 31

(a) Stage 1 - Lead #F2743304




(b) Stage 2 – Tail #F2743272

Figure 1RO elements received for autopsy.

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 84 of 120

Phone: +61 (0)7 3715 8168, Fax: +61 (0)7 3715 8170 Email: info@wwfutures.com






Figure 2 Normalised permeate flow and salt passage (SP).

Evoqua Water Technologies: RO Autopsy

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 85 of 120

8 of 31



Phone: +61 (0)7 3715 8168, Fax: +61 (0)7 3715 8170 Email: info@wwfutures.com

The Wynnum advanced water treatment plant treats tertiary effluent from a municipal wastewater treatment plant. The RO feed water had a conductivity between 1,600 and 2,000 µS/cm, pH was in the 6.5 to 7.0 range, turbidity was 0.05, SDI was below 2.5 and temperature varied between 25 and 28°C. The RO treatment had two trains with two stages. There were 16 vessels in the first stage and 8 vessels in the second stage. There were seven 8 inch elements in each pressure vessel. The feed flow was 140 m³/hr per train and the permeate flow was 100 m³/hr. The target recovery was 75%. The feed pressure was 900 kPa and the concentrate pressure was 600 kPa. The permeate pressure was 260 kPa in the first stage to balance the flow and 30 kPa in the second stage. The pre-treatment before the RO consisted of:

- Chloramination (1.5-1.7 ppm total chlorine, free chlorine < 0.05 ppm)
- Pressurised ultrafiltration

Evoqua Water Technologies: RO Autopsy

Cleaning in place (CIP) was performed based on a pressure drop in the normalised data. The frequency of cleaning approached monthly at the end of the life of the membranes. The CIP was performed with an acid solution only, no caustic cleaning was performed.

9 of 31

Q-Pulse ld: TMS1440 Active: 12/10/2015 Page 86 of 120

Phone: +61 (0)7 3715 8168, Fax: +61 (0)7 3715 8170 Email: info@wwfutures.com

2.0 RESULTS

2.1 Vacuum Decay Test

The vacuum decay test was used to determine the physical integrity of the reverse osmosis elements and the membrane. A vacuum of 700 mbar was applied on the permeate side and the vacuum decay was monitored over time (Figure 3). A decay of more than 100 mbar in the first minute is a sign of physical damage. Both elements passed the test. The vacuum loss in Stage 1 – Lead was 87 mbar after one minute while it was only 8 mbar for Stage 2 – Tail element.




Figure 3 Vacuum decay test results.

2.2 Visual Inspection

Evoqua Water Technologies: RO Autopsy

Each element was drained and weighed before it was opened. When the element was opened the sheets were labelled consecutively. All the sheets were inspected, the pictures below show typical observations.

Stage 1 - Lead

The fiberglass casing had a brown discoloration but was otherwise clean and in good condition (Figure 4a). Some of the arms of the lead anti-telescoping device were bent (Figure 4b). This could be due to high differential pressure or could have happened during loading or unloading of the element. There was a lot of debris on the lead coil (Figure 4d-e). The particles were of different sizes, ranging from less than a millimetre to over one centimetre. The particles were of various colours, mostly black or grey but also brown and blue. The permeate O-ring was heavily degraded

10 of 31



Phone: +61 (0)7 3715 8168, Fax: +61 (0)7 3715 8170 Email: info@wwfutures.com


and some of the particles on the coil seemed to have come from it (Figure 4 f). The tail antitelescoping device was in good condition except for a spike that was broken (Figure 4 c). This probably happened during loading or unloading of the element. The tail coil was clean, there were only a few black particles. The brine seal was attached to the module. It was in good condition and there was no deposit in the channel (Figure 4 g).




(a) external casing



(b) lead anti-telescoping device and coil



(c) tail anti-telescoping device and coil



(d) debris on lead coil



(e) debris on lead coil

Evoqua Water Technologies: RO Autopsy


11 of 31

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 88 of 120



Phone: +61 (0)7 3715 8168, Fax: +61 (0)7 3715 8170 Email: info@wwfutures.com





(f) permeate O-ring

(g) brine seal

12 of 31

Page 89 of 120

Figure 4External inspection of the Stage 1 – Lead element.

The fiberglass and outer tape were removed from the element and the membrane sheets unwound. The surface of the sheets was covered with a brown residue (Figure 5a-b). The amount of residue was higher at the lead. There were also some black particles towards the lead end (Figure 5c). There was a strip of black staining along a dozen of the sheets (Figure 5d). The affected sheets were all next to each other and the stain location changed gradually from the external edge toward the permeate tube. This suggested that it could be due to the element being stored lying for a long period of time in or out of the pressure vessel. Some of the deposit was caught in the spacer mesh (Figure 5e). The glue lines were in good conditions. When the surface was wiped with a cloth or scraped with a glass slide, a large amount of light brown thick deposit was removed (Figure 5f-g).

Active: 12/10/2015

Q-Pulse Id: TMS1440



Phone: +61 (0)7 3715 8168, Fax: +61 (0)7 3715 8170 Email: info@wwfutures.com



(a) surface overview



(b) deposit in middle of sheet



(c) deposit and black particles at lead end


13 of 31

Evoqua Water Technologies: RO Autopsy

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 90 of 120







(d) patch of black discoloration

(e) spacer mesh





(f) deposit removed when wiped with a cloth

(g) deposit removed when scraped with a glass slide

14 of 31

Page 91 of 120

Figure 5 Internal inspection of Stage 1 – Lead element.

The membrane surface, the spacer mesh and the deposit removed with the glass slide were observed under a stereomicroscope. The deposit on the membrane surface was concentrated along the spacer mesh lines (Figure 6a-b). The deposit was caught in the spacer mesh, in particular around the intersections (Figure 6c-d). This can block the flow of the water and lead to high differential pressure across the element. The deposit removed with the glass slide contained a lot of small particles (Figure 6e-f).

Active: 12/10/2015

Q-Pulse Id: TMS1440




(a) membrane surface x10 (b) membrane surface x50 (c) spacer mesh x10 (d) spacer mesh x50

(e) deposit removed with glass slide x10 (f) deposit removed with glass slide x50 Figure 6 Stereomicroscope inspection of Stage 1 – Lead element.

15 of 31

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 92 of 120




Phone: +61 (0)7 3715 8168, Fax: +61 (0)7 3715 8170 Email: info@wwfutures.com

Stage 2 - Tail

The fiberglass casing was clean and in good condition (Figure 7 a). The anti-telescoping devices were in good condition (Figure 7 b-c). There were some brown deposits on the lead coil but the amount was not concerning (Figure 7 d). The tail coil was clean. The brine seal was attached to the module (Figure 7 e). It was in good condition and there was no deposit in the channel. There was no external sign of high differential pressure.



(a) external casing



(b) lead anti-telescoping device and coil

Evoqua Water Technologies: RO Autopsy



(c) tail anti-telescoping device and coil

16 of 31

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 93 of 120



Phone: +61 (0)7 3715 8168, Fax: +61 (0)7 3715 8170 Email: info@wwfutures.com





(d) brown deposit on lead coil

(e) brine seal

17 of 31

Figure 7 External inspection of the Stage 2 - Tail element.

The fiberglass and outer tape were removed from the element and the membrane sheets unwound. The surface of the membrane was covered with a brown deposit (Figure 8a-c). There were isolated patches of thicker dark brown deposits (Figure 8d). In this location corresponded some deposit caught in the spacer mesh (Figure 8e). The glue lines were in good condition. When the surface was wiped with a cloth or scraped with a glass slide, a thick dark brown residue was removed (Figure 8f-g).

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 94 of 120

Phone: +61 (0)7 3715 8168, Fax: +61 (0)7 3715 8170 Email: info@wwfutures.com



(a) surface overview



(b) deposit at lead end



(c) deposit on middle of sheet

18 of 31

Evoqua Water Technologies: RO Autopsy

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 95 of 120



Phone: +61 (0)7 3715 8168, Fax: +61 (0)7 3715 8170 Email: info@wwfutures.com





(d) patches of dark brown deposit

(e) deposit caught in spacer mesh





(f) deposit removed when wiped with a white cloth

(g) deposit removed when scraped with a glass slide

19 of 31


Figure 8 Internal inspection of Stage 2 - Tail element.

The surface of the membrane, the spacer mesh and the deposit removed with the glass slide were observed under a stereomicroscope. The deposit on the membrane was more concentrated along the spacer mesh lines (Figure 9a-b). There were indentations in the surface, probably caused by the spacer mesh, however the surface of the membrane did not appear to be damaged. The dark brown deposits had a granular appearance (Figure 9c-d). The deposit caught in the spacer mesh was mostly around the intersections (Figure 9e-f). The deposit removed with the glass slide was similar to the Stage 1 – Lead element but with less particles (Figure 9g-h).

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 96 of 120



Phone: +61 (0)7 3715 8168, Fax: +61 (0)7 3715 8170 Email: info@wwfutures.com



Evoqua Water Technologies: RO Autopsy

Q-Pulse Id: TMS1440

Active: 12/10/2015

Page 97 of 120

20 of 31

Unit 6/120 Bluestone Ct, Seventeen Mile Rocks QLD Australia 4073,

Phone: +61 (0)7 3715 8168, Fax: +61 (0)7 3715 8170 Email: info@wwfutures.com





(g) deposit removed with glass slide x10

(h) deposit removed with glass slide x50

21 of 31

Figure 9Stereomicroscope inspection of Stage 2 - Tail element.

2.3 Sampling Regime

Samples were taken at the lead and tail from various sheets throughout the elements. Samples were always taken at the very edge of the glue lines. A summary of the location of the samples taken for analysis is provided (Table 1). The elements each had 25 sheets.

Table 1 Sampling regime.

Element	Location	n LOI SEM		Fujiwara	
	Lead 1/2	Х	Х	Х	
Stage 1 –	Tail 1/2	Χ	Χ	X	
Lead	Lead 19/20	Χ			
	Tail 19/20	Χ			
	Lead 1/2	Х	Χ	Х	
Stage 2 –	Tail 1/2	Χ	Χ	X	
Tail	Lead 19/20	Χ			
	Tail 19/20	Х			

Samples were prepared using different methods. The sample preparation for each of the analyses used is described:

<u>LOI</u>: Samples 10x15 cm were placed into ultrapure water.

<u>SEM-EDS</u>: Samples were mounted on plates and analysed at the surface.

<u>Fujiwara</u>: Samples 2x2 cm were taken and tested.

Evoqua Water Technologies: RO Autopsy

Q-Pulse ld: TMS1440 Active: 12/10/2015 Page 98 of 120


2.4 Loss on Ignition (LOI)

LOI, TOC and total ICP-AES analysis was performed on samples from each of the elements. Analysis was performed on two lead and two tail locations from each of the elements. LOI was performed on the foulant mass that could be wiped off the membrane surface. TOC and ICP-AES analysis was completed on the foulant mass that was able to dissolve into a 5% w/w nitric acid solution. The average results are provided individually for each location (Table 2). The elements were also placed on an indicative fouling level scale (Figure 10).

There was a significant to high amount of fouling on the Stage 1 – Lead element. The amount of fouling was almost three times higher at the lead compared to the tail. The proportions of volatile and fixed solids were the same at the lead and tail. The volatile solids accounted for nearly 90%, indicating that the foulant was mainly organic matter. It is typical for the amount of organic fouling to decrease in the direction of the flow. The total amount of fouling on the Stage 2 – Tail element was lower than on the Stage 1 – Lead element, but it was still significant. The amount also decreased in the direction of the flow. Similarly to the Stage 1 element, volatile solids accounted for a large part of the solids, more than 80%.

Total Solids Volatile Solids Fixed Solids Element mg/m² (% of Total Solids) 3,777±758 (89%) 453±39 (11%) Lead 4,230±797 Stage 1 – Lead Tail 1,573±91 1,382±121 (88%) 192±29 (12%) 1,032±88 878±101 (85%) 153±13 (15%) Lead Stage 2 - Tail Tail 682±167 562±160 (82%) 120±7 (18%)

Table 2 Results of solids content on the membranes.




(a) Stage 1 – Lead, lead sample


Q-Pulse ld: TMS1440 Active: 12/10/2015 Page 99 of 120

22 of 31


Phone: +61 (0)7 3715 8168, Fax: +61 (0)7 3715 8170 Email: info@wwfutures.com



(b) Stage 1 - Lead, tail sample



(c) Stage 2 – Tail, lead sample



(d) Stage 2 - Tail, tail sample

Figure 10 Average fouling levels.

2.5 Scanning Electron Microscopy – Energy Dispersive X-ray Spectroscopy (SEM-EDS)

SEM and EDS analysis was performed on samples from the lead and tail of each of the elements to confirm the LOI and ICP-AES findings and better characterise the deposits. First, SEM images were taken of the surface of representative samples at low magnification (x 30) to give an overview of the area. In these images, high atomic number elements correspond to more intensely white regions. EDS analysis was completed on the entire visible surface on these images. The membrane material produces large peaks of carbon, oxygen and sulfur. Then, high magnification images were taken of the deposits that were found and EDS analysis performed to better characterise them.

23 of 31

Evoqua Water Technologies: RO Autopsy

Q-Pulse ld: TMS1440 Active: 12/10/2015 Page 100 of 120

Unit 6/120 Bluestone Ct, Seventeen Mile Rocks QLD Australia 4073, Phone: +61 (0)7 3715 8168, Fax: +61 (0)7 3715 8170 Email: info@wwfutures.com

Stage 1 – Lead

The overview image of the lead sample showed that the surface was mainly free of deposits (Figure 11a). The EDS analysis showed significant peaks for the membrane material only. However, high magnification images and EDS analysis showed the presence of diatoms on the surface (Figure 11b-c). Diatoms are unicellular algae enclosed in a silica wall.




Figure 11 SEM images and EDS analysis of Stage 1 – Lead, lead sample.

Evoqua Water Technologies: RO Autopsy

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 101 of 120

24 of 31



The overview image of the tail sample showed that the surface was mainly free of deposits (Figure 12a). The EDS analysis showed significant peaks for the membrane material and a small peak for silica. Similarly to the lead sample, high magnification images and EDS analysis showed the presence of diatoms on the surface (Figure 12b).




Figure 12 SEM images and EDS analysis of Stage 1 - Lead, tail sample.

Stage 2 - Tail

Q-Pulse Id: TMS1440

The overview image of the lead sample showed a surface free of deposits (Figure 13a). The EDS analysis showed significant peaks for the membrane material only. High magnification images and EDS analysis showed the presence of diatoms (Figure 13b).

Active: 12/10/2015

25 of 31

Page 102 of 120



Phone: +61 (0)7 3715 8168, Fax: +61 (0)7 3715 8170 Email: info@wwfutures.com





Figure 13 SEM images and EDS analysis of Stage 2 – Tail, lead sample.

The overview image of the tail sample was similar to the lead sample, the surface appeared free of deposits (Figure 14a). The high magnification images and EDS analysis did not find diatoms but a small aluminium silicate particle was present (Figure 14b).




Evoqua Water Technologies: RO Autopsy

26 of 31

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 103 of 120

Phone: +61 (0)7 3715 8168, Fax: +61 (0)7 3715 8170 Email: info@wwfutures.com



(b) aluminium silicate particle x 5,000

Figure 14 SEM images and EDS analysis of Stage 2 – Tail, tail sample.

2.6 Fujiwara Analysis

Evoqua Water Technologies: RO Autopsy

Fujiwara analysis was conducted on lead and tail samples from each element. A positive control was also included (Figure 15 a). A positive result is identified by the formation of a pink colour in the test tube. Both elements had negative results (Figure 15 b-c). A negative result does not guarantee that there has not been any oxidative damage as the Fujiwara test is not sensitive in the early stages of oxidation.




(a) Positive control


27 of 31

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 104 of 120



Phone: +61 (0)7 3715 8168, Fax: +61 (0)7 3715 8170 Email: info@wwfutures.com






28 of 31

(a) Stage 1 - Lead

Evoqua Water Technologies: RO Autopsy

(b) Stage 2 – Tail

Figure 15 Fujiwara results.



Unit 6/120 Bluestone Ct, Seventeen Mile Rocks QLD Australia 4073,
Phone: +61 (0)7 3715 8168, Fax: +61 (0)7 3715 8170 Email: info@wwfutures.com

3.0 CONCLUSIONS

There was no obvious damage to the element or to the membrane surface that would explain the increased salt passage. There was a medium to high amount of fouling on both elements. The amount decreased in the direction of the flow. More than 80 % of the solids mass was organic matter, the level of inorganic fouling was low except at the lead of the Stage 1 – Lead element. Given that the plant treats tertiary effluent from a wastewater treatment plant, it was reasonable to assume that the organic matter presence was due to biofouling. Biofouling typically leads to increased differential pressure and sometime to a drop in flux but it does not usually affect salt rejection. The SEM-EDS analysis showed the presence of diatoms on the membrane. Diatoms have a hard cell wall made of silica that could lead to abrasion of the membrane surface. The increase in salt passage had been gradual over the years so it was not due to a single event. Membrane Futures opinion is that the increase in salt passage was caused by membrane ageing and possibly abrasion caused by the diatoms.

The diatoms were approximately 10 μ m in size and should be removed by ultrafiltration. Membrane Futures recommends reviewing the pre-treatment of the plant. The high pH CIP appeared to have kept biofouling development under control. If possible, cleaning in the reverse direction of the flow is preferable as it prevents pushing the fouling material further in the process.

29 of 31

Evoqua Water Technologies: RO Autopsy

Q-Pulse ld: TMS1440 Active: 12/10/2015 Page 106 of 120



Phone: +61 (0)7 3715 8168, Fax: +61 (0)7 3715 8170 Email: info@wwfutures.com

APPENDIX

Outlined below is a brief description of the autopsy tasks and how they were undertaken.

A.1 Vacuum Decay Test

The vacuum decay test was used to determine the physical integrity of the reverse osmosis elements and the membrane. A vacuum of 700 mbar was applied on the permeate side and the vacuum decay was monitored over time. A decay of more than 100 mbar in the first minute is a sign of physical damage.

A.2 Visual Inspection

The feed and tail ends of the spiral wound modules were closely examined and foreign material sampled for relevant analysis. Careful examination was made for signs of high-pressure events. The membrane module fiberglass skin was cut open and removed. The internal membrane sheets were unwound and each side of the individual membrane sleeves examined. Documentation of any visual fouling was made, as well as any evidence of high-pressure events (tears or rupturing of glue lines). Dissection of representative sections of the membrane surface was performed, including the sampling of all visually obvious fouled surfaces. Magnified images of very small ruptures were taken, if present.

A.3 Loss on Ignition (LOI)

Evoqua Water Technologies: RO Autopsy


The LOI test measures the degree of volatile and incombustible solids on the membrane surface. Samples of fibres or flat sheet membrane were placed into water and agitated very gently to remove surface fouling. The membrane was removed from the solution and the solution was evaporated at 110 °C and weighed. The remaining material was then ignited at 550 °C and weighed again.

A.4 Scanning Electron Microscopy – Energy Dispersive X-ray Spectroscopy (SEM-EDS)

SEM produces highly magnified images of the surface of the membranes and the fouling materials. The three dimensional nature of SEM allows for identification of the surface and of the fouling material structures. EDS uses electron beams to excite the atoms of the membrane and the fouling materials. X-rays emitted are examined to decipher information about the elements present at the membrane surface.

30 of 31

Q-Pulse ld: TMS1440 Active: 12/10/2015 Page 107 of 120



Unit 6/120 Bluestone Ct, Seventeen Mile Rocks QLD Australia 4073,
Phone: +61 (0)7 3715 8168, Fax: +61 (0)7 3715 8170 Email: info@wwfutures.com

A.5 Fujiwara Test

The Fujiwara test is a qualitative indicator of damage caused by halide oxidation of the membrane polyamide surface. It is commonly used to indicate oxidation caused by chlorine to polyamide thin-film membranes. Small coupons of membrane were immersed in a solution containing pyridine and sodium hydroxide and heated. The formation of a pink colour indicates oxidative damage. However, the Fujiwara test is not sensitive enough to detect early damage caused by halide oxidants. As a result, the absence of pink colour formation does not necessarily guarantee that damage has not occurred. Membrane Futures can perform additional tests to determine if the organic fouling has a biological origin.

31 of 31

Evoqua Water Technologies: RO Autopsy

Q-Pulse ld: TMS1440 Active: 12/10/2015 Page 108 of 120



Wynnum STP UF Membrane Autopsy Report

1515-000002-QUU Wynnum STP RO and UF Membrane Replacement

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 109 of 120



WYNNUM WATER RECLAMATION PLANT MEMCOR® CP SYSTEM

EVOQUA WATER TECHNOLOGIES
MEMBRANE MODULE AUTOPSY REPORT
15th May 2015

Evoqua Water Technologies Pty Ltd

15 Blackman Crescent, South Windsor NSW 2756 AUSTRALIA Reference: 1515-000002trp01_01_Wynnum Autopsy Report www.evoqua.com.au Ph:+61 2 4577 6800 Fax: +61 2 4577 0078

Printed: 19 May 2015

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 110 of 120

ST13 Wynnum STP - Membrane Replacement - Manufacturers Data Report and OM Manual



Evoqua Water Technologies Pty Ltd

Wynnum WRP - Membrane Module Autopsy Report

Contents

1	INTRO	DDUCTION		3			
2	SUMM	SUMMARY & RECOMMENDATIONS					
3	AUTOPSY RESULTS			4			
	3.1 3.2 3.3	Observations Tensile Results EDS (Energy Dispersive (X-Ray) Spectroscopy) Analysis	4 5 6				
APPE	NDIX –	REFERENCE INFORMATION		8			

Q-Pulse ld: TMS1440 Active: 12/10/2015 Page 111 of 120



Wynnum WRP - Membrane Module Autopsy Report

1 Introduction

The Wynnum Memcor® CP System consists of two MEMCOR® CP Units with 90 L20V membranes and is designed to produce 7.1 MLD of filtrate. The system has been in operation since May 2008.

The modules were replaced in March 2015 after almost 7 years in service. Considering typical membrane module life is 5 to 7 years, the CP units must have been operated and maintained well

One module, WK78654D (382036), was returned to Evoqua for a general autopsy. The autopsy findings will be discussed in this report.

2 Summary & Recommendations

The module was found to be visually clean with no gross solids fouling. The cleanness of the membrane fibres were confirmed by EDS analysis with only trace amount of inorganics detected.

Slight degradation of polyurethane of the pots and O-rings from exposure to chlorine were observed whilst other module components including nylon potting sleeves and module screen showed no apparent degradation.

Tensile tests performed on the fibres sampled from the module returned up to 25% loss in break extension compared to initial QC results. This indicates that mechanically the fibres are in good condition.

Although the membrane module was still in good mechanical condition, based on the operator feedback and recent CIP history, it was concluded that the modules at Wynnum Water Reclamation Plant were exhibiting typical symptoms of ageing such as increase in fouling rate and increase in CIP frequency.

1515-000002trp01_01_Wynnum Autopsy ReportPage 3 of 8

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 112 of 120



Wynnum WRP - Membrane Module Autopsy Report

3 Autopsy Results

3.1 Observations

Serial No	Winder ID	Comments
382036	WK78654D	 The module as received in Autopsy had its bottom pot cut off (to facilitate removal from the centre tube as the polyurethane of the pots had swelled slightly). The combined weight of the two pieces was 10.1 kg which is in the range of new wetted un-used L20V module. The polyurethane of the pots had slightly swelled and acquired a matt / cloudy surface finish. This degradation is typically caused by oxidation from exposure to chlorine over the lifetime of the membrane. Similarly, the module O-rings also had acquired a slight matt surface finish due to oxidation. Other module components including nylon potting sleeves and module screen showed no apparent degradation. On removal of the protective module screen the membrane fibres looked visually very clean except for some minor black stain internal to the fibre bundle near the bottom pot. Screen indents were not seen. This implies that the module had never experienced gross solids fouling (i.e. excellent screening of solids in the feed water).

FIGURE 1: IMAGES OF THE MODULE 382036 BEFORE AND AFTER THE MODULE SCREEN IS REMOVED

Тор	Middle	Bottom

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 113 of 120



Wynnum WRP - Membrane Module Autopsy Report





3.2 Tensile Results

12 fibres from the outside of the bundle and 12 from the inside of the bundle were sampled from the module, dried at room temperature overnight and tensile tested across the fibre. The averaged results are tabled below.

TABLE 1: RESULTS OF TENSILE TESTS

Fibre Tensile Results	Initial (QC data)	Final outside of bundle	Final centre of bundle	
Force at Break (N)	1.79	1.84 ± 0.04	1.80 ± 0.04	
Yield Extension (%)	5.67	5.21 ± 0.12	4.95 ± 0.23	
Young's Modulus (MPa)	92 ± 4	106 ± 5.35	118 ± 11.42	
Break Extension (%)	131 ± 7	107 ± 7.15	98 ± 9.04	
Drop in Break Extension relative to initial results	-	18 %	25 %	

There has been a noticeable drop in break extensions of up to 25 %, but this would not be unexpected for a module that is over seven years old.

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 114 of 120



Wynnum WRP - Membrane Module Autopsy Report

3.3 EDS (Energy Dispersive (X-Ray) Spectroscopy) Analysis

EDS analysis allows a qualitative analyses of elemental inorganic material on the membrane surface. EDS was performed on two random fibre samples, one from the inside and the other from the outside of the membrane fibre bundle. The results are shown in the table below.

TABLE 2: RESULTS OF EDS ANALYSIS

	Atomic Weight % see note								
Sample	С	0	F	Al	Si	Ca	Fe	N	Na
Inside Middle Location 1	65.7	ı	33.7	0.03	0.3	ı	ı	-	ı
Inside Middle Location 2	59.6	19.9	19. 6	-	-	1.0	-	-	1
Inside Middle Location 3	64.2	-	35.8	-	-	-	-	-	-
Inside Middle Location 4	62.6	2.3	38.9	-	-	-	-	-	-
Inside Bottom Location 1	52.8	15.7	11.7	-	-	-	-	18.6	1.2
Inside Bottom Location 2	61.6	1.3	37.1	-	-	-	-	-	-
Inside Bottom Location 3	64.7	ı	35.3	-	ı	ı	ı	-	ı
Inside Bottom Location 4	61.1	ı	34.2	-	ı	ı	0.9	-	ı
Outside Top Location 1	44.6	6.4	49.0	-	ı	ı	ı	-	-
Outside Top Location 2	52.9	11.5	30.6	-	ı	4.9	ı	-	-
Outside Top Location 3	55.9	9.5	34.6	-	ı	ı	ı	-	ı
Outside Top Location 4	63.6	2.9	33.5	-	ı	ı	ı	-	-
Outside Middle Location 1	49.4	-	50.6	-	-	-	-	-	-
Outside Middle Location 2	64.3	ı	35.7	-	ı	ı	ı	-	ı
Outside Middle Location 3	61.6	-	38.4	-	-	-	-	-	-
Outside Middle Location 4	61.9	3.5	34.6	-	-	-	-	-	-

Note

EDS analysis is performed on a very small section of the surface of the fibre, therefore the results given above may not be indicative of the entire membrane bundle.

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 115 of 120

ST13 Wynnum STP - Membrane Replacement - Manufacturers Data Report and OM Manual



Evoqua Water Technologies Pty Ltd

Wynnum WRP - Membrane Module Autopsy Report

EDS analyses showed the samples to be relatively clean. The Carbon and Fluorine are representative of the membrane formulation and the inorganics detected can be regarded as trace only.

1515-000002trp01_01_Wynnum Autopsy ReportPage 7 of 8

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 116 of 120



Wynnum WRP - Membrane Module Autopsy Report

Appendix – Reference Information

Module Serial No	382036
Module ID:	WK78654D
Unit Type:	90L20V (32024)
Location:	B4 Initial, C7 Final
Installation Date:	17/09/2007 (factory), 8/01/2008 (site)
Removal Date:	11/03/2015
CMF Running Time (Hrs)	Not Known
Pre-Screening:	500 μm AMIAD Screen
Feedstream:	Secondary Sewage
Cleaning Regime (CIP) Used:	CIP every 2 days
Cleaning Regime (Oil) Oseu.	Acid CIP after every 3 Hypochlorite
Was the module removed immediately after CIP? What was the CIP performed immediately before the module was removed	No, "not for a while" Hypochlorite
Warranty Claim:	No
Memlog Connected:	N/A
Pressure Decay Result:	45 kPa/min
Temperature:	28° C
Flow Rate:	Not Known
Backwash Interval (min):	35
TMP(measured prior to cleaning) kPa:	80 kPa
Other Notes:	Scouring air flow is not readable due to instrument issue

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 117 of 120



Miscellaneous

F-1 Protec Pressure Vessel Drawing and Data Sheet

1515-000002-QUU Wynnum STP RO and UF Membrane Replacement

Q-Pulse Id: TMS1440 Active: 12/10/2015 Page 118 of 120

Protec Pressure Vessels PRO-8-450-SP

PRO-8-450-SP



Lenntech

info@lenntech.com Tel. +31-152-610-900 www.lenntech.com Fax. +31-152-616-289


The PROTEC Model PRO-8-450-SP is designed for continuous use as housing for membrane filtration elements to purify typical brackish waters at any positive pressure up to 450 PSI.

What separates this SP model from the traditional side port is the addition of the 3 " port designed specifically for systems using multiple port technology.

The PRO-8-450-SP will accommodate any make of eight-inch nominal diameter spiral-wound element as well as many hollow fiber elements. The element interface hardware for the specified element is supplied with the vessel.

The Model PRO-8-450-SP has been designed to meet the standards of the American Society of Mechanical Engineers (ASME), Boiler and Pressure Vessel Code, Section X. At an additional cost, vessels can be inspected during fabrication by an ASME Authorized Inspector and Code stamped.

Design Pressure	450 PSI	Operating pH Range	3-11
Minimum Operating Temp.	20°F	Cleaning pH Range (less than 30 min)	2-12
Maximum Operating Temp.	120°F		
Factory Test Pressure	495 PSI	Application	Typ. Brackish Water
Burst Pressure	2700 PSI		



Shell Length Code	L inch (mm)	P1 Standard inch (mm)	P2 Optional inch (mm)	P3 Optional inch (mm)	S Span in (mm)	Empty Weight Ib (kg)
-1	58.7	47	45	46	1 @ 28	76
	(1490.98)	(1193.80)	(1143.00)	[1168.40]	(711.20)	(35)
-1.5	78.7	67	65	66	1 @ 42	88
	(1998.98)	(1701.80)	(1651 <u>.</u> 00)	[1676.40]	(1066.80)	(40)
-2	98.7	87	85	86	1 @ 56	99
	(2506.98)	(2209.80)	(2159.00)	[2184.40]	(1422.40)	(45)
-3	138.7	127	125	126	1 @ 80	122
	(3522.98)	(3225.80)	(3175.00)	[3200.40]	(2032.00)	(55)
-4	178.7	167	165	166	2 @ 64	145
	(4538.98)	(4241.80)	(4191.00)	[4216.40]	[1625.60]	(66)
-5	218.7	207	205	206	2 @ 78	168
	(5554.98)	(5257.80)	(5207.00)	[5232.40]	[1981.20]	(76)
-6	258.7	247	245	246	2 @ 92	191
	(6570.98)	(6273.80)	(6223.00)	[6248.40]	[2336.80]	(87)
-7	298.7	287	285	286	2 @ 106	214
	(7586.98)	(7289.80)	(7239.00)	[7264.40]	[2692.40]	(97)
-7.5	318.7	307	305	306	2 @ 114	226
	(8094.98)	(7797.80)	(7747.00)	[7772.40]	[2895.60]	(103)
-8	338.7 (8602.98) Q-Pulse Id:	327 (8305.80)	325 (8255.00)	326 [8280.40]	2 @ 120 [3048.00]	237 (108)

TEM	QTY	P/N	DESCRIPTION	MATERIAL
1	1	4080020	Shell	Filament Wound, Epoxy FRP
2	2	4080030	Bearing Plate	6061-T6 Aluminum, SB-221, Anodized
3	2	4080177-3	Sealing Plate	Noryl GFN2
4	2	4080250	Feed/Concentrate Port, 1-1/2", "D"	Stainless Steel, 316, SA-312
5	4	6121187	Retaining Ring, F/C Port, 1-1/2", "D"	Stainless Steel, 316, SA-479
6	2	6184604-N	O-Ring Seal, F/C Port, 1-1/2", "D"	Ethylene Propylene
7	2	4080309	Permeate Port	Noryl GFN2
8	2	6100442MK	Head Seal	Ethylene Propylene
9	2	6110229-N	Permeate Port Seal	Ethylene Propylene
10	2	4080320	Retaining Ring w/ Finger Pull	Stainless Steel, 316, SA-479
11	2	6121200	Retaining Ring, Permeate Port	Stainless Steel, 316
12	2*	4080174	Support Saddle	Thermoplastic Rubber
13	2	4080137	Strap Assembly	Stainless Steel, 316L
14	4	6150001	Strap Screw	Stainless Steel, 18-8
15	2	A/R	Adapter	Thermoplastic
16	1	4080165-1	Thrust Cone	PVC Thermoplastic
17	2	6110326-N	Adapter Seal	Ethylene Propylene
18	A/R	A/R	PWT Seal	Ethylene Propylene
19	3	4080062-4	Shim, Adapter	Noryl GFN2

Active: 12/10/2015

		DIMENSIONS IN INCHES (MM APPROX.)					
		FOR REFERENCE ONLY, NOT FOR CONSTRUCTION UNLESS CERTIFIED					
		SHIMMING OF THE S	SADDLES MAY BE REQUIRE	ED			
		CENTER VESSEL OF	N 2 OR 3 SUPPORTS AT SPA	AN(S) "S".			
		INCORRECT MANIFOLDING WILL CAUSE SEVERE LOCAL STRESS AROUND PORT AND MAY RESULT IN LEAKS AND PREMATURE FAILURE. TAKE EVERY PRECAUTION LISTED IN THE ENGINEERING PACKET OR USERS MANUAL.					
LENNI	IECH	INTERNAL PERMEAT	E PRESSURE MUST NOT E	EXCEED 125 PSI.			
info@lenntech.com		ASME SECTION X, 2010 RP CODE STAMP OPTIONAL					
Tel. +31-15-	261.09.00	SPECIFICATIONS SUBJECT TO CHANGE WITHOUT NOTICE					
Fax. +31-15-261.62.89			O PRO	TEC sawa			
	APPROVED AP 12/1/00	PR	0 8-4	50-SP			
	CHECKED AP 12/1/00						
	DRAWN AP	ECO	REVISED	DRAWING	REV		
	12/1/00	10119	4/28/11	101003	U		

101003 Page 120 of 120

NOTES: