

# HEAT EXCHANGERS HANDOVER PACKAGE Oxley WRP

**Document No:** JHG-8543-HOP-001

Controlled Copy

No:

1

Revision: B

**Date:** 11 JULY 2012



### OXLEY WRP - HEAT EXCHANGERS - HANDOVER PACKAGE

### Revision List

Draft/tender issues of this document shall be identified as Revision A, B, C, etc. Upon initial issue (generally Contract Award) this shall be changed to a sequential number commencing at Revision 0

All copies shall be distributed in accordance with the Distribution List. On receipt of a revision, the copy holder shall incorporate the revised pages into their copy of the document. The document shall be subject to reissue after a practical number of changes have been made.

Date	Rev	Details	Sect.	_Page	Auth. (Initial)
21 <sup>st</sup> May 2012	Α	Preliminary Draft	All	All	JB
11 July 2012	B	FOR ISSUE	ALL	ALL	Ma

### Approval

20	Name	Signature	Date
JHG	Tate Brammer	OFFIN-	11/4/12
JHG	Mason Grieco	1100	11/7/12

### **Distribution List**

	Name	Hard Copy	Soft Copy	Signature	Date
QUU	Paul Fisher	1	1		
JHG	Mason Grieco	1	1	The second	11/7/12

Revision:

Date: Q-Pulse Id: TMS217

21 May 2012

2 of 661



# **Contents**

# 1. Design Documents

- 1.1. Updated Functional Description
- 1.2.P&ID
- 1.3. General Arrangement Drawings
- 1.4. Electrical Drawings

# 2. Quality Assurance

- 2.1.Inspection & Test Plans, Handover Register & Completion List
- 2.2. Checksheets
  - 2.2.1. Civil Checksheets
  - 2.2.2. Mechanical/Pre-commissioning Checksheets
  - 2.2.3. Electrical Checksheets
  - 2.2.4. FAT Checksheets
  - 2.2.5. SAT Checksheets

### 2.3. Certificates of Compliance

- 2.3.1. Digester Feed Pumps
- 2.3.2. Heat Exchangers
- 2.3.3. Stainless Steel Pipework
- 2.3.4. E&H Instrumentation

# 3. Operation & Maintenance Manuals

- 3.1. Heat Exchangers General Instructions
- 3.2. Digester Feed Pumps CAMBI EZI-Strip Installation, Operation & Maintenance Instructions
- 3.3. Digester Feed Pumps Motovario Use & Maintenance Instructions
- 3.4. Digester Feed Pump Station Pneumatically Actuated Valves Aeon Kempster KV7 Knife Gate Valve Data Sheet
- 3.5. Digester Feed Pump Station Manual Valves Erhard Knife Gate Valve Data Sheet
- 3.6. Digester Feed Pump Flowmeter Endress & Hauser Proline Promag 50

Revision: A

**Date:** 21 May 2012

Q-Pulse ld: TMS217 05/03/2013 3 of 661



### OXLEY WRP - HEAT EXCHANGERS - HANDOVER PACKAGE

- 3.7. Digester Feed Pump Flowmeter Endress & Hauser Cerabar M
- 3.8. Digester Feed Pump Flowmeter Endress & Hauser Temperature Transmitters
- 3.9. Heat Exchangers Endress & Hauser Temperature Transmitters

Revision: A

**Date:** 21 May 2012

Q-Pulse Id: TMS217 05/03/2013 4 of 661

# 1. Design Documents

# 1.1. Updated Functional Description

Oxley WRP		
Functional Specification	Cus	stomer: Queensland Urban Utilities

# Oxley Creek Water Reclamation Plant Sludge Temperature Maintenance & Storage (Heat Exchangers) Functional Specification

W:\PROJ\QLD\NR-Proj\Oxley WWTP\NEW FILING SYSTEM\COMMISSIONING\Functional Specification\Updated Heat Exchangers Functional Description.doc  Author: John Edv				nn Edwards
Rev	Description	Ву	Approved	Date
С	Updated	DJS		28/09/05
D	Updated – Post Software FAT	JE		30/01/06
Е	Updated – Added Sludge and Updated Inlet Works	DP		05/04/07
F	Updated – Changes to Struvite	DP		01/06/07

Oxley WRP	
Functional Specification	Customer: Queensland Urban Utilities

### 1.1. Sludge Temperature Maintenance & Storage

Hydrolysed sludge from the Flash Tank is pumped by the duty/duty/standby Digester Feed Pumps 01, 02 & 03, part of the Thermal Hydrolysis Unit (THU), to the parallel duty/duty Post Thermal Hydrolysis Heat Exchangers 01 & 02, HX-626-01/02 then on to the 4 number digesters.

The digester feed pumps speeds are controlled via a PID control loop to maintain a combined sludge flow rate set point. This combined flow is divided between the online/available heat exchangers by an operator adjustable digester feed pump ratio set point in the CAMBI PLC. Pumping occurs when the level in the flash tank is above a low fill level.

The Heat Exchangers, tube in tube, will be controlled by the plant control system. On each Heat Exchanger (HX) there is modulating valve on the service water outlet line. This valve operates via a PID control loop to maintain a sludge outlet temperature set point.

In Pulper Feed Mode 1, Hot sludge from thermal hydrolysis is pumped out at between 80-100°C and is cooled in the main sludge heat exchanger to between 40-50°C. The sludge digesters operate at 35-37°C. As such the existing heat exchanger arrangement on each digester will be modified to cool the sludge as required.

In Pulper Feed Mode 2, Sludge is fed directly to the Digesters. In this case, the existing heat exchanger arrangement on the digesters will be modified to heat the sludge to the required temperature.

During the transition between Pulper Feed Modes, there may be a requirement for Pulper Feed Mode 2, but to have the Digesters in a cooling mode. As a result, the operation of Digester Temperature control will be operator selectable via SCADA.

### 1.1.1. Equipment List

# 1.1.1.1. Post Thermal Hydrolysis Sludge Cooling and Distribution

Tag	Equipment	Range	Туре	Make & Model	Comment
TT-626-01	Heat Exchanger 1 Service Water Return Temperature Transmitter				
TT-626-02	Heat Exchanger 2 Service Water Return Temperature Transmitter				
TT-626-04	Heat Exchanger 1 Sludge Output Temperature Transmitter				

	OJ\QLD\NR-Proj\Oxley WWTP\NEW FILING SYSTEM\COMMISSIONING\Functional cation\Updated Heat Exchangers Functional Description.doc	Page 2 of 9	Author: Jo	hn Edwards
Rev	Description	Ву	Approved	Date
С	Updated	DJS		28/09/05
D	Updated – Post Software FAT	JE		30/01/06
Е	Updated – Added Sludge and Updated Inlet Works	DP		05/04/07
F	Updated – Changes to Struvite	DP		01/06/07
G	Updated – changes to service water system	GF		02/02/12

Oxley WRP	
Functional Specification	Customer: Queensland Urban Utilities

TT-626-06	Heat Exchanger 2 Sludge Output Temperature Transmitter		
FCV-626-04	Heat Exchanger 1 Cooling Water Control Valve		
FCV-626-06	Heat Exchanger 2 Cooling Water Control Valve		
HV-626-11	Thermal Hydrolysis Heat Exch. 1 Inlet Valve		
HV-626-25	Thermal Hydrolysis Heat Exch. 2 Inlet Valve		
FIT-626-05	Digesters Sludge Flow Transmitter		
FCV- 626-90	Heat Exchanger 1 Service Water Auto Flush Inlet valve		
FCV-626-14	Heat Exchanger 1 Automatic Flush Drain Valve		
FCV-626-13	Heat Exchanger 1 Sludge Outlet Automatic Valve		
FCV- 626-94	Heat Exchanger 2 Service Water Auto Flush Inlet valve		
FCV-626-24	Heat Exchanger 2 Automatic Flush Drain Valve		
FCV-626-23	Heat Exchanger 2 Sludge Outlet Automatic Valve		

### 1.1.1.2. Process instrumentation

# **1.1.1.2.1.** Post Thermal Hydrolysis Heat Exchanger Temperature *Transmitters: TT-626-01/02/04/06*

These temperature transmitters measure sludge temperature and drainage service water temperature of the two post thermal hydrolysis heat exchangers. These devices operate as Standard Process Analogues, and shall be controlled as outlined in the functional standards. The process value of this device is filtered and is scaled from 0 to 100°C.

## 1.1.1.2.2. Digesters Sludge Flow Transmitter: FIT-626-05

This flow transmitter measures the amount of sludge being fed into the four digesters. This device operates as a Standard Flowmeter, and shall be controlled as outlined in the functional standards. The process value of this device is filtered and scaled from 0 to 10 L/s.

W:\PROJ\QLD\NR-Proj\Oxley WWTP\NEW FILING SYSTEM\COMMISSIONING\Functional Specification\Updated Heat Exchangers Functional Description.doc			age 3 of 9		Author: Joh	nn Edwards
Rev	Description		Ву	Α	pproved	Date
С	Updated		DJS			28/09/05
D	Updated – Post Software FAT		JE			30/01/06
Е	Updated – Added Sludge and Updated Inlet Works		DP			05/04/07
F	Updated – Changes to Struvite		DP			01/06/07
G	Updated – changes to service water system		GF			02/02/12

Oxley WRP	
Functional Specification	Customer: Queensland Urban Utilities

# 1.1.1.2.3. Thermal Hydrolysis Heat Exchanger Inlet Valves: HV-626-11/21

The two post thermal hydrolysis heat exchangers are equipped with hand valves that have position feedback switches. These devices operate as Standard Process Digital Inputs, and shall be controlled as outlined in the functional standards.

### 1.1.1.3. Controlled Equipment

# 1.1.1.3.1. Post Thermal Hydrolysis Heat Exchanger Cooling Water Control Valves: FCV-626-04/06

These flow control valves control the amount of cooling water used by the two heat exchangers. These devices operate as Standard Modulating Control Valves, and are controlled as outlined in the functional standards.

# 1.1.1.1.1. Heat Exchanger 1 and 2 Service Water Flush Inlet Valves: FCV-626-90/94

These valves control the inlet service water for the automatic flush on the sludge side of the heat exchangers. These devices operate as Standard Control Valves, and are controlled as outlined in the functional standards.

# 1.1.1.1.2. Heat Exchanger 1 and 2 Automatic Flush Drain Valves: FCV-626-14/24

These valves control the drainage for the automatic service water flush on the sludge side of the heat exchangers. These devices operate as Standard Control Valves, and are controlled as outlined in the functional standards.

# 1.1.1.1.3. Heat Exchanger 1 and 2 Sludge Outlet Automatic Valves: FCV-626-13/23

These valves control the sludge outlet from the heat exchangers. These devices operate as Standard Control Valves, and are controlled as outlined in the functional standards.

	DJ\QLD\NR-Proj\Oxley WWTP\NEW FILING SYSTEM\COMMISSIONING\Functional cation\Updated Heat Exchangers Functional Description.doc				Author: John Edwards	
Rev	Description		Ву	Α	pproved	Date
С	Updated		DJS			28/09/05
D	Updated – Post Software FAT		JE			30/01/06
E	Updated – Added Sludge and Updated Inlet Works		DP			05/04/07
F	Updated – Changes to Struvite		DP		•	01/06/07
G	Updated – changes to service water system		GF			02/02/12

Oxley WRP	
Functional Specification	Customer: Queensland Urban Utilities

### 1.1.2. Automatic Control

### 1.1.2.1. Post Thermal Hydrolysis Sludge Cooling

Service water for cooling is supplied to each online/available heat exchanger. There are two heat exchangers which require a number of permissive. For Heat Exchanger 01A (HX-626-01A) the following permissives must be confirmed for the unit to be available:

- Inlet Hand Valve in Open Position ZSO-626-611
- Temperature Transmitter on cooling water outlet available TT-626-01
- Temperature Transmitter on Sludge outlet available TT-626-04
- Flow control valve on discharge of sludge is available FCV-626-13
- Dilution water valve are available— FCV-626-90 and FCV-626-14
- Flow control valve on cooling water discharge (FCV-626-04) available

NB: The same permissives are also required for Heat Exchanger 02A with the associated equipment.

A heat exchanger can be set online and offline by the operator. A heat exchanger will only be able to be put online if the above permissives are confirmed.

This flow is controlled on the down stream side of the service water flow from the HX via a control valve FCV62604 and FCV62606. Note that FCV62604 and FCV62606 should be slow closing to prevent water hammer. The valve position is controlled to maintain a temperature set point in the 'cooled' sludge line. That is:

- TIC62604 controls FCV62604 via a PID control loop and
- TIC62606 control FCV62606 via a PID control loop.

Three interlocks will be sent to the Thermal Hydrolysis PLC to prevent hydrolysed sludge being pumped from the flash tanks.

Tag	Туре	Purpose
dcFeedPump1IL	Boolean	PU401 Interlock
dcFeedPump2IL	Boolean	PU402 Interlock
dcFeedPump3IL	Boolean	PU403 Interlock

These interlocks will be set high to prevent the pumps from operating. The interlocks will operate on any of the following conditions:

- The associated heat exchanger inlet hand valve is not confirmed open, HV-626-11 for PU401 or PU402 (if pumping to HX-626-01A), HV-626-21 for PU403 or PU402 (if pumping to HX-626-02A) OR
- Any of the associated heat exchangers sludge or service water temperature high levels are reached OR
- None of the digester inlet control valves are open

	OJ\QLD\NR-Proj\Oxley WWTP\NEW FILING SYSTEM\COMMISSIONING\Functional cation\Updated Heat Exchangers Functional Description.doc	\Functional Page 5 of 9			Author: John Edwards	
Rev	Description		Ву	Ap	proved	Date
С	Updated		DJS			28/09/05
D	Updated – Post Software FAT		JE			30/01/06
Е	Updated – Added Sludge and Updated Inlet Works		DP			05/04/07
F	Updated – Changes to Struvite		DP			01/06/07
G	Updated – changes to service water system		GF			02/02/12

Oxley WRP	
Functional Specification	Customer: Queensland Urban Utilities

May need to add min, max speed and flows for controller on Digester feed pumps now that capacity has been doubled. TB

## 1.1.1.2. Post Thermal Hydrolysis Sludge Cooling – Automatic Flush

When feed to a heat exchanger is stopped and the heat exchanger is taken offline an automatic flush will be completed for an operator adjustable duration. The sequence will operate as follows:

- 1. Confirm Associated digester feed pump has stopped (PU-625-401, PU-625-402 or PU-625-403) and associated digester feed pump discharge valves are in closed postion (FCV-625-423/433/434/435).
- 2. Wait 5 seconds and Close associated Heat Exchanger sludge discharge valve (FCV-626-13 or FCV-626-23).
- 3. When Close feedback position has been confirmed on associated heat exchanger sludge discharge valve, Open the associated Heat Exchanger Automatic Flush Drainage Valve (FCV-626-14 or FCV-626-24).
- 4. When Open feedback position has been confirmed on associated Automatic Flush Drainage Valve, Open the associated Heat Exchanger Service Water Flush Inlet Valve (FCV-626-90 or FCV-626-94).
- 5. Run flush for operator adjustable Heat Exchanger Flush Timer.
- 6. When Timer has expired, Close Heat Exchanger X Service Water Flush Inlet Valve (FCV-626-90 or 94).
- 7. When Closed feedback has been confirmed, wait 20 seconds and then close Heat Exchanger X Automatic Flush Drainage Valve (FCV-626-14 or 24).

This flush can also be triggered manual by the operator if the associated equipment including heat exchanger and pump are confirmed offline.

### 1.1.2.2. Post Thermal Hydrolysis Sludge Distribution

The system shall be set such that the flow reading used for digester feed control can be either:

- Mode 1, Digester Inlet: The value from FIT62605
- Mode 2, Heat Exchanger Inlet: The sum of the values from FIT-625-410, FIT-625-409 and FIT-625-408 (THU PLC). Only utilising flowmeters associated with pumps selected for duty.

In the event that FIT62605 faults, and digester feed is mode 1, then operation should continue using mode 2. These flows will be sent from the THU PLC to the sludge PLC.

	DJ\QLD\NR-Proj\Oxley WWTP\NEW FILING SYSTEM\COMMISSIONING\Functional cation\Updated Heat Exchangers Functional Description.doc				Author: John Edwards	
Rev	Description		Ву	Α	pproved	Date
С	Updated		DJS			28/09/05
D	Updated – Post Software FAT		JE			30/01/06
Е	Updated – Added Sludge and Updated Inlet Works		DP			05/04/07
F	Updated – Changes to Struvite		DP		•	01/06/07
G	Updated – changes to service water system		GF			02/02/12

Oxley WRP	
Functional Specification	Customer: Queensland Urban Utilities

Tag	Туре	Purpose
dsFIT409Avail	Boolean	FIT409 Available status
dsFIT408Avail	Boolean	FIT408 Available status
dsFIT410Avail	Boolean	FIT410 Available status
asFIT409Flow	REAL	FIT409 Flow
asFIT408Flow	REAL	FIT408 Flow
asFIT410Flow	REAL	FIT410 Flow

In this system there is a flow setpoint for each digester:

- Digester 1 Feed Interval Flow Set point (m3).
- Digester 2 Feed Interval Flow Set point (m3).
- Digester 3 Feed Interval Flow Set point (m3).
- Digester 4 Feed Interval Flow Set point (m3).

Under normal circumstances these values should be equal. They should also be set such that the period between switching between digesters is reasonable (e.g. 10 minutes approx).

In mode 1 the sequence is as follows:

- 1. Digester 1 Feed Control Valve FCV62613 is open (confirmed by ZO62613)
- 2. Digester Feed pumps are running
- 3. FIQ62605 starts an interim totaliser
- 4. When the interim totaliser reaches the Digester 1 Feed Interval Flow Set point,
- 5. Digester 3 Feed Control Valve FCV62615 opens, when this is confirmed by ZO62615
- 6. Then Digester 1 Feed Control Valve FCV62613 closes (confirmed by ZC62613), when this is confirmed then
- 7. FIQ62605 starts a new interim totaliser
- 8. When the totaliser reaches the Digester 3 Feed Interval Flow Set point,
- 9. Digester 2 Feed Control Valve FCV62614 opens, when this is confirmed by ZO62614
- 10. Then Digester 3 Feed Control Valve FCV62615 closes (confirmed by ZC62615), when this is confirmed then
- 11. FIQ62605 starts a new interim totaliser
- 12. When the totaliser reaches the Digester 2 Feed Interval Flow Set point (m3).
- 13. Digester 4 Feed Control Valve FCV62616 opens, when this is confirmed by ZO62616
- 14. Then Digester 2 Feed Control Valve FCV62613 closes (confirmed by ZC62613), when this is confirmed then
- 15. FIQ62605 starts a new interim totaliser
- 16. When the totaliser reaches the Digester 4 Feed Interval Flow Set point,
- 17. Digester 1 Feed Control Valve FCV62613 opens, when this is confirmed by ZO62613
- 18. Then Digester 4 Feed Control Valve FCV62616 closes (confirmed by ZC62616), when this is confirmed then the sequence recommences.

If any of the digesters are unavailable the sequence skips to the next digester.

For mode 2, the sequence operates in the same manner. The only difference being that FIT-625-401/402 will be used to totalize flow to the digesters.

	DJ\QLD\NR-Proj\Oxley WWTP\NEW FILING SYSTEM\COMMISSIONING\Functional cation\Updated Heat Exchangers Functional Description.doc				Author: John Edwards	
Rev	Description		Ву	Α	pproved	Date
С	Updated		DJS			28/09/05
D	Updated – Post Software FAT		JE			30/01/06
Е	Updated – Added Sludge and Updated Inlet Works		DP			05/04/07
F	Updated – Changes to Struvite		DP			01/06/07
G	Updated – changes to service water system		GF			02/02/12

Oxley WRP	
Functional Specification	Customer: Queensland Urban Utilities

# 1.1.3. Setpoints

Setpoint Description	Default Value	Security Level
TT-626-01 High	-	Operator
TT-626-01 Low		
TT-626-02 High		
TT-626-02 Low		
TT-626-04 High		
TT-626-04 Low		
TT-626-06 High		
TT-626-06 Low		
Heat Exchanger 1 Temperature Set Point		
Heat Exchanger 2 Temperature Set Point		
Digester Feed Pump Mode		
Digester Feed Flow Mode		
Digester 1 Feed Interval Flow Set Point		
Digester 2 Feed Interval Flow Set Point		
Digester 3 Feed Interval Flow Set Point		
Digester 4 Feed Interval Flow Set Point		

## 1.1.4. Process Alarms and Interlocks

# 1.1.4.1. Post Thermal Hydrolysis Heat Exchanger Drainage Temperature Alarms

Tag	Equipment	Action
TT-626-01	Heat Exchanger 2 Outlet	Raise Alarm
11-020-01	Temperature Transmitter	Raise Alaitii
TT-626-02	Heat Exchanger 1 Outlet	Daiga Alarm
11-020-02	Temperature Transmitter	Raise Alarm

Alarms will be raised on Invalid, High and High High conditions. The High High condition will also interlock the corresponding hydrolysed sludge feed pump PU401/402. These are Priority 6 Alarms.

# 1.1.4.2. Post Thermal Hydrolysis Heat Exchanger Drainage Temperature Alarms

Tag	Equipment	Action
TT-626-04	Heat Exchanger 1 Sludge Output Temperature Transmitter	See Below
TT-626-06	Heat Exchanger 2 Sludge Output Temperature Transmitter	See Below

	DJ\QLD\NR-Proj\Oxley WWTP\NEW FILING SYSTEM\COMMISSIONING\Functional cation\Updated Heat Exchangers Functional Description.doc	Page 8 of 9			Author: John Edward		
Rev	Description		By Approved			Date	
С	Updated		DJS			28/09/05	
D	Updated – Post Software FAT		JE			30/01/06	
E	Updated – Added Sludge and Updated Inlet Works		DP			05/04/07	
F	Updated – Changes to Struvite		DP		•	01/06/07	
G	Updated – changes to service water system		GF			02/02/12	

Oxley WRP	
Functional Specification	Customer: Queensland Urban Utilities

Alarms will be raised on Invalid, Low, High and High High conditions. The High High condition will also interlock the corresponding hydrolysed sludge feed pump PU401/402. These are Priority 6 Alarms.

# 1.1.4.3. Post Thermal Hydrolysis Heat Exchanger Control Valves

Tag	Equipment	Action
FCV-626-04	Heat Exchanger 1 Cooling Water Control Valve	Raise Alarm
FCV-626-06	Heat Exchanger 2 Cooling Water Control Valve	Raise Alarm
FCV- 626-90	Heat Exchanger 1 Service Water Auto Flush Inlet valve	Raise Alarm
FCV-626-14	Heat Exchanger 1 Automatic Flush Drain Valve	Raise Alarm
FCV-626-13	Heat Exchanger 1 Sludge Outlet Automatic Valve	Raise Alarm
FCV- 626-94	Heat Exchanger 2 Service Water Auto Flush Inlet valve	Raise Alarm
FCV-626-24	Heat Exchanger 2 Automatic Flush Drain Valve	Raise Alarm
FCV-626-23	Heat Exchanger 2 Sludge Outlet Automatic Valve	Raise Alarm

These alarms will be generated when the valve fails to position. These are Priority 6 Alarms.


### 1.1.4.4. DWAS Flow Indicator


Tag	Equipment	Action
FIT-626-05	Digesters DWAS Flow	Raise Alarm.
111-020-03	Transmitter	Naise Alaitii.

This alarm will be generated when the flow becomes high or invalid. These are Priority 6 Alarms.


	OJ\QLD\NR-Proj\Oxley WWTP\NEW FILING SYSTEM\COMMISSIONING\Functional cation\Updated Heat Exchangers Functional Description.doc	Page 9 of 9			Author: Joh	nn Edwards
Rev	Description		Ву	Α	pproved	Date
С	Updated		DJS			28/09/05
D	Updated – Post Software FAT		JE			30/01/06
E	Updated – Added Sludge and Updated Inlet Works		DP			05/04/07
F	Updated – Changes to Struvite		DP			01/06/07
G	Updated – changes to service water system		GF			02/02/12
					D : ( )	00/00/40


# 1.2. P&ID








# 1.3. General Arrangement Drawings

















# 1.4. Electrical Drawings





# 2. Quality Assurance

2.1. Inspection & Test Plans, Handover Register& Completion List



			Verifying			Verify or Te	st by							
Item No.	Activity Details	Reference Procedure	Document of Report incl check sheet number. Refer to handover register.	JHG				QUU		Remarks/Records				
		Trocedure		Key	Resp.	Sign/Date	Key	Sign/Date						
1.01	Ensure Civil Installation Check Sheets are complete					JB 11/6								
			Refer to handover register.			JB 111	6			Pump	CURVE	5 70		
	Mechanical Pump & Heat Exchangers Installation Check		Refer to handover register.			OPS 11	1			BE	COMP	CETED		
	Sheets are complete (PU-625-401, PU-625-402, PU-625-403, HX-626-		Refer to handover register.			TTO W	6			ON	SLUL	4E.		
	01, HX-626-02)		Refer to handover register.			JB 12/6								
_			Refer to handover register.			FB 12/6								
	Check sheets are complete		Refer to handover register.			JB11/6								
	Mechanical Instrument Installation Check sheets are complete		Refer to handover register.			B 11/6								
2.04	Mechanical Pipework Installation Check sheets are complete		Refer to handover register.			JB 11/6								
3.01	Electrical Check Sheets Complete	Refer to reference Electrical.	Refer to handover register.			JB 11/6								
4.01	Energisation of equipment	Refer to engergisation procedure.	Refer to handover register.			JB 11/6								
5.01	Control System FAT complete		Insert commissioning ITP reference.			JB 11/6			CON!	ROL SYST AVAILABLE ST MODE.	EM FAT O DUE TO	N DIGESTER FEED PS CAMBI PLC CODE HAVIN		

	INSPECTION AND	TEST PLAN	Document Title	HEAT EXCHANGE	loba	
ITP No:	8453-001-HX	Project:	Oxley WRP Flood Recovery	Inspection Key: W -	Responsibility Key: SV- Supervisor, SV-	
Revision:	A	Project Number:	8543	Witness, H - Hold, S -	Surveyor, PE – Project Engineer Sup-	HOIGING
Date of Issue: 01	01.06.12	Approved by:		Surveillance	Superintendent PM- Project Manager	

		Reference Procedure	Verifying			Verify or Te	st by		
Item No.	Activity Details		Document of Report incl check	JHG				QUU	Remarks/Records
		Tiocedale	sheet number.	Key	Resp.	Sign/Date	Key	Sign/Date	
6.01	HANDOVER from Construction to Commissioning Certificates Complete		Refer to handover register.			1811/6			
7.01	Pre-commissioning Checks Complete		Insert commissioning ITP reference.			JB 11/6			
8.01	Control System SAT complete		Insert commissioning ITP reference.			tas in	6		

		F	INAL APPROVAL FOR CLOSE OUT OF ITP	
		NAME	SIGNATURE	DATE
JH	TATE	BRAMMER	The	11/6/12

# Heat Exchanger/Digester Feed Pump Station Mech/Elec and Energisation Register

9: 07/03/2012 New: A

Novi	TAG		MECH	ANICAL		ELEC	TRICAL		ENERGISATION						
Item	P&ID	Prefix	Number	Description	Mech Complete Sign	LOT. No.	Date	Elec Complete Sign off	Doc. No.	Date	Equipment Energised	Doc. No.	Date	Handover to Commissioning	Date
1	R7W105	PU		Digester feed pump 01	8543-M-HX-001	JB	11/6	8543-E-HX-001	NO.	116	7796	NA	NA	175	11/4/13
2	R7W105	PU	625-402	Digester feed pump 02	8543-M-HX-002	3B	uls	11	ND	116	11	11	u	- [1	1/1
3	R7W105	PU	625-403	Digester feed pump 03	8543-M-HX-003	33	11/6	H	TO	4/6	Н	11	11	(	Ч
4	R7W105	FCV	625-423	Pneumatic ON/OFF valve after digester feed pump 1	9543-M-HX-100	JB	11/6	ч	NO	(1/6	ч	11			1
5	R7W105	FCV	625-435	Pneumatic ON/OFF valve after digester feed pump 3	8543-M-HX-101	38	1 11/6	11		11/6	11	- h	1	11	H
- 6	R7W105	FCV	625-433	Pneumatic ON/OFF distribution valve for pump 2 to HX 1	8543-M-HX-102	<b>IB</b>	14/6	11		11/6	ι(	- 1(	(1	11	и
7	R7W105	FCV	625-434	Pneumatic ON/OFF distribution valve for pump 2 to HX 2	8543-M-HX-103	JB	11/6	N Total		11/6	11	11 11	11	U U	1(
	R7W105	FIT	625-409	Flow transmitter after digester feed pump 1	8543-M-HX-200	38	11/6	1	(K)	11/6	l(	- 11		(†	11
0	R7W105	FIT	625-408	Flow transmitter after digester feed pump 2	8543-M-HX-201	38	116	15	12	11/6	- 11	H	11		u
10	R7W105	FIT	625-410	Flow transmitter after digester feed pump 3	8543-M-HX-202	33	116	11	(Jac	11/6	1(	- ((	11	(1	1(
11	R7W105	PIT	625-405	Pressure transmitter after digester feed pump 1	8543-M-HX-203	38	11/6	11	(1)	1166	11	- 11	11	11	11
12	R7W105	PIT	625-413	Pressure transmitter after digester feed pump 2	8543-M-HX-204	18	11/6	11	(19)	11/6	11	H	11		11
13	R7W105	PIT		Pressure transmitter after digester feed pump 3	8543-M-HX-205	33	11/6	H	N	116		1	11	Щ	- 11
14	R7W105	TIT	625-406	Temperature transmitter after digester feed pump 1	8543-M-HX-206	13	uc	11	(ND)	11/6	11	- 11	- ((	<u>(1</u>	11
15	R7W105	TIT	625-412	Temperature transmitter after digester feed pump 2	8543-M-HX-207	JB	116	11	Q	11 18	1(		11	11	11
15	R7W105	TIT	625-418	Temperature transmitter after digester feed pump 3	8543-M-HX-208	JB	1176	JI .	ND	11/6	it	l/	- 11		- 11
17	R7W105	HV	625-419	ON/OFF valve before digester feed pump 1	8543-M-HX-300	JB	C.C	NA	NA	NA	NA	NA	NA	(I	- 11
18	R7W105	HV	625-424	ON/OFF valve before digester feed pump 2	8543-M-HX-301	JB	H	- 11	-	<u></u>		4-		ļ(	
10	R7W105	HV	625-427	ON/OFF valve before digester feed pump 3	8543-M-HX-302	JB	11	11	-			_	-	11	11
20	R7W105	HV	625-416	Instrument valve on PIT-625413	8543-M-HX-500	1B	ii	1/	-					![	1
21	R7W105	HV	625-418	Instrument valve on PIT-625405	8543-M-HX-500	18	- 11	J <sub>1</sub>	-	_			_	W.	- 11
22	R7W105	HV	625-417	Instrument valve on PIT-625419	8543-M-HX-500	JB	И	11		-				!!	
23	R7W105	HV	625-420	Flushing and sampling point	8543-M-HX-500	IB	11	H		-			-	I I	
24	R7W105	HV		Flushing and sampling point	8543-M-HX-500	JB	U	ł†	-					11	11
25	R7W105	HV	-	Flushing and sampling point	8543-M-HX-500	3B	- 11	1(	_	-	-		-	u u	
26	R7W105	HV	625-426	Flushing and sampling point	8543-M-HX-500	JB	H	11	_	-			-	<u> </u>	
27	R7W105	HV	625-437	Flushing and sampling point	8543-M-HX-500	B	И	11	-	-			-	it	1 11
28	R7W105	HV	625-428	Flushing and sampling point	8543-M-HX-500	JB	H	1(		-				[(	
29	R7W105	HV	625-429	Flushing valve on level transmitter	8543-M-HX-500	dB	11	1(	-	-			-	1	1(
30	R7W105	HV		ON/OFF valve after digester feed pump	8543-M-HX-303	JB	ļļ .	N	-	_	~		-	<u> </u>	11
31	R7W105	HV		ON/OFF valve after digester feed pump	8543-M-HX-304	33	11	11	-	-	-		-	. 4	11

8543-M-HX-500

JB

R7W105

HV

625-436 Flushing and sampling point

Oxley Creek STP ST22 Sludge Treatment (Heat Exchangers) General

# Heat Exchanger/Digester Feed Pump Station Mech/Elec and Energisation Register e: 07/03/2012 A

		<u> </u>			Mech Complete Sign			Elec Complete Sign							
Item	P&ID	Prefix	Number	Description	off	LOT. No.	Date	off	Doc. No.	Date	Equipment Energised	Doc. No.	Date	Handover to Commissioning	Date
									_	1	$\nabla$ 7		1-1-1		11/
33	R7D177	НХ	626-01	Post TH Heat Exchanger 1	8543-M-HX-004	38	11/6	8543-E-UX-001		11/6	THE	NA	11/6/12	TEB	11/6/1:
34	R7D177	НХ	626-02	Post TH Heat Exchanger 2	8543-M-HX-005	38	11/6	- 11	100	11/6	u	(	/ L(	ı(	/11/
35	R7D177	FCV	626-04	THSC H-Exch 1 SW to Drain FCV	8543-M-HX-104	<b>JB</b>	11/6	(1	(D)	1116	(1	, u	11		11
36	R7D177	FCV	626-06	THSC H-Exch 2 SW to Drain FCV	8543-M-HX-105	38	11/6	1(	Œ	11/6	1(		а		111
37	R7D177	FCV	626-13	THSC H-Exch 1 Sludge Out Isol.	8543-M-HX-501	JB	14/6	H	(2)	11/6		11		- 1	11
38	R7D177	FCV	626-23	THSC H-Exch 2 Sludge Out Isol.	8543-M-HX-309	JB	11/6	1(	(60)	11/6		11	11	11	- 11
39	R7D177	FCV	626-90	THSC H-Exch 1 SW Flush Inlet FCV	8543-M-HX-104	JB	146	11	W	116		11	11	11	- U
40	R7D177	FCV	626-94	THSC H-Exch 2 SW Flush Inlet FCV	8543-M-HX-105	JB	11/6		HH	11/6		11	11	- 0	11
41	R7D177	FCV	626-14	THSC H-Exch 1 SW Flush Outlet FCV	8543-M-HX-501	JB	W6	11	Phi.	11/6		4	- 11	1	- (1
42	R7D177	FCV	626-24	THSC H-Exch 2 SW Flush Outlet FCV	8543-M-HX-309	38	116	1(	(F)	116		и	11	l1	- "
37	R7D177	π	626-01	Heat Exchanger 1 SW Outlet Temperature	8543-M-HX-209	38	116	16	(10)	11/6		- Il	11	(I	- 11
38	R7D177	π	626-02	Heat Exchanger 2 SW Outlet Temperature	8543-M-HX-210	<b>I</b> B	u/6	И	400	11/6	1(	11	ll l	u	1(
39	R7D177	П	626-04	Heat Exchanger 1 Sludge Output Temperature	8543-M-HX-211	AR	116	[1]	(V)	11/6	11	u	11	<u>t</u>	- 11
40	R7D177	IT	626-06	Heat Exchanger 2 Sludge Output Temperature	8543-M-HX-212	JB	u.L	Н	<b>X</b>	1/6	11	и	1	K	- !!
41	R7D177	HV	626-10	THSC H-Exch 1 & 2 Cl dosing line flush/bleed point	8543-M-HX-501	JB	ülb	N/A	40	-	(	"	11		I
42	R7D177	HV	626-11	THSC H-Exch 1 Sludge In Isol.	8543-M-HX-305	28	1	8543-E-HX-001	K)	1116	[[	- 11	ll l	· · · · · · · · · · · · · · · · · · ·	11
43	R7D177	HV	626-12	THSC H-Exch 1 Sludge in Flush	8543-M-HX-501	35	L	NA	NA	NA	tl	11	11		H
46	R7D177	HV	626-15	THSC H-Exch 1 Sludge Out Drain Valve 1	8543-M-HX-501	JB	u	11	((	1		11	- 11	W .	u
47	R7D177	HV	626-16	THSC H-Exch 1 SW in isol.	8543-M-HX-306	JB	W	11	11	11	· (	- 11	11	li	- 11
48	R7D177	HV	626-17	THSC H-Exch 1 SW In Flush	8543-M-HX-501	JB	II.	11	1(	11		- 11	11		- II
49	R7D177	HV	626-18	THSC H-Exch 1 SW Out Flush	8543-M-HX-501	JB	11	11	11	11	11		11		- (1
50	R7D177	HV	626-19	THSC H-Exch 1 SW Out Isol.	8543-M-HX-501	JB	U	11	- 11	II		li li	1(	<u>"</u>	- "
51	R7D177	HV	626-20	THSC H-Exch Cl dosing bypass valve	8543-M-HX-307	<b>38</b>	II	1)	J.A.	1	- 11	н	- 11	1	11
52	R7D177	HV	626-21	THSC H-Exch 2 Sludge in Isol.	8543-M-HX-308	JB	][	8543-E-HX-001	Ú).	4/6-		u	- 11	II.	- 11
53	R7D177	HV	626-22	THSC H-Exch 2 Sludge In Flush	8543-M-HX-501	38	U	NA	NA	NA	1	U.	N	<u> </u>	U
56	R7D177	HV	626-26	THSC H-Exch 2 SW In Isol.	8543-M-HX-310	IB	N .	11	11	11	(	ti.	- "	Ŭ.	u
57	R7D177	HV	626-27	THSC H-Exch 2 SW In Flush	8543-M-HX-501	JB	И	11	11	11	М	ц	ц	- 11	11
58	R7D177	HV	626-28	THSC H-Exch 2 SW Out Flush	8543-M-HX-501	JB	ıL	11	Jt.	11			11	li .	- 11
59	R7D177	HV	626-29	THSC H-Exch 2 SW Out Isol.	8543-M-HX-501	JB	N	11	11	11	И	ч	11	· · · · · · · · · · · · · · · · · · ·	. 11
60	R7D177	HV	626-30	THSC H-Exch 1 & 2 Cl dosing feed valve	8543-M-HX-502	IB	h	1(		II		и	U	.11	- 1
61	R7D177	HV	626-31	THSC H-Exch 1 & 2 Cl dosing pressure gauge isolation valve	8543-M-HX-502	JB	И	- 11	H	- 11	11	U	- 11	11	H
62	R7D177	HV	626-32	THSC H-Exch 1 & 2 Cl dosing dispenser discharge valve	8543-M-HX-502	TB	И	u	- 10	II	11	ц	111	11	- 11
65	R7D177	PRV	626-01	THSC H-Exch 1 CW Out PRV	8543-M-HX-400	JB	14	11	- 11	11	N	u		IL	1
66	R7D177	PRV	626-02	THSC H-Exch 2 CW Out PRV	8543-M-HX-401	JS	u	(1	[(	11	11	u_	11	II .	- !!
67	R7D177	TI	626-03	Heat Exchanger 1 Sludge Output temp gauge	8543-M-HX-700	33	U	II .	11	11	l l	u _	- 11		- H
68	R7D177	TI	626-05	Heat Exchanger 2 Sludge Output temp gauge	8543-M-HX-700	3B	И	1(	IJ	II		11	11	ll .	1/
69	R7D177	PI	626-90	Heat Exchanger 1 & 2 Chlorine dosing pressure gauge	8543-M-HX-700	1B	M	11	II.	H	10	11	И	t)	111

# 2.2. Checksheets

# 2.2.1. Civil Checksheets

STRUCTURAL CONCRETE			AREA:						NGER			
TP ref. No:	8543-010	Project:	HEATE EXCHANGER UPGRADE 8543				Inches				John	
OT No.	8543-C-HX-001	Project Number:									lity Key: SV- Supervisor, SV-	
ate of Issue:	06.02.12						Surveillance				dent PM- Project Manager	
QUIPMENT D	ESCRIPTION:	Heat Exchanger Ex	tension Slab and Footir	ngs								
Item No.	Activity Details	Reference Document	Acceptance Criteria			erify or Test by						
				Key	S/C Sign/Date	Kov	JH	Sign/Date	Van	QUU Sign/Date	Remarks/Records	
1.00	Start-up checks		-	IXOY	Olginbate	Key	Resp.	Signibate	Ney	Sign/Date		
1.01	Check drawings are latest revisions	Drawings	Visual Inspection		1.0	w	PE	Mh				
1.02	Lot identification and set out	Drawings	Surveyor's set-out		1	W	FM	3/1		1		
1.03	Review approved TRAs and ensure appropriate safety measures are in place	TRA				н	FM	NI			HOLD POINT	
1.04	Check environmental protection measures	SEP	Visual Inspection			н	FM	M	9		HOLD POINT	
	Construction	19	100									
2.01	Check formwork/False work DESIGN	AS3610	Design Engineer Approved			w	PE	Mh			Edge form, no design regral	
2.02		Survey Set-out Drawing	+0mm to -10mm			w	FM	Mh				
2.03	Check erection of formwork and falsework, check dimensions and stability	JHG-2-002-3	Inspect foundation for falsework. Compliance with Designers Drawings & standards as applicable AS1509, AS3610. Toe bracing checked			н	PE	14			Hold POINT Forms inspected	
2.04	Check location and preparation of construction and expansion joints	Drawings				Н	PE	16				

STRUCTURAL CONCRETE			AREA:					NGER			
P ref. No:	8543-010	Project:	HEATE EXCHANGER UPGRADE			lasson	Inspection Key: W - Responsible				
T No.	8543-C-HX-001	Project Number:	8543								lity Key: SV- Supervisor, SV-
ate of Issue:	06.02.12									Superintend	tendent PM- Project Manager
QUIPMENT D	ESCRIPTION:	Heat Exchanger Ext	tension Slab and Footir	ngs							
Item No.	Activity Details	Reference Document	Acceptance Criteria		7.7	erify or Test by					
				Key	S/C Sign/Date	Kev	JH	Sign/Date	Kov	QUU Sign/Date	Remarks/Records
2.05	Reinforcement installation, check line and length	Drawings	As per designed drawings support and tying, cover to be maintained during pour. Crushing of chairs prevented. Inspection completed			н	PE	MG		- Igni sate	HOLD POINT
2.06	Check cast-in items and clock-out alignments and levels	Drawings	As per designed drawings. Visual check			Н	PE	NA			HOLD POINT No Cast Ins
2.07	Concrete Placement, check mix and signoff that correct mix is being delivered	Drawings	N32			н	PE	MG			HOLD POINT - Attach batch records
2.08	On-site concrete testing is performed as required	AS3600/Spec Cl.7.3.3	Check concrete conforms to design requirements (grade temp, slump)			w	FM C	the			Attach test records
2.09	Finishing concrete	Drawings C1351Rev0, C1352Rev0, C1353Rev0 SpecCl7.2.16	Levels as per spec (+10mm to -0mm) Acceptable finish quality			w	FM d	Wh_			
2.1	Check curing application and time is adequate	Spec Cl.7.2.18				w	FM 2	ML	_		
2.11	Stripping of formwork	AS3600-1994 Section 7	24 hours after pour			w	FM	ML			

STRUCTURAL CONCRETE			AREA:						NGER				
TP ref. No:	8543-010	Project:	HEATE EXCHANGER UPGRADE 8543				Inches	Witness, H - Hold, S - Surveyor,			ibility Key: SV- Supervisor, SV-		
OT No.	8543-C-HX-001	Project Number:									onsibility Key: SV- Supervisor, SV- eyor, PE – Project Engineer Sup-		
ate of Issue:	06.02.12						Survei				endent PM- Project Manager		
QUIPMENT D	ESCRIPTION:	Heat Exchanger Exte	ension Slab and Footin	ngs									
	Activity Details	Reference Document	Acceptance Criteria			V	erify or Test by						
Item No.				S/C		JH			QUU		Remarks/Records		
		B LEWIS CO.		Key	Sign/Date	Key	Resp.	Sign/Date	Key	Sign/Date			
2.12	Check as-built survey against design tolerences	Surveyor's sketch Spec CI.7.2.16	Levels as per spec (+10mm to -0mm) Acceptable finish quality			w	PE	M					
2.13	Installation of Joint Sealant	Drawings	Manufacturers specifications			w	PE	14					
2.14	Verify concrete test results	Spec Cl.7.23.3	32MPa compressive strength			w	PE	MG					
3.00	Installation Complete												
3.01	Final inspection		QA records complete ITP stages signed off NCRs dispositioned			Н	PE	16			HOLD POINT - All items completed and all relevand documentation attached		
		NAME	'		APPROVAL								
				SIGN	ATURE	DATE							



NEILSENES GT S122 Sludge Treatment (Heat Exchangers) General ABN 28 055 131 283

NEILSEN'S TECHNICAL SERVICES LABORATORY 39 MICA STREET, CAROLE PARK QLD 4300

PHONE: (07) 3723 8704 FACSIMILE: (07) 3271 2620

liciai	
Reference	No.

eference No.	SOLERER
elerence ivo.	GRA, SA
	161,10

	, 11	1			JOB No.:		U	AB No	<b>e</b>	;	
1. Jedin	Hellow	1.			DATE & DAY			tien	1	70	(12)
				1	DATE & DAY	SAMPLI	ED: I	1 100,7			PLANT: CALLE
ECT ADDRESS:	20. De	matthe,	A.s.t								No. 14
ECT ADDRESS:	0 40 0	and to			TESTING O	FFICER:		7	7		
		e creatines			TIME ARRIV	/AL:	Gam				DEPART: ESSMENT
		تسنند		-			PF	ODU	CHON		LOGINEITI
THER: F	#E	-	Slump (Initial)		-	DATE FOR TESTING		2		EST TYPE (C / FS)	
ode		. O avoto	Slump (Additive)	9	MOULD NUMBER	resi	1 1	AIR CURED (Y / N)	CHARGE REQUEST / QC	0)	REMARKS
	Location o	f Concrete	Concrete Temp.	SPECIMEN No.	N N	DR	4	REC	ARG	14PI	
. Slump			Ambient Temp.	- WE	9	П П	w	CO	E S	ST	
( No.	Delivery I	Docket No.	Sampling Method	PEC	Joh	DAT	AGE	AIR	끮	밑	
Batched	Load	Progressive	Compaction	1	-		1-7		R	1	
sampled	Hari		80	H	101	-	-		1		
12,22,90	Heari exch	′		13	224		21		11	1	
32120	C 7 ( F	4-198		. C	256		28		11	1_	
32/20	1 ./	1	3.3	-	200						
	5.0	16,	3.7		My and		-	-	+	+	
490			7.21							1	
ne 412	5046	509		-							
0-642	2 4	3 5	1.7.3				-	+	+		
0945	3.0							1	+	+	
								1			
				-		+					
						4-	_	+		+	
								11	-	-	
				-	-	+					
	-						_	-	-	+	
											The state of the s
				-		-					
							-+	+	+		
				-							
						+					
							- 3-1		-		
					neistance	est only	y, 7.2.3	- Slov	v disc	charg	e, 7.2.4 - Terminated discharg
	od: AS 1012.1.	7.2.1 - Uninter	pted discharge, 7.	2.2 - Co ions.	onsistence						
Sampling Met	from non-agitat	or units, 7.4 - F	upted discharge, 7. rom specified locat ing 1.7.4 - Vibratior	1, 1.7.5	- Ramming						
Compaction M	athor. ASILIE	.0, 1,1,0					Delaye	d Cur	ing (T		erature & Reason)
	Pick-u	ip & Start Start	Init	ial Curin	g Hours		Max	,	-	Min	
Date	Time	В	V								AC1010 13 AC1012.3 F
				NOTE:	Concrete tes	ted in acc	cordance	with /	AS101	2.1, A	S1012.8, AS1012.13, AS1012.3
								_			
							- 4				ssociation of Testing Authorities

Q-Pulse Id: TMS217

Concrete Test Record Rev. 8 June 2011

Tested By\_

05/03/2013

THIS IS NOT A TAX INVOICE

37 of 661



Neilsen's Technical Services Laboratory

39 Mica St, Carole Park QLD 4300

Phone: (07) 3723 8705 Fax: (07) 3271 2620

# **Concrete Test Report [AS]**

JOHN HOLLAND CONSTRUCTIONS

PO BOX 556

FORTITUDE VALLEY QLD 4006

Project:

Client:

240 DONALDSON RD

**ROCKLEA** 

Report No: CON:W12-00308

Issue No: 1

This report replaces all previous issues of report no 'CON:W12-00308'.



This document is issued in accordance with NATA's accreditation requirements.

Salde unson

NATA Accredited Laboratory Number: 14293

Approved Signatory: Garry Baldwinson

Date of Issue: 12/03/2012 THIS DOCUMENT SHALL NOT BE REPRODUCED EXCEPT IN FULL

#### COMPRESSIVE STRENGTH OF CONCRETE CYLINDERS

#### **Details of Sampled Concrete** Concrete Specimens and Results Date & Time Truck No Plant Name Batched Time Sampled Docket No Product Cod Plant Name Grade(MPa) Air (%) Density Curing Type (kg/m³) Initial Std of (hrs) (days) Cap Dimensions Density Age Strength Marks Fail Location & Remarks Agg(mm) Compact Slump(mm) (days) (MPa) Load / Prog. Product Code Design Measured Diameter Height Sampling AS 1012.1 CI 6b HEAT EXCHANGE SLAB 09/02/12 490 Windsor N32 CA195\A 199 2480 6 S 16/02/12 99.9 22.0 08:42 09:45 5046509 20 CA195\B 100.2 200 2480 27 S 08/03/12 28 36.0 N Concrete Temp. (°C): 33 N32280 3.8/3.8 CA195\C 100.0 199 2500 27 S 08/03/12 28 38.0

#### Notes

Sampling in accordance with AS 1012.1
 Slump Test in accordance with AS 1012.3.1
 Compaction by rodding, in accordance with AS 1012.8.1 Clause 7.3
 Initial Curing in accordance with AS 1012.8.1 Clause 9.2.2
 Standard Curing in accordance with AS 1012.8.1 Clause 9.3(a)
 Capping R - Rubber, S - Sulphur, G - Ground, D - Double Cap Sulphur

 Compressive Strength in accordance with AS 1012.9
 B. Density in accordance with AS 1012.12.1
 Moisture Condition SSD in accordance with AS 1012.12.1, unless otherwise stated No: 18969.V1.00, Report No: CON:W12-00308

Remarks

FailureMode: N = NORMAL

(c) 2000-2009 QESTLab by SpectraQEST.com

Page 1 of 1

	STRUCTURAL CONCRETE		AREA:					Н	EAT EXCHA	NGER	
P ref. No:	8543-010	Project:	HEATE EXCHANGE	R UPG	RADE	-	I	N 16 18		of Control of Control	
OT No.		Project Number:	8543				Witnes	tion Key: W	S -	Surveyor P	lity Key: SV- Supervisor, SV-
ate of Issue:							Survei		199	Superintend	dent PM- Project Manager
QUIPMENT D	ESCRIPTION:	Heat Exchanger Pli	nths and Digester Feed	Pump	Plinth						
	A-Al-M- Dod- II	Reference	Acceptance			V	erify or 1				
Item No.	Activity Details	Document	Criteria	Key	S/C Sign/Date	Key	JH Resp.	Sign/Date	Kev	QUU Sign/Date	Remarks/Records
1.00	Start-up checks		-							J.g.mouto	
1.01	Check drawings are latest revisions	Drawings	Visual Inspection			w	PE	16			
1.02	Lot identification and set out	Drawings	Surveyor's set-out			w	FM	Mil.		-	
1.03	Review approved TRAs and ensure appropriate safety measures are in place	TRA				н		Mhe			HOLD POINT
1.04	Check environmental protection measures	SEP	Visual Inspection			н	FM	Alle			HOLD POINT
2.00	Construction										
2.01	Check formwork/False work DESIGN	AS3610	Design Engineer Approved			w	PE	MG			
2.02	Check as-built of base/binding layer	Survey Set-out Drawing	+0mm to -10mm			w	FM	Alle			
2.03	Check erection of formwork and falsework, check dimensions and stability	JHG-2-002-3	Inspect foundation for falsework. Compliance with Designers Drawings & standards as applicable AS1509, AS3610. Toe bracing checked			Н	PE	MG			HOLD POINT
2.04	Check location and preparation of construction and expansion joints	Drawings				Н	PE	Mbi			

	STRUCTURAL CONCRETE		AREA:				NGER				
P ref. No:	8543-010	Project:	HEATE EXCHANGE	R UPG	RADE		Inchas	tion Key: W		Dagway siki	John
OT No.	8543-C-HX-002	Project Number:	8543				Witnes	ss, H - Hold,	S-	Surveyor, F	lity Key: SV- Supervisor, SV-
ate of Issue:	17.02.12						Survei			Superinten	dent PM- Project Manager
QUIPMENT I	DESCRIPTION:	Heat Exchanger Plin	nths and Digester Feed	Pump	Plinth						
92	Andludes Date No.	Reference	Acceptance			V	erify or 1				
Item No.	Activity Details	Document	Criteria	Key	S/C Sign/Date	Kev	JH Resp.	Sign/Date	Key	QUU Sign/Date	Remarks/Records
2.05	Reinforcement installation, check line and length	Drawings	As per designed drawings support and tying, cover to be maintained during pour. Crushing of chairs prevented. Inspection completed			Н	PE	MG			HOLD POINT
2.06	Check cast-in items and clock-out alignments and levels	Drawings	As per designed drawings. Visual check	H		н	PE	MG			HOLD POINT
2.07	Concrete Placement, check mix 7 and signoff that correct mix is being delivered	Drawings	N32			н	PE	MG			HOLD POINT - Attach batch records
2.08	On-site concrete testing is performed as required	AS3600/Spec Cl.7.3.3	Check concrete conforms to design requirements (grade temp, slump)			w	The				Attach test records
2.09	9 Finishing concrete	Drawings C1351Rev0, C1352Rev0, C1353Rev0 SpecCl7.2.16	Levels as per spec (+10mm to -0mm) Acceptable finish quality			w	the				
2.	Check curing application and time is adequate	Spec Cl.7.2.18				w	EM/		Ť		
2.1	1 Stripping of formwork	AS3600-1994 Section 7	24 hours after pour			w	EM				

	STRUCTURAL CONCRET	TE.	AREA:						HE	EAT EXCHA	NGER	Provide a se
P ref. No:	8543-010	Project:	HEATE EXCHANGE	R UPG	RADE		Incoor	ction Key: W	,	Dannell	1115 - K OV - O OV -	John
OT No.	8543-C-HX-002	Project Number:	8543				Witnes	ss, H - Hold,	S-	Surveyor, I	ility Key: SV- Supervisor, SV-	John Holland
ate of Issue:	: 17.02.12						Survei	llance			dent PM- Project Manager	
QUIPMENT I	DESCRIPTION:	Heat Exchanger Plin	ths and Digester Feed	Pump	Plinth							
	Activity Datella	Reference	Acceptance		All	V	erify or 1		,			
Item No.	Activity Details	Document	Criteria	Key	S/C Sign/Date	Key	JH	Sign/Date	Key	QUU Sign/Date	Remarks/Re	ecords
2.12	2 Check as-built survey against design tolerences	Surveyor's sketch Spec Cl.7.2.16	Levels as per spec (+10mm to -0mm) Acceptable finish quality			W	PE	MG	Key	Olginbate		
2.13	3 Installation of Joint Sealant	Drawings	Manufacturers specifications			w	PE	1/4				
2.14	4 Verify concrete test results	Spec Cl.7,23,3	32MPa compressive strength			w	PE .	MG				
3.00	0 Installation Complete							1		-		
3.0	1 Final inspection		QA records complete ITP stages signed off NCRs dispositioned			Н	PE	Mb			HOLD POINT - All items comp documentation attached	leted and all relevan
					APPROVAL							
		NAME			7.10	SIGNA	TURE				DATE	
/C								1				
Н	MASON GRIECO					/	1/1	1			11/01	/

Oxle**N Elles ENPS CO NODE TE a prept (Hea**t Exchangers) General ABN 28 055 131 283

**CONCRETE TEST RECORD** 

# EILSEN'S e Independent Alternative"

NEILSEN'S TECHNICAL SERVICES LABORATORY 39 MICA STREET, CAROLE PARK QLD 4300

PHONE: (07) 3723 8704 FACSIMILE: (07) 3271 2620

Reference	N	0.

	6
nce No.	SOLCAR
	Chi

PROJECT ADDRESS		Nou	K	1.	JOB No				No.:		
PROJECT ADDRESS:	_		eff	4	DATE	DAY SAM	DI CD.				-12.11
	left)	-LADIAL I	DSON	T)	A Proposition of the last of t		_	1 5		٠٠.	PLANT PROLL
/	7				The same of the same		1				( )
hit.	OCKL	2 A	,		TESTIN	G OFFICE	4: 6	- John Colon	u.	1	No. / () .
WEATHER:	) Copy	"out 1	- to	4	TIME AF	RRIVAL:					DEPART:
Mix Code			Slump (Initial)	-			F	PROD	UCTIO	N ASSE	SSMENT
F'c Spec. Slump	Location	of Concrete	Slump (Additive) Concrete Temp.	No.	моигр мимвея	DATE FOR TESTING		AIR CURED (Y / N)	CHARGE REQUEST / QC	C/FS)	
Track No.			Ambient Temp.	JEN EN	N N	RO		E E	RGE ST/	PE (	REMARKS
1. Batched		y Docket No.	Sampling Method	SPECIMEN No.	3	E	ш	20	CHA	TEST TYPE (C /	
Time sampled	Load	Progressive	Compaction	S G	N N	DA.	AGE	AIR	REC	TES	
E3280	HEAT.	XCHRKLER	10	H	10		7		2	0	
N3>/20	NIB 1	XCHARLER WALL	-	B	95		28		1		
- ČO	1	7 -	35	C .	236		汉	*			
53%	PLIN	7415	22							1	
1104	11.	7 228 1	7 7 1						- 11	+	
1104.	70	700%	7.2.1.							111	
1200	1.0	5.8.	1.7.2.						///	11	
			/						-1	1	
								-	-	-	
										_ 11.	
x					י חוד	1					
3			a TIM	5	11/11	41					
			1111516	1711	ILIN.						
1			回己也	10							
		+		-				-			
		+		-			-	-			
	1.						-				
mpling Method: AS - Sampling from no mpaction Method: A		to, Hom spe	cined locations.			nly, 7.2.3	- Slow	disch	arge,	7.2.4 -	Terminated discharge,
pacaon memod. /				namm	ing						
Date	Time	tart Standard Moi	<del></del>	Ua-ii			Curing			ure &	Reason)
Date	THIC	By *	Initial Curing	Hours		Max.	-	M	in.		
	17		- NOTE: Co	ncrete to	ested in ac	cordance	with AS1	012.1,	AS101	2.8, AS	1012.13, AS1012.3
			The same			-					
tomer's Signatu	ire	<del>)</del> ;		<u> </u>			Na Na	tional A	Associa	ation of	Testing Authorities
N. T. C.	0.	111				NAT	FA			Austral	lia Iboratory
ted ByI	ميمونيسياريامي وي	V				1			Acci	ed No.	14293 Øbenchma
The second secon					INVOIC						150 900



Neilsen's Technical Services Laboratory

39 Mica St, Carole Park QLD 4300

Phone: (07) 3723 8705 Fax: (07) 3271 2620

# Concrete Test Report [AS]

Client:

JOHN HOLLAND CONSTRUCTIONS

PO BOX 556

FORTITUDE VALLEY QLD 4006

Project:

240 DONALDSON RD

**ROCKLEA** 

Report No: CON:W12-00450

This report replaces all previous issues of report no 'CON:W12-00450'.



This document is issued in accordance with NATA's accreditation requirements.

Baldwinson

NATA Accredited Laboratory

Approved Signatory: Garry Baldwinson

Number: 14293

Date of Issue: 20/03/2012

THIS DOCUMENT SHALL NOT BE REPRODUCED EXCEPT IN FULL

### COMPRESSIVE STRENGTH OF CONCRETE CYLINDERS

#### Details of Sampled Concrete Concrete Specimens and Results Date & Time Truck No Plant Name Grade(MPa) Air (%) Specimen Dimensions Batched Time Sampled Docket No Product Code Slump(mm) Avg. Density Curing Type Date of (kg/m³) Initial Std of Test Age Strength Marks Fail Location & Remarks (days) (MPa) Mode Avg. Diameter Height (hrs) (days) Cap Load Design 21/02/12 531 Carole Park CA307\A 100.0 198 2480 6 S 28/02/12 7 26.0 Sampling AS 1012.1 CI 6b HEAT EXCHANGER NIB 11:04 12:00 4029801 20 CA307\B 100.1 200 2480 27 S 20/03/12 28 44.0 WALL & PLINTHS 2.8/2.8 N32280 80 CA307\C 100.0 201 2500 S 20/03/12 28 44.5 Concrete Temp. (°C): 33

#### Notes

1. Sampling in accordance with AS 1012.1
2. Slump Test in accordance with AS 1012.3.1
3. Compaction by rodding, in accordance with AS 1012.8.1 Clause 7.3
4. Initial Curing in accordance with AS 1012.8.1 Clause 9.2.2
5. Standard Curing in accordance with AS 1012.8.1 Clause 9.3(a)
6. Capping R - Rubber, S - Sulphur, G - Ground, D - Double Cap Sulphur 7. Compressive Strength in accordance with AS 1012.9
8. Density in accordance with AS 1012.1.1

Moisture Condition SSD in accordance with AS 1012.1.1 unless other

9. Moisture Condition SSD in accordance with AS 1012.12.1, unless otherwise stated m No: 18969.V1.00, Report No: CON:W12-00450

Remarks

FailureMode: N = NORMAL

(c) 2000-2009 QESTLab by SpectraQEST.com

Page 1 of 1

# 2.2.2. Mechanical/Pre-commissioning Checksheets

Revision: A

Approved By: Tate Brammer

STAINLES	S STEEL PIPEWORK INSTALLA	TION CHECK SHEET	AREA:		DIGE	STER FEE	D PUI	MP STA	TION/HEA	T EXCHANGER			
IP ref. No:	8543-001-HX	Project:	Oxley WRP Heat E Upgrade	xchanger									
hecksheet lo.:	8543-M-HX-500	Project Number:	8543				Inspection Key: W - Witness, H - Hold, S -			- Project Engineer			
QUIPMENT	DESCRIPTION:	DIGESTER FEED PU EXCHANGER PIPEV	JMP STATION TO H VORK	EAT	- Survei	Surveillance			ger	nt rivi- rioject	t PM- Project		
IPE ID:		TO:	HEAT EXC	MAN	GERS	5 -	FROI	M:		DIGESTER	FEED PS		
With the state of			REFERENCE			Verify or	Test b	y	10000				
Item No.	Activity Det	ails	DOCUMENT/		S/C			Jŀ	1	Rema	arks/Records		
F 35 1/2 -			DRAWINGS	Key	Resp.	Sign/Date	Key	Resp.	Sign/Date	1005000100			
	Pipework issued as per specifica			j l			Н	PE	JB 31/5				
2.00	Pipework installation incl Stain	less Steel (316)											
	Correct installation of joints		Manufacturer's Instruction				s				*****		
2.02	Pipe and flange alignment correc horizontal)	t (Square, grade,	NA				s	AN					
2.03	Ensure bolts are all tightened cor procedure.	rectly as per torque	Refer to Flange Tightenging Procedure JHG- OXL-037.				S	The state of the s					
2.04	Correct gaskets installed (spiral v rubber as applicable)	vound or 3mm insertion	NA				S	44/					
2.05	Check installation of pipe support centrelines)	s (Site to confirm	Drawing				S	*/					
2.06	Instruments installed as per P&ID indicators etc.	including pressure	486/5/5-R7W105				S	A SE					
2.07	Ensure that all valves are consiste equipment schedule.	ent with P&ID and	486/5/5-R7W105				H	PE	JB 11/6				
2.08	Ensure all instrumentation is insta the P&ID and equipment schedule	alled and consistent with	486/5/5-R7W105				И	PE	B11/6				
2.09	Equipment lables are in place and	consistent with P&ID.	486/5/5-R7W105				w	PE	3811/6				
3.00	Installation of Expansion joints												

Revision: A

Approved By: Tate Brammer

Date of Issue: 13.02.12

IPE ID:	то:					FROI	M:		
Item No.	Activity Details	REFERENCE DOCUMENT/		S/C	Verlfy or	Test b	y JH		Remarks/Records
		DRAWINGS	Key	Resp.	Sign/Date	Key	Resp.	Sign/Date	
	Apply lubricant to the expansion joints before installation	Recommended lubricants are graphite solution or water or glycerine				s		,	
3.02	Install bolts from the arch end (so that bolt heads are adjacent to the arch) to insure that bolts do not interfere with the arch during periods of compression	NA				s			
3.03	Tighten all bolts gradually and equally by alternating around the flange and monitor the flange bulge slightly.	NA				s	IL.		
3.00	Pre-commissioning						an D		
3.01	Ensure all stainless steel pipework completed by qualified welder and all welds have been inspected					s		\$	
3.02	Pipework pressure test completed - record pressure test sheet reference number and attach.					Н	SISE	e	
3.02	Check bolt tightness of expanion joints at least one week after going on-stream and periodically thereafter.					Н	PE		
3.03	Check for damage and leave area tidy and clean for next discipline.					w	PE	2011/6	
		NA				Н			
			PPROVAL				***		
	NAME		SIGNATU	RE		1			DATE
	JANE BEECHER		Ja	~	Beegl	res			11/6/12

Form: 8531 - HTR - 003

Revision: 0

# HYDRO STATIC TESTING RECORD

316 Stainless Steel Oxley Flood Recovery



Australian Standard Refer	1 1 1 0 0 5 5 5 0 0 0 0 0 0 1 3 5 5	
		Line No:
	ischarge on Digester Feed Pump Station	247, 248.83
	ainless Steel	Line Size: DN100
	table Water	
Hydro test Equipment:	Bucket pump, calibrated gauges,	-
D' T I D (IZD)		11000
Pipe Test Pressure (KPa):	-1D 15 1	600KPA
Hold Test for Znours Reco	ord Pressure at 15 minute intervals 30 minute Pressure. OSS pa	
45 Minute Pressure 605 A	1 Hour Pressure 205 Kpc	
1 Hour 15 Minute Pressure	605 Kpm	
1 Hour 30 Minute Pressure	605 Kpc	
1 Hour 45 Minute Pressure	605 Kpa	
2 Hour Pressure 6.0.5.	Kpa	
Allowable Make-up Water	Quantity $(Q \le 0.14LDH)(L/hr)$	0.13 L/hr
Measured Make-up Water	Quantity (L/hr)	NIL
	rt of Test	9:18 am 11:25 cm
Temperature: Con	mpletion of Test	11:25 cm
Water Temperature:	·	
Hydro Test Complies:		yes
	Sketch of Repaired Section:	
Test Water Dumped (locati	ion):	House drain
Pipeline is	☐ fit for service	□ not fit for service
Subcontractor's Representa		AND Else
Sub-contained bittepresents	Signature:	1341
	Date:	19-DC-17
JHG Engineer:	Name:	17.03.12
0	Signature:	
	Date:	
	Date.	
Client's Representative	Name:	
A THE RESIDENCE OF THE PROPERTY AND ADDRESS OF THE PARTY	Signature:	

Form: 8543-500-002

Revision: 0

# HYDRO STATIC TESTING RECORD

316 Stainless Steel Oxley Flood Recovery



Australian Standard Referenced:	AS 2566.2:2002 App M4	Line No: 25/	252, 253-150-55-43
Line Description: Sludge Discha	rge of Heat Exchanger 1		100 000
Line Material: 316 Stainless		Line Size: DN	100
Hydro Test Medium: Potable W			
Hydro test Equipment: Bucket	pump, calibrated gauges,		
			- 181
Pipe Test Pressure (KPa):		600KPA	
Hold Test for 2hours Record Pr 15 minutes Pressure 600	essure at 15 minute intervals		
15 minutes Pressure	ninute Pressure. O.O.O. 1901		
45 Minute Pressure. 6009 H	our PressureC.C.C.C.C.C.C.C.C.C.C.C.C.C.C.C.C.C		
1 Hour 15 Minute Pressure	OOK Da		
1 Hour 45 Minute Pressure	ÖÖKDA		
2 Hour Pressure 600 Kg	Va		
Allowable Make-up Water Quan		0.13 L/hr	
Measured Make-up Water Quant	ity (L/hr)	NiL	
Ambient Start of T	est	10.05 am	
Temperature: Completi	on of Test	12.15 pm	
Water Temperature:			
Hydro Test Complies:		yes	
If Hydro Test Fails Attach Sketch	of Repaired Section:		
Test Water Dumped (location):		House drain	
Pipeline is	fit for service	not fit for service	1 1
	fit for service Name:	□ not fit for service	y Else
	<del></del>	not fit for service	y esse
	Name:	not fit for service  THG AND  21-05-12	y Else
Subcontractor's Representative	Name: Signature:	not fit for service  THG AND  Al-05-12	y 1se
Pipeline is Subcontractor's Representative  JHG Engineer:	Name: Signature: Date:	□ not fit for service  THG AND  Al-05-12	y Else
Subcontractor's Representative	Name: Signature: Date: Name:	□ not fit for service  THG AND  Al-05-12	y Else
Subcontractor's Representative  IHG Engineer:	Name: Signature: Date: Name: Signature:	not fit for service  THG AND  21-05-12	y Else
Subcontractor's Representative	Name: Signature: Date: Name: Signature: Date:	□ not fit for service  THG AND  PLLE  21-05-12	y Else

Form: 8543-500-003

Revision: 0

## HYDRO STATIC TESTING RECORD

# 316 Stainless Steel Oxley Flood Recovery



Assetuation Standard Defense	aced: AS 2566.2:2002 App M4	1: 11   0   0   0   0	2 w de alle
Australian Standard Referent Line Description: Sludge D	Discharge of Heat Exchanger 2	Line No: 251, 252, 25	3-150 45 115
	aless Steel	Line Size: DN100	-
	ble Water	Line Size: Divioo	+
	acket pump, calibrated gauges,		-
riyero test Equipment.	, , , , , , , , , , , , , , , , , , , ,		
Pipe Test Pressure (KPa):		<i>6</i> 0Ω ΚΡΑ	
Hold Test for 2hours Record 15 minutes Pressure 2007 45 Minute Pressure 1 Hour 15 Minute Pressure 1 Hour 30 Minute Pressure 1 Hour 45 Minute Pressure 2 Hour Pressure	Hour Pressure DOO Kpa 600 Kpa 600 Kpa		
	Quantity (Q ≤ 0.14LDH)(L/hr)	0.13 L/hr	
Measured Make-up Water Q	uantity (L/hr)	NIL	
Ambient Start	of Test	1005 am	
Temperature: Com	pletion of Test	12:15 pm	
Water Temperature:		100 spin	
Hydro Test Complies:		Ves	
If Hydro Test Fails Attach Sl			
Test Water Dumped (location	n):	House drain	
Pipeline is	fit for service	□ not fit for service	
Subcontractor's Representati		ANGLY EISE	
	Signature:	Charles and the second	
HIC E	Date:	21-05-12	
JHG Engineer:	Name:		
	Signature:		
	Date:		
Clientia Dannes t-ti-	Name		
Client's Representative	Name:		
	Signature: Date:		
	Date.		

Form: 8531 – HTR - 003


Revision: 0


#### HYDRO STATIC TESTING RECORD

316 Stainless Steel Oxley Flood Recovery



581-100-5/5 Australian Standard Referenced: AS 2566.2:2002 App M4 Line No: 580-150-5/ Service Water to Heat Exchanger 1 Line Description: 552-1005/8 316 Stainless Steel Line Material: DN100 Line Size: Potable Water Hydro Test Medium: Bucket pump, calibrated gauges, Hydro test Equipment: Pipe Test Pressure (KPa): 1065 KPA Hold Test for 2hours Record Pressure at 15 minute intervals 15 minutes Pressure ....... 30 minute Pressure ....... 1 Hour 15 Minute Pressure ..... 1 Hour 30 Minute Pressure ...... 1 Hour 45 Minute Pressure ..... 2 Hour Pressure ..... Allowable Make-up Water Quantity  $(Q \le 0.14LDH)(L/hr)$ 0.13 L/hr Measured Make-up Water Quantity (L/hr) Ambient Start of Test Temperature: Completion of Test Water Temperature: Hydro Test Complies: If Hydro Test Fails Attach Sketch of Repaired Section: Test Water Dumped (location): House drain If fit for service Pipeline is □ not fit for service Name: Subcontractor's Representative Signature: Date: JHG Engineer: Name: Signature: Date: Client's Representative Name: Signature: Date:





Revision: A

Approved By: Tate Brammer

Date of ue: 13.02.12

PV	C PIPEWORK INSTALLATION CHE	CK SHEET	AREA:				HEAT	EXCH	ANGERS		
TP ref. No: Checksheet lo.:	8543-001-HX 8543-M-HX-501	Project: Project Number:	Ungrado 8543	xunanger		Inspection Key: W - Witness, H - Hold, S -		SV- Surveyor, PE - Project Eng		ect Engineer	
QUIPMENT	DESCRIPTION:	HEAT EXCHANGER	S PVC PIPEWORK		Surveillance			uperintendent PM er	M- Project		
IPE ID:	CHLORING DISPENSER	TO:			_		FROM	Л:			
			REFERENCE			Verify or	Test by	y			
Item No.	m No. Activity Details		DOCUMENT/ DRAWINGS	Wass	S/C			JH		Remarks/Records	
1.01	Pipework issued as per specification		Diominico	Key	Kesp.	Sign/Date		_	The state of the s		
	Pipework installation incl PVC						ļΗ	PE	JB31/5		
2.01	Correct installation of joints		Manufacturer's Instruction		1		s				
2.02	Pipe and flange alignment correct (S horizontal)	Square, grade,	NA				s				
2.03	Correct gaskets installed (3mm inse	rtion rubber)	NA				S	No.			
2.04	Correct torquing of bolts			1			s	9			
2.05	Ensure PVC is installed as per manurecommendations. Confirm PVC glusealant are suitable for application	ufacturer's ue, primer and thread	WeldOn P70(Primer), 724(Glue) and Spears Blue 75 Liquid thread sealant				s	A			
2.06	Check installation of pipe supports (centrelines)	Site to confirm	Drawing				s				
2.07	Instruments installed as per P&ID in indicators etc.	cluding pressure	486/5/5-R7D177				s	E			
2.08	Ensure that all valves are consistent equipment schedule.	with P&ID and	486/5/5-R7D177				Н	PE	B n/6		
2.09	Ensure all instrumentation is installe the P&ID and equipment schedule.	d and consistent with	486/5/5-R7D177				Н	PE	JB 11/6		
2.10	Equipment lables are in place and co	onsistent with P&ID.	486/5/5-R7D177				w	PE	JB 11/6		

Revision: A Approved By: Tate Brammer

Date of Issue: 13.02.12

то:					FROM	<b>V</b> 1:				
	REFERENCE	Verify or Test by								
Activity Details	DOCUMENT/	DOCUMENT/ S/C			JH			Remarks/Records		
	DRAWINGS	Key	Resp.	Sign/Date	Key	Resp.	Sign/Date			
Pipework pressure/service test completed - record pressure test sheet reference number and attach.					н	A L				
2.12 Check for damage and leave area tidy and clean for next discipline.		2.12 Check for damage and leave area tidy and clean for ne discipline.	xt				w	PE	5B 5/6/12	
MECH INSTALLATION COMPLETE	NA				Н	SAL				
		APPROVA	L	-	0	2				
NAME					^			DATE		
JANE BEECHEL	-		Tare	Beec	hes	-		11/6/12		
							·			
	Activity Details  Pipework pressure/service test completed - record pressure test sheet reference number and attach.  Check for damage and leave area tidy and clean for ne discipline.  MECH INSTALLATION COMPLETE	Activity Details  REFERENCE DOCUMENT/DRAWINGS  Pipework pressure/service test completed - record pressure test sheet reference number and attach.  Check for damage and leave area tidy and clean for next discipline.  MECH INSTALLATION COMPLETE  NA	Pipework pressure/service test completed - record pressure test sheet reference number and attach.  Check for damage and leave area tidy and clean for next discipline.  MECH INSTALLATION COMPLETE  NA  NAME  SIGNAT	Activity Details  REFERENCE DOCUMENT/ DRAWINGS  Pipework pressure/service test completed - record pressure test sheet reference number and attach.  Check for damage and leave area tidy and clean for next discipline.  MECH INSTALLATION COMPLETE  NA  REFERENCE DOCUMENT/ S/C  Key Resp.	Activity Details  REFERENCE DOCUMENT/ DRAWINGS  Pipework pressure/service test completed - record pressure test sheet reference number and attach.  Check for damage and leave area tidy and clean for next discipline.  MECH INSTALLATION COMPLETE  NA  NAME  SIGNATURE	Activity Details  REFERENCE DOCUMENT/ DRAWINGS  Pipework pressure/service test completed - record pressure test sheet reference number and attach.  Check for damage and leave area tidy and clean for next discipline.  NA  NA  NA  REFERENCE S/C  Key Resp. Sign/Date Key  H  W  SIGNATURE	Activity Details  REFERENCE DOCUMENT/ DRAWINGS  Pipework pressure/service test completed - record pressure test sheet reference number and attach.  Check for damage and leave area tidy and clean for next discipline.  MECH INSTALLATION COMPLETE  NA  REFERENCE S/C JH  Key Resp. Sign/Date Key Resp.  W PE  H  PE  MECH INSTALLATION COMPLETE  NA  SIGNATURE	Activity Details  REFERENCE DOCUMENT/ DRAWINGS  Rey Resp. Sign/Date Key Resp. Sign/Date  Pipework pressure/service test completed - record pressure test sheet reference number and attach.  Check for damage and leave area tidy and clean for next discipline.  MECH INSTALLATION COMPLETE  NA  REFERENCE SIC JH  W PE Sign/Date  W PE SIGNATURE		

Revi. . A Approved By: Tate Brammer

Date of Issue: 2.12 Page 1 of 3

**PUMP INSTALLATION CHECK SHEET** AREA: DIGESTER FEED PUMP STATION John Holland Oxley WRP Hest Exchanger ITP ref. No: 8543-001-HX Project: Inspection Key: W -Responsibility Key: SV- Supervisor, SV-Witness, H - Hold, S -Surveyor, PE - Project Engineer Sup-Checksheet 8543-M-HX-001 Superintendent PM- Project Manager Project Number: Surveillance EQUIPMENT DESCRIPTION: DIGESTER FEED PUMP 1 Tag Number: PU-625-401 Verify or Test by REFERENCE Item No. **Activity Details** S/C DOCUMENT/ Remarks/Records DRAWINGS Resp. Sign/Date Key Resp. |Sign/Date 1.01 Set out and Levels are correct to drawing. 2.00 Pump Storage 2.01 Pump delivered as specified JB 31/5 2.02 Clean and free of debris Visual inspect pump and ensure there is no damage. 2.03 Record notes. 3.00 Record nameplate data: Pump - Record any variances to below Manufacturer: Mono Pumps 3.01 Pump type: Compact EZ Strip Range JB 31/5 PE Model No .: CAMBI-DIG-LH-SF Record Serial No.: C559554 201 Type: UEG W22 Record Serial No.: Phase: SOUZ Frequency: JB315 3.02 Protection: 1855 18.5kw 380 V 36.3 A 0.85 PE Power: Voltage: Current: cos φ: 1460/min Revs: 4.00 Pump Installation PE/SV BB31/5 4.01 Anchors as per manufacturers requirements 4.02 Confirm gasket type (3mm insertion spiral wound gasket) NA

**DIGESTER FEED PUMP STATION** 

PE

SLUDGE.

AREA:

Revision: A

Approved By: Tate Brammer

**PUMP INSTALLATION CHECK SHEET** 

5.05 current, voltage and power from VSD and instruments.

Plot results against manufacturers curve.

John Oxley WRP Hest Exchanger ITP ref. No: 8543-001-HX Project: Upgrade Inspection Key: W -Responsibility Key: SV- Supervisor, SV-Witness, H - Hold, S -Surveyor, PE - Project Engineer Sup-Checksheet Surveillance Superintendent PM- Project Manager 8543-M-HX-001 Project Number: 8543 EQUIPMENT DESCRIPTION: DIGESTER FEED PUMP 1 Tag Number: PU-625-401 Verify or Test by REFERENCE S/C Item No. **Activity Details** DOCUMENT/ Remarks/Records DRAWINGS Resp. Sign/Date Key Resp. Sign/Date 4.03 Pipework aligned correctly NA 4.04 Base grouted NA Refer to Flange Ensure bolts are torqued up as per spiral wound gasket methodology and torque rating (Approx Torque per bolt Tightenging 339Nm for 12 bolts and 203 Nm for 8 bolts) Mark all Procedure JHG-OXLbolts with an 'X' after torquing completed. 037. 4.06 Check all nuts, bolts, securing flanges and base mounting fixtures are tightened Check oil levels and top up if required. Recommended oil: Mono Pump O&M: 4.07 KLUBER SYNTHESO D460 EP OIL or MOBIL GEAR OIL EZ Strip Range. SHC 320 MPA600 Mono Pump O&M: 4.08 Check alignment of pump and gearbox. EZ Strip Range. JB/1/6 4.09 Equipment lables are in place and consistent with P&ID. 486/5/5-R7D185 PE MECH INSTALLATION COMPLETE 5.00 Pump Pre-com Mech 5.01 Remove gearbox breathers if required. Verify that pump is energised. Check energisation register Insert engerisation JB \$1/6 5.02 PE procedure number. 5.03 Ensure pump is filled with liquid and check rotation of JB1/6 PE pumps (Anti-clockwise gives inlet at drive end) Test all pump interlocks and ensure the pump starts and JB12/6 5.04 PE stops accordingly. Run test of pump at different speeds and record flowrate, COMPLETED ON

Revis. A

Approved By: Tate Brammer

	PUMP INSTALLATION CH	ECK SHEET	AREA:				DIGES	STER FI	EED PUMP STA	TION	In the State of the
TP ref. No:	8543-001-HX	Project:			Inspec	Inspection Key: W -			Responsibility Key: SV- Supervisor, SV-		John
Checksheet No.:	8543-M-HX-001	Project Number:			Witness, H - Hold, S - Surveillance				Surveyor, PE – F Superintendent F	Project Engineer Sup- PM- Project Manager	
EQUIPMENT I	DESCRIPTION:	DIGESTER FEED P	UMP 1						Tag Number:		PU-625-40*
			REFERENCE		Verify or Test by					1 0 020 40	
Item No.	Activit	y Details	DOCUMENT/		S/C			JH		Remarks/F	Records
			DRAWINGS	Key	Resp.	Sign/Date	Key	Resp.	Sign/Date		
5.0	Check for damage to pump a for next discipline.	and leave area tidy and clean					w	PE	JB 11/6		

		APPROVAL	
	NAME	SIGNATURE	DATE
TATE BRAN	nnex	There	11/6/12

Revis. A
Approved By: Tate Brammer

Date of Issue: 2.12 Page 1 of 3

PUMP INSTALLATION CHECK SHEET AREA: **DIGESTER FEED PUMP STATION** Oxley WRP Hest Exchanger lohn ITP ref. No: 8543-001-HX Project: Upgrade Inspection Key: W -Responsibility Key: SV- Supervisor, SV-Witness, H - Hold, S -Surveyor, PE - Project Engineer Sup-Checksheet 8543-M-HX-002 Project Number: 8543 Surveillance Superintendent PM- Project Manager EQUIPMENT DESCRIPTION: DIGESTER FEED PUMP 2 PU-625-402 Tag Number: Verify or Test by REFERENCE Item No. **Activity Details** DOCUMENT/ S/C JH Remarks/Records DRAWINGS Key Resp. Sign/Date Key Resp. Sign/Date 1.01 Set out and Levels are correct to drawing. 2.00 Pump Storage 2.01 Pump delivered as specified JB 31/5 2.02 Clean and free of debris 2.03 Visual inspect pump and ensure there is no damage. Record notes. 3.00 Record nameplate data: Pump - Record any variances to below Manufacturer: Mono Pumps 3.01 Pump type: Compact EZ Strip Range Model No.: CAMBI - DIG-RH-SF JB31/5 PE Record Serial No.: C559552 101 <u>Motor</u> Type: WEG WZZ Record Serial No.: Phase: 3 Protection: 1955 Power: 1856 Voltage: 380 V JB31/5 3.02 Protection: PE 36.3A Current: cos φ: 1460/min Revs: 4.00 Pump Installation 4.01 Anchors as per manufacturers requirements PE/SV J8 31/5 4.02 Confirm gasket type (3mm insertion spiral wound gasket) NA

Revision: A Approved By: Tate Brammer

	PUMP INSTALLATION C	HECK SHEET	AREA:				DIGES	STER FE	EED PUMP ST	ATION	
TP ref. No:	8543-001-HX	Project:	Oxley WRP Hest Exc Upgrade	hanger	Inspec	tion Key: W				Key: SV- Supervisor, SV	John Holland
Checksheet No.:	8543-M-HX-002	Project Number:	8543			Witness, H - Hold, S - Surveillance			Surveyor, PE - Superintendent		
EQUIPMENT D	ESCRIPTION:	DIGESTER FEED PL	UMP 2						Tag Number:		PU-625-402
			REFERENCE			Verify o	Test				
Item No.	Activ	rity Details	DOCUMENT/ DRAWINGS	Key	S/C Resp. Sign/Date		Ji-		Sign/Date	Remark	s/Records
4.03	Pipework aligned correctly		NA .	itey	itesp.	Olg///Date	S	Resp.	Signibate		
	Base grouted		NA				S	18/2			
4.05	methodology and torque ra	p as per spiral wound gasket ating ( <b>Approx Torque per bolt</b> 203 Nm for 8 bolts) Mark all iing completed.	Refer to Flange Tightenging Procedure JHG-OXL 037.				s	SV			
4.06	Check all nuts, bolts, secur fixtures are tightened	ring flanges and base mounting	NA				s	Ma			
4.07		o if required. Recommended oil: 60 EP OIL or MOBIL GEAR OIL	Mono Pump O&M: EZ Strip Range. MPA600				w	sv	B31/5		
4.08	Check alignment of pump a	and gearbox.	Mono Pump O&M: EZ Strip Range. MPA601				w	Alle			
4.09	Equipment lables are in pla	ace and consistent with P&ID.	486/5/5-R7D185				w	PE	3811/6		
PARTY.			MECH INST	ALLA	ATION	COMPLE	TE				
5.00	Pump Pre-com Mech				196			C 10 1			
5.01	Remove gearbox breathers	s if required.					w	Me			
5.02	for specific area.	sed. Check energisation register	Insert engerisation procedure number.				Н	PE	JB 1/6		
5.03	pumps (Anti-clockwise give						w	PE	JB1/6		
5.04	Test all pump interlocks ar stops accordingly.	nd ensure the pump starts and					w	PE	JB 1946		
5.05		ent speeds and record flowrate, r from VSD and instruments. acturers curve.					w	PE	70 BE	COMPLETED SLUDGE	av

Revis. \_\_. A
Approved By: Tate Brammer

	PUMP INSTALLATION CH	ECK SHEET	AREA:			DIGES	STER FI	EED PUMP STATI	ON		
ITP ref. No:	8543-001-HX	Project:	75		Inspec	Inspection Key: W -			Responsibility Key:	John	
Checksheet No.:	8543-M-HX-002	Project Number:			Witness, H - Hold, S - Surveillance				Surveyor, PE – Proj Superintendent PM-		Holland
EQUIPMENT I	DESCRIPTION:	DIGESTER FEED P	UMP 2						Tag Number:	1124 1114 11	PU-625-402
			REFERENCE	Verify or Test by				ESSENCE OF THE PARTY OF THE PAR			
Item No.	Activity	/ Details	DOCUMENT/		S/C			JH		Remarks/F	Records
			DRAWINGS	Key	Resp.	Sign/Date	Key	Resp.	Sign/Date		
5.0	6 Check for damage to pump a for next discipline.	and leave area tidy and clean		1			w	PE	JB11/6		-+

		APPROVAL	
	NAME	SIGNATURE	DATE
JH	TATE BRAMMER	Offin	11/6/12

Revis A

Approved By: Tate Brammer

Date of Issue: 2.12 Page 1 of 3

	PUMP INSTALLATION CHI	ECK SHEET	AREA:				DIGE	STER FE	ED PUMP STA	ATION	John Holland	
TP ref. No:	8543-001-HX	Project:	Oxley WRP Hest Ex Upgrade	changer	Inspec	tion Key: W			Responsibility K	ey: SV- Supervisor, SV-		
Checksheet No.:	8543-M-HX-003	Project Number:	8543		Surveil	s, H - Hold, lance	S-		Surveyor, PE – Project Engineer Sup- Superintendent PM- Project Manager			
EQUIPMENT D	DESCRIPTION:	DIGESTER FEED F	PUMP 3						Tag Number:		PU-625-403	
	Visit in the second		REFERENCE		Verify or Test by						1 0-023-403	
Item No.	Activity	/ Details	DOCUMENT/	1	S/C			JH		Remarks/	Records	
			DRAWINGS	Key	Resp.	Sign/Date	Key	Resp.	Sign/Date			
1.01	Set out and Levels are correct	ct to drawing.					s	dela				
	Pump Storage			-			7. 6					
2.01	Pump delivered as specified						Н	PE	JB 31/5			
2.02	Clean and free of debris						s	Mhe				
2.03	Visual inspect pump and ens Record notes.	ure there is no damage.					w	Olla				
3.00	Record nameplate data:											
	Pump - Record any variances	s to below										
Manu	Manufacturer: Mono Pumps											
3.01	Pump type: Compact EZ Stri	p Range					] <sub>w</sub>	PE	JB 31/5			
	Model No .: CAMBI - DIE	S-ZH-SF					]**		05 5./5			
	Record Serial No.: C559	554 102										
	Motor											
	Type: WEG W22						1					
	Record Serial No.: Phase: 3				_		1		<b>I</b>			
	Frequency: 50 MZ			+	+		-		l , ⊢			
3.02	Protection: 1955		<del> </del>	+	+		-		783V5 -			
0.02	Power: 185 kW			+	+	-	w	PE	D 1/5			
	Voltage: 380 V		_	+	+		1		l ⊢			
	Current: 76.2 14		<del>                                     </del>	+	_		1		l ⊢			
	cos φ: 0.85	· · · · · · · · · · · · · · · · · · ·			_		1		<u> </u>			
	Revs: 1460/min						1	1	l			
4.00	Pump Installation											
4.01	Anchors as per manufacturer	s requirements					w	250				
4.02	Confirm gasket type (3mm in	sertion spiral wound gasket)	NA				s	Mile				

Revision: A Approved By: Tate Brammer

	PUMP INSTALLATION CHECK	SHEET	AREA:				DIGE	STER FE	ED PUMP S	STATION	
TP ref. No:	8543-001-HX	Project:	Oxley WRP Hest Exc Upgrade	changer		tion Key: W				y Key: SV- Supervisor, SV	John Holland
Checksheet No.:	8543-M-HX-003	Project Number:	8543		Witness, H - Hold, S - Surveillance					- Project Engineer Sup- ent PM- Project Manager	Hollana
QUIPMENT D	DESCRIPTION:	DIGESTER FEED PU	JMP 3					_	Tag Number		PU-625-403
			REFERENCE			Verify o	r Test	by			
Item No.	Activity Det	tails	DOCUMENT/ DRAWINGS	Key	S/C Resp. Sign/Date I		Jh Key Pasn		Sign/Date	Remarks	/Records
4.03	Pipework aligned correctly		NA		Ittoop	O.g.III Date	S	2500	Appearance of the Person of th		
4.04	Base grouted		NA				S	1			
4.05	bolts with an 'X' after torquing con	pprox Torque per bolt for 8 bolts) Mark all npleted.	Refer to Flange Tightenging Procedure JHG-OXL 037.				s	SV			
4.06	Check all nuts, bolts, securing flat fixtures are tightened	nges and base mounting	NA				s	Mar			
4.07	Check oil levels and top up if requ KLUBER SYNTHESO D460 EP C SHC 320	uired. Recommended oil: OIL or MOBIL GEAR OIL	Mono Pump O&M: EZ Strip Range. MPA600				w	Me	JB31/5		
4.08	3 Check alignment of pump and gea	arbox.	Mono Pump O&M: EZ Strip Range. MPA601				w	Ma			
4.09	Equipment lables are in place and	d consistent with P&ID.	486/5/5-R7D185				w	PE .	1811/6		
			MECH INST	TALLA	MOIT	COMPLE	TE	2			
5.00	Pump Pre-com Mech				1000						
5.01	Remove gearbox breathers if requ						w	Ma		0.2	
5.02	for specific area.		Insert engerisation procedure number.				Н	PE	JB 1/6		
5.03	Ensure pump is filled with liquid a pumps (Anti-clockwise gives inlet						w	PE	JB 1/6		
5.04	Test all pump interlocks and ensu stops accordingly.	ire the pump starts and					w		3812/6		-
5.05	Run test of pump at different spec current, voltage and power from V Plot results against manufacturers	/SD and instruments.					w	PE	70 BE	COMPLETED SLUDGE	ON

Revis.\_\_, A Approved By: Tate Brammer

	PUMP INSTALLATION CHECK S	SHEET	AREA:				DIGES	TER F	EED PUMP ST	ATION	
ITP ref. No:	8543-001-HX	Project:	Oxley WRP Hest Exchanger Upgrade 8543		Inspection Key: W -				Responsibility K	John	
Checksheet No.:	8543-M-HX-003	Project Number:			Witness, H - Hold, S - Surveillance				Surveyor, PE – Superintendent	Holland	
EQUIPMENT I	DESCRIPTION:	DIGESTER FEED PI	JMP 3						Tag Number:		PU-625-403
			REFERENCE			Verify o	r Test	by		1 0 020 100	
Item No.	Activity Deta	ills	DOCUMENT/		S/C					Remarks/F	Records
		The second of	DRAWINGS	Key	Resp.	Sign/Date	Key	Resp.	Sign/Date		2000100
5.0	Check for damage to pump and leafor next discipline.	ave area tidy and clean					w	PE	JB 11/6		

		Al <sup>o</sup> PROVAL	
	NAME	SIGNATURE	DATE
JH	TATE BRAMMER	The	11/6/12

Date of Issue: 1 2.12

Page 1 of 2

Revis A

Approved By: Tate Brammer

HEAT EXCHANGER INSTALLATION CHECK SHEET AREA: **HEAT EXCHANGERS** John Holland Oxley WRP Hest Exchanger ITP ref. No: 8543-001-HX Project: Upgrade Inspection Key: W -Responsibility Key: SV- Supervisor, SV-Witness, H - Hold, S -Checksheet Surveyor, PE - Project Engineer Sup-8543-M-HX-004 8543 Surveillance Project Number: Superintendent PM- Project Manager EQUIPMENT DESCRIPTION: HEAT EXCHANGER 1 Tag Number: HX-626-01A Verify or Test by REFERENCE Item No. **Activity Details** S/C DOCUMENT/ JH Remarks/Records DRAWINGS Key Resp. Sign/Date Resp. Sign/Date 1.01 Set out and Levels are correct to drawing. 1.02 Heat exchanger delivered as specified PE 183/5 1.03 Clean and free of debris 1.04 Visual inspect heat exchanger tubes and ensure there is no damage. Record notes. 2.00 Record nameplate data: Heat exchanger - Record any variances to below Manufacturer: Teralba Industries Model No.: 2.01 Record Serial No.: 18 31/5 PE Temperature Range: Pressure Range: 3.00 Heat Exchanger Installation 3.01 Anchors as per manufacturers requirements 3.02 Confirm gasket type (3mm insertion spiral wound) 3.03 Pipework aligned correctly NA 3.04 Base grouted NA 3.05 Check all nuts, bolts, securing flanges and base mounting fixtures are tightened. Ensure bolts are torqued up as per spiral wound gasket methodology and torque rating (Approx Torque per bolt 176 Nm for 8 bolts) Mark all bolts with an 'X' after Bolt Load Tables and torquing sequence. torquing completed. JB 11/6 3.07 Equipment lables are in place and consistent with P&ID. 486/5/5-R7D185 MECH INSTALLATION COMPLETE

Revision: A Approved By: Tate Brammer

HEA	T EXCHANGER INSTALLAT	ION CHECK SHEET	AREA:		HE				XCHANGE		
TP ref. No:	8543-001-HX	Project:	773		Inspection Key: W -			Responsibility Key: SV- Supervisor, SV- Surveyor, PE – Project Engineer Sup- Superintendent PM- Project Manager		John Holland	
Checksheet No.:	8543-M-HX-004	Project Number:			Witness, H - Hold, S - Surveillance						
QUIPMENT D	DESCRIPTION:	TION: HEAT EXCHANGER 1				Tag Number:					HX-626-01A
				1		Verify o	r Test I	by			
Item No.	Activity Details		DOCUMENT/ DRAWINGS	S/C				JH		Remarks/I	Records
				Key	Resp.	Sign/Date	Key	Resp.	Sign/Date		
5.00	Heat Exchanger Pre-com I	Wech									
5.0			Teralba quality assurance report				w	SV/PE	JB 31/5	Carried out at Teralba Industr	ies workshop
5.02	Scour service water line for no debris enters the cooling	several minutes to ensure that jacket.					н	PE	JB 12/6		
5.03	Check for damage to pump for next discipline.	and leave area tidy and clean					w	PE	SB 11/6	-	

ME CONTE		APPROVAL.	
	NAME	SIGNATURE	DATE
JH	JANE SECONDE	Jone Beeches	12/6/12

Revis . A Approved By: Tate Brammer

Date of Issue: 2.12 Page 1 of 2

IILAI	EXCHANGER INSTALLATION	N CHECK SHEET	AREA:					HEAT E	XCHANGE	RS	
TP ref. No:	8543-001-HX	Project:	Oxley WRP Hest Exc Upgrade	hanger		tion Key: W			Responsibility Key: SV- Supervisor, SV		John Holland
Checksheet No.:	8543-M-HX-005	Project Number:	8543						Surveyor, PE – Project Engineer Sup- Superintendent PM- Project Manager		Holland
QUIPMENT DE	SCRIPTION:	HEAT EXCHANGER	2						Tag Number:		HX-626-02A
			REFERENCE		Verify or Test by						TIX OLO OLA
Item No.	Activity D	Details	DOCUMENT/		S/C			JH		Remarks/F	Records
			DRAWINGS	Key	Resp.	Sign/Date	Kev	Resp.	Sign/Date	Tromarkan	(GCO) US
1.01	Set out and Levels are correct t	to drawing.				100	s	2/			
1.02	Heat exchanger delivered as sp	pecified			1		Н	PE	JB31/5		
1.03	Clean and free of debris						s	Who .	2000115		
	Visual inspect heat exchanger t no damage. Record notes.	tubes and ensure there is					w	Alle,			
	Record nameplate data:										
	Heat exchanger - Record any v										
	Manufacturer: Teralba Industrie	es									
2 01L	Model No.:						1		. ,		
	Record Serial No.:						w	PE ,	JB31/5		
-	Temperature Range:							`			
	Pressure Range:						1				
	Heat Exchanger Installation										
3.01	Anchors as per manufacturers i	requirements			T		W	A STATE OF THE STA			
3.02	Confirm gasket type (3mm inse	rtion spiral wound)	NA				S				
	Pipework aligned correctly		NA		$\vdash$		S				
	Base grouted		NA				S			rowed plentha	1 to back
3.05	Check all nuts, bolts, securing f fixtures are tightened.	flanges and base mounting	NA				S		-	The state of the s	Co May
3.06	Ensure bolts are torqued up as methodology and torque rating of 176 Nm for 8 bolts) Mark all botorquing completed.	(Approx Torque per bolt	Refer to Flange Tightenging Procedure JHG-OXL- 037.				s	Me	7		

Revision: A Approved By: Tate Brammer

HEA	T EXCHANGER INSTALLAT	TION CHECK SHEET	AREA:									
ITP ref. No:	8543-001-HX	Project:	Oxley WRP Hest Ex Upgrade	Oxley WRP Hest Exchanger Upgrade		Inspection Key: W -			Responsibility Key: SV- Supervisor, S'		i John	
Checksheet No.:	8543-M-HX-005	Project Number:	8543		Witness, H - Hold, S - Surveillance				Surveyor, PE – Project Engineer Sup- Superintendent PM- Project Manager		Holland	
EQUIPMENT D	ESCRIPTION:	2						Tag Numbe	er:	HX-626-02A		
The same of the	Item No. Activity Details		REFERENCE	1		Verify o	r Test I	by				
Item No.			DOCUMENT/ DRAWINGS	S/C				JH		Remarks/	Remarks/Records	
				Key	Resp.	Sign/Date	Key	Resp.	Sign/Date	A Company of the Comp		
5.0	Complete pressure test on testing sheets are complete	Complete pressure test on heat exchanger and ensure testing sheets are completed and attached					w	SV/PE	JB 31/5	Carried out at Teralba Industr	ries workshop	
	for several minutes to ensu cooling jacket.						н	PE				
5.03	Check for damage to heat and clean for next discipline	exchanger and leave area tidy					w	PE	JB 11/6			

		APPROVAL	
	NAME	SIGNATURE	DATE
JH	JANE BEECHBR	Jane Baches	12/6/12

Date of Issue: 1 2.12

Page 1 of 2

Revis A

Approved By: Tate Brammer

AIR ACTUATED VALVE > DN50 INSTALLATION CHECK SHEET AREA: DIGESTER FEED PUMP STATION John Oxley WRP Heat Exchanger ITP ref. No: 8543-001-HX Project: Inspection Key: W -Upgrade Responsibility Key: SV- Supervisor, SV-Witness, H - Hold, S -Surveyor, PE - Project Engineer Sup-Checksheet 8543-M-HX-100 Surveillance **Project Number:** Superintendent PM- Project Manager **EQUIPMENT DESCRIPTION:** DIGESTER FEED PUMP 1 Outlet Valve Tag Number: FCV-625-423 Verify or Test by REFERENCE Item No. **Activity Details** DOCUMENT/ S/C JH Remarks/Records DRAWINGS Resp. Sign/Date Key Resp. Sign/Date 1.00 Record Actuator nameplate data - record any variances to below Manufacturer: Aeon Kempster Model: KV7 Lugged Knife gate Valve 1.01 DN: 100mm TB 31/5 PE Valve Class: GA21-A With Air Actuator and Limit Switch Box 2.00 Valve installation 2.01 Check internal pipework and clear any debris 2.02 Confirm gasket type (SS316 spiral wound gasket rating DN100 PN10-16) 2.03 Check installation direction of valves and ensure it is as per vendor manual or arrow on valve body. Aeon KV7 BB116 PE Installation Manual Confirm flange alignment and install valve making sure of correct bolting sequence and torques. 2.05 Ensure bolts are well lubricated before torquing up. Ensure bolts are torqued up as per spiral wound gasket Refer to Flange 2.06 methodology and torque rating (Approx Torque per bolt 176 Nm for 8 bolts) Mark all bolts with an 'X' after Tightenging Procedure JHG-OXL torquing completed. 037. 3.01 Actuator Installation 3.03 Verify silences/speed adjustments are installed. NA Is SV/PE NA Connect compressed air and ensure isolated. Do not pressurise until pre-commissioning. SV/PE J85/6/12 JB 11/6 3.05 Equipment lables are in place and consistent with P&ID. 486/5/5-R7W105 PE SV/ASTB 11/6 3.05 MECH INSTALLATION COMPLETE NA

Revision: A Approved By: Tate Brammer

		REFERENCE		6. 28	Verify o	r Test t	ру		White the second
Item No.	Activity Details	DOCUMENT/ DRAWINGS	S/C				JH	Basses &	Remarks/Records
			Key	Resp.	Sign/Date	Key	Resp.	Sign/Date	
	Pre-commissioning								
4.01	Disconnect compressed air line. Energise compressed air and flush line. Adjust regulator to correct pressure (Verify Max Compressed air Allowed). Reconnect airline to valve.				- 12	н	PE	JB 11/6	-
4.02	Energise valve electrically following energisation procedure.	NA						3611/6	
4.02	Stroke the valve with air manually and ensure actuator is operating normally. Adjust stroke and speed if required.	NA				w	ΡΈ	JB 11/6	
4.05	Check for damage and leave area tidy and clean for next discipline.	NA				w	PE	3611/6	

		APPROVAL	
	NAME	SIGNATURE	DATE
JH	BANG BEECHEL	Jane Beecher	11/6/12

Revis A Approved By: Tate Brammer

Date of Issue: 2.12
Page 1 of 2

AIR ACTU	ATED VALVE >DN50 INSTALLA	TION CHECK SHEET	AREA:				DIGES	TER F	EED PUMP S	TATION	, John
TP ref. No:	8543-001-HX	Project:	Oxley WRP Heat Exc Upgrade	hanger		tion Key: W			Responsibility	Key: SV- Supervisor, SV-	
hecksheet lo.:	8543-M-HX-101	Project Number:	8543					- Project Engineer Sup- nt PM- Project Manager	Holland		
QUIPMENT D	ESCRIPTION:	DIGESTER FEED PU	JMP 3 Outlet Valve						Tag Number:		FCV-625-435
			REFERENCE			Verify o	r Test I	by			104-025-450
Item No.	Activity De	etails	DOCUMENT/	1100	S/C			JH		Remarks/F	Poporde
				Key	Resn	Sign/Date	Kov	_	Sign/Date	Remarks/r	Records
1.00	Record Actuator nameplate da	ta - record any variance	s to below	lite)	Incop.	Oigi II Date	itey	Ivesb.	Sign/Date		
15.11.50.5	Manufacturer: Aeon Kempster	and the same and t	To bolow		1		1	_	1		
	Model: KV7 Lugged Knife gate V	'alve			1		1		L , -		
1.01	DN: 100mm				-		l <sub>w</sub>	PE	JB 31/5		
	Valve Class: GA21-A						1''	1, -	00013		
	With Air Actuator and Limit Switch	ch Box		_	1	_	1		1 F		
	Valve Installation										
2.01	Check internal pipework and clea	ar any debris		Γ	T		le	X			
2.02	Confirm gasket type (SS316 spin						s				
2.03	Check installation direction of valuer vendor manual or arrow on v	lves and ensure it is as alve body.	Aeon KV7 Installation Manual				s	PE	JB11/6		
2.04	Confirm flange alignment and ins correct bolting sequence and tore						s d	Alle .			
2.05	Ensure bolts are well lubricated t	pefore torquing up.					S	19/1/	1		
2.06	torquing completed.	Approx Torque per bolt	Refer to Flange Tightenging Procedure JHG-OXL 037.				s d	Bh			
3,01	Actuator Installation							14 12			
3.03	Verify silences/speed adjustment	ts are installed.	NA				s	SV/PE	TNA T		
3.04	Connect compressed air and ens pressurise until pre-commissionii	sure isolated. Do not	NA				s		J8 5/6/12		
3.05	Equipment lables are in place an	d consistent with P&ID.	486/5/5-R7W105				w	PE	08 n/6		
3.05	MECH INSTALLATION COMPL	ETE	NA				н	sv/Æ	JB11/6		

Revision: A Approved By: Tate Brammer

		REFERENCE			Verify o	r Test b	ру		
Item No.	Activity Details	DOCUMENT/ DRAWINGS	S/C				Jŀ		Remarks/Records
			Key	Resp.	Sign/Date	Key	Resp.	Sign/Date	
	Pre-commissioning								
4.01	Disconnect compressed air line. Energise compressed air and flush line. Adjust regulator to correct pressure (Verify Max Compressed air Allowed). Reconnect airline to valve.					н	PE	JB 11/6	
4.02	Energise valve electrically following energisation procedure.	NA						JB 11/6	
	operating normally. Adjust stroke and speed it required.	NA				w	PE	3811/6	
4.05	Check for damage and leave area tidy and clean for next discipline.	NA				w	PE	JB 11/6	

		APPROVAL.			
	NAME	SIGNATURE	DATE		
JН	JANE BEECHEL	Ine Beecher	11/6/12		

Date of Issue: 2.12

Page 1 of 2

Revis A

Approved By: Tate Brammer

AIR ACTUATED VALVE > DN50 INSTALLATION CHECK SHEET AREA: **DIGESTER FEED PUMP STATION** John Oxley WRP Heat Exchanger ITP ref. No: 8543-001-HX Project: Inspection Key: W -Upgrade Responsibility Key: SV- Supervisor, SV-Witness, H - Hold, S -Surveyor, PE - Project Engineer Sup-Checksheet 8543-M-HX-102 Project Number: Surveillance Superintendent PM- Project Manager **EQUIPMENT DESCRIPTION:** DIGESTER FEED PUMP 2 DISTRIBUTION VALVE TO HX \$ Tag Number: FCV-625-433 Verify or Test by REFERENCE Item No. **Activity Details** DOCUMENT/ S/C Remarks/Records DRAWINGS Resp. Sign/Date Key Resp. Sign/Date 1.00 Record Actuator nameplate data - record any variances to below Manufacturer: Aeon Kempster Model: KV7 Lugged Knife gate Valve 1.01 DN: 100mm JB31/5 Valve Class: GA21-A With Air Actuator and Limit Switch Box 2.00 Valve installation 2.01 Check internal pipework and clear any debris 2.02 Confirm gasket type (SS316 spiral wound gasket rating DN100 PN10-16) 2.03 Check installation direction of valves and ensure it is as per vendor manual or arrow on valve body. Aeon KV7 JB 11/6 Installation Manual 2.04 Confirm flange alignment and install valve making sure of correct bolting sequence and torques. 2.05 Ensure bolts are well lubricated before torquing up. Ensure bolts are torqued up as per spiral wound gasket Refer to Flange 2.06 methodology and torque rating (Approx Torque per bolt 176 Nm for 8 bolts) Mark all bolts with an 'X' after Tightenging Procedure JHG-OXLtorquing completed. 037. 3.01 Actuator Installation 3.03 Verify silences/speed adjustments are installed. NA SV/PE 3.04 Connect compressed air and ensure isolated. Do not pressurise until pre-commissioning. SV/PE JB 5/6/M 3.05 Equipment lables are in place and consistent with P&ID. JB 11/6 486/5/5-R7W105 SV/AG 13 11/6 3.05 MECH INSTALLATION COMPLETE

Revision: A Approved By: Tate Brammer

Date of Issue: 13.02.12 Page 2 of 2

		REFERENCE			Verify o	r Test I	by		
Item No.	Activity Details	DOCUMENT/	S/C			JH			Remarks/Records
	DRAWINGS Key	Key	Resp.	Sign/Date	Key	Resp.	Sign/Date		
	Pre-commissioning					Black.			
4.01	Max Compressed air Allowed). Reconnect airline to	NA				н	PE	JB 11/6	
4.02	Energise valve electrically following energisation procedure.	NA						JB 11/6	
4.02	Stroke the valve with air manually and ensure actuator is operating normally. Adjust stroke and speed if required.	NA				w	PE	JB11/6	
	Check for damage and leave area tidy and clean for next discipline.	NA				w	PE	JB/6	

		APPROVAL	
	NAME	SIGNATURE	DATE
JH	JANE BEECHEL	Ine Beecher	11/6/12

2

Revis A Approved By: Tate Brammer

AIR ACTU	AIR ACTUATED VALVE > DN50 INSTALLATION CHECK SHEET		AREA:				STATION				
TP ref. No:	8543-001-HX	Project:	Oxley WRP Heat Exc Upgrade	changer	Inspec	tion Key: W			Responsibility Key: SV- Supervisor, SV-		John Holland
Checksheet No.:	8543-M-HX-103	Project Number:			Survei	ss, H - Hold, llance	S-		Surveyor, PE – Project Engineer Sup- Superintendent PM- Project Manager		
EQUIPMENT D	DESCRIPTION:	CRIPTION: DIGESTER FEED PL		VALVE	TOHX	2			Tag Numbe	er:	FCV-625-434
			REFERENCE		4	Verify o	r Test	by			1 0 4-023-43-
Item No.	Activit	y Details	DOCUMENT/		S/C			JH	1	Remarks/F	Records
			DRAWINGS	Key	Resp.	Sign/Date	Kev	Resp.	Sign/Date	Nomanon	1000103
1.00	Record Actuator nameplat	e data - record any variance	s to below						1-0		
	Manufacturer: Aeon Kempst	er	The second secon					T			
1.0	Model: KV7 Lugged Knife ga	ate Valve					1		1001		
1.0	DN: 100mm						lw	PE	JB315		
	Valve Class: GA21-A						1	-			
	With Air Actuator and Limit S	Switch Box		$\overline{}$			1				
2.00	Valve installation							-	,		
2.0	1 Check internal pipework and	I clear any debris			1		S	100%	1	F	
2.02	Confirm gasket type (SS316 DN100 PN10-16)	spiral wound gasket rating					S	Ma			
2.03	Check installation direction of per vendor manual or arrow		Aeon KV7 Installation Manual				S	PE	JB11/6		
2.04	Confirm flange alignment an correct bolting sequence and	d install valve making sure of d torques.					s d				
2.05	Ensure bolts are well lubrica						S	1900	<u> </u>		
2.06	Ensure bolts are torqued up methodology and torque ratin 176 Nm for 8 bolts) Mark all torquing completed.	ng (Approx Torque per bolt	Refer to Flange Tightenging Procedure JHG-OXL 037.				S	The second			
	Actuator Installation					44454					
3.03	Verify silences/speed adjusti	ments are installed.	NA				s	SV/PE	NA		
3.04	Connect compressed air and pressurise until pre-commiss	d ensure isolated. Do not sioning.	NA				s		38 5/6/12		
3.05	Equipment lables are in plac	e and consistent with P&ID.	486/5/5-R7W105				w	PE	JB 11/6		
3.05	MECH INSTALLATION COM	MPLETE	NA				н	sv/Æ	JB 11/6		

Revision: A Approved By: Tate Brammer

		REFERENCE	100		Verify o	r Test b	by		
Item No.	Activity Details	DOCUMENT/	OCUMENT/ S			JH			Remarks/Records
		DRAWINGS	Key	Resp.	Sign/Date	Key	Resp.	Sign/Date	
	Pre-commissioning								
4.01	Disconnect compressed air line. Energise compressed air and flush line. Adjust regulator to correct pressure (Verify Max Compressed air Allowed). Reconnect airline to valve.					н	PE	JB 11/6	
4.02	Energise valve electrically following energisation procedure.	NA						JB 11/6	
1	loperating normally. Adjust stroke and speed if required.	NA				w	PE	JB 11/6	
4.05	Check for damage and leave area tidy and clean for next discipline.	NA				w	PE	JB 11/6	

		APPROVAL.	
	NAME	SIGNATURE	DATE
JН	JANE BEECHER	Jane Beecho	11/6/12

Date of Issue: 1 2.12

Page of 2

Revis A

Approved By: Tate Brammer

AIR ACTUATED VALVE > DN50 INSTALLATION CHECK SHEET AREA: **HEAT EXCHANGERS** John Holland Oxley WRP Heat Exchanger ITP ref. No: 8543-001-HX Project: Inspection Key: W -Upgrade Responsibility Key: SV- Supervisor, SV-Witness, H - Hold, S -Surveyor, PE - Project Engineer Sup-Checksheet 8543-M-HX-104 8543 Surveillance Project Number: Superintendent PM- Project Manager EQUIPMENT DESCRIPTION: Heat Exchanger 1 Service Water Drain FCV Tag Number: FCV-626-04 Verify or Test by REFERENCE Item No. S/C **Activity Details** DOCUMENT/ JH Remarks/Records DRAWINGS Resp. Sign/Date Key Resp. Sign/Date 1.00 Record Actuator nameplate data - record any variances to below Manufacturer: RTK Valve Model: PV6211 TB 5/6/17 1.01 DN: 75mm Valve Class: GL01-A Positioner: Siemens Sipart PS2 2.00 Valve installation 2.01 Check internal pipework and clear any debris 2.02 Confirm gasket type (3mm insertion rubber) 2.03 Check installation direction of valves and ensure it is as per vendor manual or arrow on valve body. RTK Manual for PV6211 2.04 Confirm flange alignment and install valve making sure of correct bolting sequence and torques. 2.05 Ensure bolts are well lubricated before torquing up. 2.03 Confirm flange alignment and install valve making sure of correct bolting sequence and torques. 3 Actuator Installation 3.01 Verify silences/speed adjustments are installed. NA Connect compressed air and ensure isolated. Do not 3.02 pressurise until pre-commissioning. 3.03 Equipment lables are in place and consistent with P&ID. 486/5/5-R7W177 DB11/6 3.04 MECH INSTALLATION COMPLETE SV/PE J8 5/6/17 NA 4.00 Pre-commissioning 4.01 Energise compressed air and adjust regulator to correct pressure (Verify max pressure on actuator) JB 5/6/12 PE

Revision: A

Approved By: Tate Brammer

		REFERENCE			Verify o				
Item No.	Activity Details	DOCUMENT/	S/C			Jt			Remarks/Records
		DRAWINGS	Key	Resp.	Sign/Date	Key	Resp.	Sign/Date	
	Energise valve electrically following energisation procedure.	NA				w	PE	38 5/6/12	
4.03	Run auto setup for sipart positioners and record settings and attach to this checksheet.	Siemens Sipart PS2 PA Manual				w	PE	JB 5/6/12	
4.04	Stroke the valve manually and ensure gearbox operating normally. Adjust stroke and speed if required.	NA				w	PE	185/6/12	
4.05	Check for damage and leave area tidy and clean for next discipline.	NA				w	PE	JB5/6/12	

		APPROVAL	
	NAME	SIGNATURE	DATE
JH	JANE SCECHEL	Jone Beeche	11/6/12

Revis A Approved By: Tate Brammer

AIR ACTU	ATED VALVE > DN50 INSTALLAT	TION CHECK SHEET	AREA:					HEAT	EXCHANGERS		
TP ref. No:	8543-001-HX	Project:	Oxley WRP Heat Ex Upgrade	kchanger		tion Key: W			Responsibility Key: SV- Supervisor, SV-		<b>I. John</b>
Checksheet No.:	8543-M-HX-105	Project Number:			Witness, H - Hold, S - Surveillance				Surveyor, PE – Project Engineer Sup- Superintendent PM- Project Manager		Holland
QUIPMENT D	DESCRIPTION:	Heat Exchanger 2 Se	ervice Water Drain FC	V					Tag Number:		FCV-626-06
			REFERENCE			Verify o	r Test	by			1 0 4-020-00
Item No.	Activity De	Activity Details		Key	S/C Key Resp. Sign/Date		Key	Jh	Sign/Date	Remarks	Records
1.00	Record Actuator nameplate da	ta - record any variance	s to below	1,	рксор/	lo gin bate	lito	Плевр.	Olgin Date		- F2 - F4 - F4
	Manufacturer: RTK			1			1	T			
	Valve Model: PV6211		1				1				
1.01	DN: 75mm		NA				w	PE	JB31/5		
	Valve Class: GL01-A						1		0- /-		
	Positioner: Siemens Sipart PS2						1				
	Valve Installation							-			
2.01	Check internal pipework and clea	ar any debris	NA				s	Mich	7		
2.02	Confirm gasket type (3mm inser	tion rubber)	NA				s				
2.03	Check installation direction of val per vendor manual or arrow on va	ves and ensure it is as alve body.	RTK Manual for PV6211				S				
2.04	Confirm flange alignment and ins correct bolting sequence and torce	tall valve making sure of ques.	NA				s				
2.05	Ensure bolts are well lubricated b	pefore torquing up.	NA	+			S		7		
2.03	Confirm flange alignment and instance correct bolting sequence and toro	tall valve making sure of ques.	NA				s				<u> </u>
3	Actuator Installation										
3.01	Verify silences/speed adjustment	s are installed.	NA				s	SV/PE	NA		
	Connect compressed air and ens pressurise until pre-commissionir		NA				s		JB 5/6/12		
3.03	Equipment lables are in place and	d consistent with P&ID.	486/5/5-R7W177				w	PE	JB 11/6		
3.04	MECH INSTALLATION COMPLE	ETE	NA				Н	SV/PE	JB5/6/17		
	Pre-commissioning								11914		
4.01	Energise compressed air and adjunction pressure (Verify max pressure of	ust regulator to correct on actuator)	NA				Н	PE	385/6/12		

Revision: A Approved By: Tate Brammer

		REFERENCE		7-10	Verify o	r Test I	ру		
Item No.	Activity Details				JH		Remarks/Records		
		DRAWINGS	Key	Resp.	Sign/Date	Key	Resp.	Sign/Date	
	Energise valve electrically following energisation procedure.	NA				w	PE	J8 5/6/12	
4.03	Run auto setup for sipart positioners and record settings and attach to this checksheet.	Siemens Sipart PS2 PA Manual				w	PE	385/6/12	
4.04	Stroke the valve manually and ensure gearbox operating normally. Adjust stroke and speed if required.	NA				w	PE	185/6/12	
4.05	Check for damage and leave area tidy and clean for next discipline.	NA				w	PE	38 5/6/12	

		APPROVAL	
	NAME	SIGNATURE	DATE
JH	JANE BEGUIER	Jane Rewho	11/6/12

Page of 2

Revis A

Date of Issue: 1 2.12 Approved By: Tate Brammer

AIR ACTUATED VALVE > DN50 INSTALLATION CHECK SHEET AREA: **HEAT EXCHANGERS** John Oxley WRP Heat Exchanger ITP ref. No: 8543-001-HX Project: Inspection Key: W -Responsibility Key: SV- Supervisor, SV-Upgrade Holland Witness, H - Hold, S -Surveyor, PE - Project Engineer Sup-Checksheet 8543-M-HX-106 Surveillance Project Number: Superintendent PM- Project Manager EQUIPMENT DESCRIPTION: HEAT EXCHANGER 1 SLUDGE DISCHARGE VALVE Tag Number: FCV-626-13 Verify or Test by REFERENCE Item No. **Activity Details** DOCUMENT/ JH Remarks/Records DRAWINGS Resp. Sign/Date Key Resp. Sign/Date 1.00 Record Actuator nameplate data - record any variances to below Manufacturer: Tyco - Keystone 1.01 Model: VLV KGV F55 JB 31/5 DN: 100mm With Air Actuator and Limit Switch Box 2.00 Valve installation 2.01 Check internal pipework and clear any debris Confirm gasket type (SS316 spiral wound gasket rating 2.02 DN100 PN10-16) 2.03 Check installation direction of valves and ensure it is as per vendor manual or arrow on valve body. Tyco Keystone O&M JB5/6/12 manual 2.04 Confirm flange alignment and install valve making sure of correct bolting sequence and torques. 2.05 Ensure bolts are well lubricated before torquing up. Ensure bolts are torqued up as per spiral wound gasket Refer to Flange 2.06 methodology and torque rating (Approx Torque per bolt 176 Nm for 8 bolts) Mark all bolts with an 'X' after Tightenging Procedure JHG-OXLtorquing completed. 037. 3.01 Actuator Installation 3.03 Verify silences/speed adjustments are installed. SV/PE NA Connect compressed air and ensure isolated. Do not SV/PE JB 5/6/17 pressurise until pre-commissioning. JB 1/6 3.05 Equipment lables are in place and consistent with P&ID. 486/5/5-R7D177 PE 3.05 MECH INSTALLATION COMPLETE NA 4.00 Pre-commissioning

Revision: A Approved By: Tate Brammer

		REFERENCE		3.8	Verify o	r Test b	у		
Item No.	Activity Details	DOCUMENT/	S/C			JH			Remarks/Records
		DRAWINGS	Key	Resp.	Sign/Date	Key	Resp.	Sign/Date	
4.01	Disconnect compressed air line. Energise compressed air and flush line. Adjust regulator to correct pressure (Verify Max Compressed air Allowed). Reconnect airline to valve.	NA				н	PE	J85/6/12	
4.02	Energise valve electrically following energisation procedure.	NA						JB5/6/17	
4.03	Stroke the valve with air manually and ensure actuator is operating normally. Adjust stroke and speed if required.	NA				w	PE	385/6/12	
4.08	Check for damage and leave area tidy and clean for next discipline.	NA				w	PE	JB 5/6/12	

		APPROVAL	
	NAME	SIGNATURE	DATE
JH	JANE BEECHER	Ine Beecher	11/6/12

Date of Issue: 2.12

Revis : A

Approved By: Tate Brammer

Page 1 of 2 AIR ACTUATED VALVE > DN50 INSTALLATION CHECK SHEET AREA: **HEAT EXCHANGERS** Oxley WRP Heat Exchanger John 8543-001-HX ITP ref. No: Project: Inspection Key: W -Upgrade Responsibility Key: SV- Supervisor, SV-Witness, H - Hold, S -Surveyor, PE - Project Engineer Sup-Checksheet 8543-M-HX-108 Surveillance Project Number: 8543 Superintendent PM- Project Manager EQUIPMENT DESCRIPTION: HEAT EXCHANGER 1 SW FLUSH INLET VALVE Tag Number: FCV-626-90 Verify or Test by REFERENCE Item No. **Activity Details** S/C DOCUMENT/ Remarks/Records DRAWINGS Resp. Sign/Date Key Resp. Sign/Date 1.00 Record nameplate data - record any variances to below Actuator Type: Air actuator DN50 J85/6/12 Serial No .: 1.02 Valve issued as per specification/ purchase order PE JB5/6/17 2.00 Valve installation 2.01 Check internal pipework and clear any debris Confirm alignment and install valve making sure valve is securely tightened. 2.03 Check installation direction of valves and ensure it is as per vendor manual or arrow on valve body. Check manual handles have correct access and no JB 5/6/12 restriction for operation 3.01 Actuator Installation If installing the actuator separately ensure valve is secure 3.01 before fitting the actuator. 3.02 Fit the actuator to valve as per vendor recommendations. 3.03 Verify silences/speed adjustments are installed. SV/PE NA 3.04 Flush compressed airline. SV/PE J85/6/12 SV/PE JB5/6/12 3.05 Connect compressed air. Verify compressed air is within manufacturers recommendations. (5.6 bar to 10bar). s JB 11/6 3.06 Equipment lables are in place and consistent with P&ID. 486/5/5-R7D177 JB 5/6/12 3.07 Ensure Limit Switches are installed and ready for wiring.

MECH INSTALLATION COMPLETE

Revision: A

Approved By: Tate Brammer

		REFERENCE			Verify o	r Test b			
Item No.	Activity Details	DOCUMENT/	S/C			JH			Remarks/Records
		DRAWINGS	Key	Resp.	Sign/Date	Key	Resp.	Sign/Date	
4.00	Pre-commissioning								
4.01	Energise compressed air and check for leaks.					S	SVIP	EJ85/6/11	
4.02	Stroke the valve manually and ensure gearbox operating normally. Adjust stroke and speed if required.					w	PE	JB 11/6	
4.05	Check for damage and leave area tidy and clean for next discipline.					w	PE	JB 11/6	

	APPROVAL APPROVAL								
	NAME	SIGNATURE	DATE						
Н	JANE BEECUER	Love Leadies	11/6/19						

AREA:

486/5/5-R7D177

MECH INSTALLATION COMPLETE

Date of Issue: 12.12

Page 1 of 2

Revis : A

ITP ref. No:

Checksheet

Item No.

Approved By: Tate Brammer

AIR ACTUATED VALVE > DN50 INSTALLATION CHECK SHEET

3.06 Equipment lables are in place and consistent with P&ID.

3.07 Ensure Limit Switches are installed and ready for wiring.

John Oxley WRP Heat Exchanger 8543-001-HX Project: nspection Key: W -Upgrade Responsibility Key: SV- Supervisor, SV-Holland Witness, H - Hold, S -Surveyor, PE - Project Engineer Sup-8543-M-HX-109 Project Number: Surveillance 8543 Superintendent PM- Project Manager EQUIPMENT DESCRIPTION: HEAT EXCHANGER 2 SW FLUSH INLET VALVE Tag Number: FCV-626-94 Verify or Test by REFERENCE **Activity Details** DOCUMENT/ S/C JH Remarks/Records DRAWINGS Resp. Sign/Date Key Resp. Sign/Date 1.00 Record nameplate data - record any variances to below Actuator Type: Air actuator DN50 18 5/6/12 Serial No.: 385/6/12 1.02 Valve issued as per specification/ purchase order PE 2.00 Valve Installation 2.01 Check internal pipework and clear any debris 2.02 Confirm alignment and install valve making sure valve is securely tightened. 2.03 Check installation direction of valves and ensure it is as per vendor manual or arrow on valve body. 2.04 Check manual handles have correct access and no restriction for operation 3856/12 3.01 Actuator Installation 3.01 If installing the actuator separately ensure valve is secure before fitting the actuator. 3.02 Fit the actuator to valve as per vendor recommendations. 3.03 Verify silences/speed adjustments are installed. SV/PE /U/A SV/PE JB 5/6/17 3.04 Flush compressed airline. 3.05 Connect compressed air. Verify compressed air is within manufacturers recommendations. (5.6 bar to 10bar). SV/PE 385/6/12 s

**HEAT EXCHANGERS** 

Revision: A Approved By: Tate Brammer

		REFERENCE			Verify or	r Test I	by		
Item No.	Activity Details	DOCUMENT/		S/C			Jŀ		Remarks/Records
		DRAWINGS	Key	Resp.	Sign/Date	Key	Resp.	Sign/Date	
4.00	Pre-commissioning								
4.01	Energise compressed air and check for leaks.			T		s	SV /	938 5/6/12	
4.02	Stroke the valve manually and ensure gearbox operating normally. Adjust stroke and speed if required.					w	PE	185/6/12	
4.05	Check for damage and leave area tidy and clean for next discipline.					w	PE	JB5/6/12	

		APPROVAL	
	NAME	SIGNATURE	DATE
JH	JANE SEGUIER	Fac Beacher	11/6/12

Date of Issue: 12.12

Page 1 of 2

Revit : A

Approved By: Tate Brammer

AIR ACTUATED VALVE > DN50 INSTALLATION CHECK SHEET AREA: **HEAT EXCHANGERS** John Oxley WRP Heat Exchanger ITP ref. No: 8543-001-HX Project: Inspection Key: W -Upgrade Responsibility Key: SV- Supervisor, SV-Witness, H - Hold, S -Surveyor, PE - Project Engineer Sup-Checksheet 8543-M-HX-110 Surveillance Project Number: 8543 Superintendent PM- Project Manager EQUIPMENT DESCRIPTION: HEAT EXCHANGER 1 SW FLUSH DISCHARGE VALVE Tag Number: FCV-626-14 Verify or Test by REFERENCE Item No. **Activity Details** S/C DOCUMENT/ JH Remarks/Records DRAWINGS Resp. Sign/Date Key Resp. Sign/Date 1.00 Record nameplate data - record any variances to below Actuator Type: Air actuator DN50 JB 5/6/12 Serial No.: 1.02 Valve issued as per specification/ purchase order PE w 2.00 Valve installation 2.01 Check internal pipework and clear any debris Confirm alignment and install valve making sure valve is 2.02 securely tightened. 2.03 Check installation direction of valves and ensure it is as per vendor manual or arrow on valve body. Check manual handles have correct access and no JBSKIN restriction for operation 3.01 Actuator Installation If installing the actuator separately ensure valve is secure 3.01 before fitting the actuator. 3.02 Fit the actuator to valve as per vendor recommendations. 3.03 Verify silences/speed adjustments are installed. SV/PE MA SV/PE JB 5/6/17 3.04 Flush compressed airline. Connect compressed air. Verify compressed air is within 3.05 manufacturers recommendations. (5.6 bar to 10bar). SV/PE JB 5/6/17 JB 5/6/12 3.06 Equipment lables are in place and consistent with P&ID. 486/5/5-R7D177 3.07 Ensure Limit Switches are installed and ready for wiring.

MECH INSTALLATION COMPLETE

Revision: A Approved By: Tate Brammer

		REFERENCE DOCUMENT/ DRAWINGS		Verify o			
Item No.	Activity Details			S/C		JH	Remarks/Records
			Key	Resp. Sign/Date	Key	Resp. Sign/Date	
4.0	0 Pre-commissioning						
4.0	1 Energise compressed air and check for leaks.			O La	S	SV/PE-18 5/6/12	
4.02	Stroke the valve manually and ensure gearbox operating normally. Adjust stroke and speed if required.				w	PE IB 5/6/12	
4.0	Check for damage and leave area tidy and clean for next discipline.				w	PE 585/6/12	

		APPROVAL	
	NAME	SIGNATURE	DATE
JH	JANG SECHEL	Jane Beecher	11/6/12

Date of Issue: 2.12

Page 1 of 2

Revis : A

Approved By: Tate Brammer

AIR ACTUATED VALVE > DN50 INSTALLATION CHECK SHEET AREA: **HEAT EXCHANGERS** John Oxley WRP Heat Exchanger ITP ref. No: 8543-001-HX Project: Inspection Key: W -Upgrade Responsibility Key: SV- Supervisor, SV-Holland Witness, H - Hold, S -Surveyor, PE - Project Engineer Sup-Checksheet 8543-M-HX-111 8543 Surveillance Project Number: Superintendent PM- Project Manager EQUIPMENT DESCRIPTION: HEAT EXCHANGER 2 SW FLUSH DISCHARGE VALVE Tag Number: FCV-626-24 Verify or Test by REFERENCE Item No. **Activity Details** S/C DOCUMENT/ JH Remarks/Records DRAWINGS Resp. Sign/Date Key Resp. Sign/Date 1.00 Record nameplate data - record any variances to below Actuator Type: Air actuator DN50 JB 5/4/2 Serial No.: 385/6/12 1.02 Valve issued as per specification/ purchase order PE 2.00 Valve installation 2.01 Check internal pipework and clear any debris Confirm alignment and install valve making sure valve is securely tightened. Check installation direction of valves and ensure it is as per vendor manual or arrow on valve body. Check manual handles have correct access and no JB 5/6/12 restriction for operation 3.01 Actuator Installation If installing the actuator separately ensure valve is secure 3.01 before fitting the actuator. 3.02 Fit the actuator to valve as per vendor recommendations. SV/PE AA 3.03 Verify silences/speed adjustments are installed. SV/PE 385/6/17 3.04 Flush compressed airline. Connect compressed air. Verify compressed air is within SV/PE 165/6/12 manufacturers recommendations. (5.6 bar to 10bar). 3.06 Equipment lables are in place and consistent with P&ID. JB 5/6/17 486/5/5-R7D177 sv/PE 88 5/6/12 3.07 Ensure Limit Switches are installed and ready for wiring.

MECH INSTALLATION COMPLETE

Revision: A Approved By: Tate Brammer

		REFERENCE			Verify o				
Item No.	Activity Details	DOCUMENT/	S/C			JH			Remarks/Records
		DRAWINGS	Key	Resp.	Sign/Date	Key	Resp.	Sign/Date	
4.00	Pre-commissioning								
4.01	Energise compressed air and check for leaks.					S	SVPE	385/6/12	
4.02	Stroke the valve manually and ensure gearbox operating normally. Adjust stroke and speed if required.					w	PE	385/6/12	
4.05	Check for damage and leave area tidy and clean for next discipline.					w	PE	JE 5/6/12	

		APPROVAL	
	NAME	SIGNATURE	DATE
JН	JANE BEECHER	In beeche	11/6/12

Revit : A Approved By: Tate Brammer

Date of Issue: 1 \2.12 Page 1 of 2

AIR ACTUA	ATED VALVE >DN50 INSTA	LLATION CHECK SHEET	AREA:				HEAT E					
TP ref. No:	8543-001-HX	Project:	Oxley WRP Heat Exc Upgrade	changer		ion Key: W			Responsibility Key:	SV- Supervisor, SV-	John Holland	
Checksheet lo.:	8543-M-HX-107	Project Number:	8543		Surveill	s, H - Hold, ance	5-		Surveyor, PE – Project Engineer Sup- Superintendent PM- Project Manager			
QUIPMENT D	ESCRIPTION:	HEAT EXCHANGER	R 2 SLUDGE DISCHARGE VALVE						Tag Number:		FCV-626-23	
			REFERENCE			Verify o	r Test	by				
Item No.	Activit	ty Details	DOCUMENT/		S/C			JH		Remarks/F	Records	
			DRAWINGS	Key	Resp.	Sign/Date	Key	Resp.	Sign/Date			
		te data - record any variance	s to below									
	Manufacturer: Tyco - Keysto	one			1							
	Model: VLV KGV F55						1	DE	JB 5/6/n			
	DN: 100mm		125				W	PE	00 3/9/16			
	With Air Actuator and Limit	Switch Box		Tric								
	Valve installation				40000		0.00	ALL				
2.01	Check internal pipework and	,					S	Sh	-			
2.02	Confirm gasket type (SS316 DN100 PN10-16)	spiral wound gasket rating					s	1/2				
	Check installation direction of per vendor manual or arrow		Tyco Keystone O&M manual				s	PE	385/6/12			
2.04	Confirm flange alignment an correct bolting sequence and	nd install valve making sure of d torques.					s	EL.				
2.05	Ensure bolts are well lubrica						S	A STATE OF THE PARTY OF THE PAR				
2.06	Ensure bolts are torqued up methodology and torque rati 176 Nm for 8 bolts) Mark a torquing completed.	ing (Approx Torque per bolt	Refer to Flange Tightenging Procedure JHG-OXL 037.				s	Wh				
3.01	Actuator Installation											
3.03	Verify silences/speed adjust	ments are installed.	NA				s	SV/PE	NA			
3.04	Connect compressed air and pressurise until pre-commiss		NA				s	SV/PE	JB SKIZ			
3.05	Equipment lables are in place	ce and consistent with P&ID.	486/5/5-R7D177				w	PE	JB 11/6			
3.05	MECH INSTALLATION CO	MPLETE	NA				н	sv/P6	JB 5/6/12			

Revision: A Approved By: Tate Brammer

100		REFERENCE			Verify o	r Test I	by	100	
Item No.	Activity Details	DOCUMENT/		S/C			JH		Remarks/Records
		DRAWINGS	Key	Resp.	Sign/Date	Key	Resp.	Sign/Date	
4.01	Disconnect compressed air line. Energise compressed air and flush line. Adjust regulator to correct pressure (Verify Max Compressed air Allowed). Reconnect airline to valve.					н	PĖ	385/6/12	
4.02	Energise valve electrically following energisation procedure.	NA						385/6/12	
4.02	Stroke the valve with air manually and ensure actuator is operating normally. Adjust stroke and speed if required.	NA				w	BE <sub>3</sub> ·	385/4/12	
4.05	Check for damage and leave area tidy and clean for next discipline.	NA				w	PE	JB5/6/12	,

		APPROVAL	
	NAME	SIGNATURE	DATE
JH	JANE SEECHER	Jan Beecher	11/6/12

Revision: A Approved By: Tate Brammer

Date c :ue: 13.02.12 Page 1 of 2

11	ISTRUMENT INSTALLATION	N CHECK SHEET	AREA:				DIGE	STER F	EED PUMP	STATION	Mark September	
TP ref. No:	8543-001-HX	Project:	Oxley WRP Heat Ex Upgrade	kchanger		tion Key: W			Responsibili	ity Key: SV- Supervisor, SV-	, John	
Checksheet No.:	8543-M-HX-200	Project Number:								E – Project Engineer Sup- dent PM- Project Manager	Holland	
QUIPMENT I	QUIPMENT DESCRIPTION: DIGESTER FEED		PUMP 1 FLOWMETER						Tag Numbe	er:	FIT-625-409	
			REFERENCE			Verify o	r Test	by			111-020-403	
Item No.	Activi	ty Details	DOCUMENT/		S/C			JI	1	Remarks/I	Records	
			DRAWINGS	Key	Resp.	Sign/Date	Key	Resp.	Sign/Date	, , , , , , , , , , , , , , , , , , ,	(10,10,10,00,	
1.0		record any variances to belo	ow.									
	Manufacturer: Endress & Ha	auser										
	Model: Promag P						1					
	Order Code: 50P65-EA1A1/	AA0KFAH	1				1					
	Serial No.: ECO1292	-0000					1		70 01			
1.0	1 k-FACTOR:			1	1		l <sub>w</sub>	PE	JB31/5	· · · · · · · · · · · · · · · · · · ·		
	Size: DN65			+			┤``	~				
	Pressure rating: PN40	Pressure rating: PN40		+	+	-	1		-			
	Temperature rating:			+	+		┨					
	Protection: IP67			+-	+		1					
1.02	2 Instrument issued as per sp	ecifications/ purchase order					w	PE	JB 3/5	<u> </u>		
2.0	Instrument Installation							and the				
2.0	1 Check internal pipework and	d clear any debris	NA				s	A L				
2.03	Install the instrument upstre tees, elbows etc. and ensure run is maintained as follows Inlet run: ≥ 5xDN and Outle	e the correct inlet and outlet	E&H Manual for Magflow Meter.				S	The second				
2.03	Confirm flange alignment an sure of correct bolting seque	nd install instrument making ence and torques (20-44Nm).	NA				s	Selez.				
2.04	Ensure bolts are well lubrica	ated before torquing up.					s d	John .				
2.05	Install instruments with corre wound gaskets)	ect gaskets. (3mm spiral	NA				s					

Revision: A

Approved By: Tate Brammer

Activity Details re bolts are torqued up as per spiral wound gasket	REFERENCE DOCUMENT/ DRAWINGS		S/C			ILL		
re holts are torqued up as not spiral wound assist	DRAWINGS	· cons			JH			Remarks/Records
re holts are torqued up as per spiral wound assket		Key	Resp.	Sign/Date	Key	Resp.	Sign/Date	
odology and torque rating (Approx Torque per bolt m for 8 bolts) Mark all bolts with an 'X' after torquing					s		?	
oment lables are in place and consistent with P&ID.	486/5/5-R7D185				w	PE	3831/5	
up and fasten the cable ready for electrical installation	NA				s	Alla.		
k for damage and leave area tidy and clean for next bline.	NA				w	PE	JB 31/5	
on	nent lables are in place and consistent with P&ID.  and fasten the cable ready for electrical installation	nent lables are in place and consistent with P&ID.  and fasten the cable ready for electrical installation for damage and leave area tidy and clean for next ne.  E&H O&M manual 486/5/5-R7D185	nent lables are in place and consistent with P&ID.  and fasten the cable ready for electrical installation of the damage and leave area tidy and clean for next ne.  E&H O&M manual 486/5/5-R7D185	nent lables are in place and consistent with P&ID.  and fasten the cable ready for electrical installation for damage and leave area tidy and clean for next ne.	nent lables are in place and consistent with P&ID.  and fasten the cable ready for electrical installation for damage and leave area tidy and clean for next ne.	nent lables are in place and consistent with P&ID.  486/5/5-R7D185  W  and fasten the cable ready for electrical installation  NA  S	nent lables are in place and consistent with P&ID.  486/5/5-R7D185  W PE  and fasten the cable ready for electrical installation for damage and leave area tidy and clean for next ne.  NA  W PE	nent lables are in place and consistent with P&ID.  486/5/5-R7D185  W PE 351/5  and fasten the cable ready for electrical installation NA  solution for damage and leave area tidy and clean for next ne.

		APPROVAL	
	NAME	SIGNATURE	DATE
JH	JANG SEECHER	Jan Beecher	5/6/12

Revision: A Approved By: Tate Brammer

Date c sue: 13.02.12 Page 1 of 2

- IN	ISTRUMENT INSTALLATION	N CHECK SHEET	AREA:				DIGE	STER F	EED PUMP	STATION	
ΓP ref. No:	8543-001-HX	Project:	Oxley WRP Heat Ex Upgrade	changer		ion Key: W			Responsibili	ty Key: SV- Supervisor, SV-	John
hecksheet lo.:	8543-M-HX-201			8543			S-		Surveyor, Pl Superintend	E – Project Engineer Sup- ent PM- Project Manager	Holland
QUIPMENT	DESCRIPTION:	DIGESTER FEED P	UMP 2 FLOWMETER	9					Tag Numbe	TG .	FIT-625-408
			REFERENCE	1		Verify o	r Test	by			111-023-400
Item No.	Activi	ty Details	DOCUMENT/		S/C			JI	1	Remarks/F	Records
			DRAWINGS	Key	Resp.	Sign/Date	Key	Resp.	Sign/Date		
1.00	The second secon	record any variances to belo	w								
	Manufacturer: Endress & Ha	auser									
	Model: Promag P						1				
	Order Code: 50P65-EA1A1/	AA0KFAH			11				1		
	Serial No.: EC01282	20000					1		-10 o.la		
1.01	k-FACTOR:			+-	1		lw	PE	JB 31/5		
	Size: DN65		<del>                                     </del>	_	_		- ∃	ļ. –			
	Pressure rating: PN40			+	-						
	Temperature rating:			+-	$\vdash$		1		1 }		
	Protection: IP67			+-			1				
1.02	Instrument issued as per sp	ecifications/ purchase order					w	PE	JB 31/5		
2.00	Instrument installation							all			
2.01	Check internal pipework and	d clear any debris	NA				S	NO			
2.02	Install the instrument upstre tees, elbows etc. and ensure run is maintained as follows Inlet run: ≥ 5xDN and Outle	e the correct inlet and outlet :	E&H Manual for Magflow Meter.				S	SVIP			
2.03	Confirm flange alignment an sure of correct bolting seque	nd install instrument making ence and torques (20-44Nm).	NA				s	Ela.			
2.04	Ensure bolts are well lubrica						s	alle			
2.05	Install instruments with corre	ect gaskets. (3mm spiral	NA				s				

Revision: A

Approved By: Tate Brammer

Activity Details  are torqued up as per spiral wound gasket and torque rating (Approx Torque per bolt bolts) Mark all bolts with an 'X' after torquing	REFERENCE DOCUMENT/ DRAWINGS	Key	S/C Resp.	Sign/Date	Kov	JH		Remarks/Records
are torqued up as per spiral wound gasket and torque rating (Approx Torque per bolt holts) Mark all holts with an IVI offer to require	Refer to Flange	Key	Resp.	Sign/Date	Kov	-2000	No.	
are torqued up as per spiral wound gasket and torque rating (Approx Torque per bolt holts) Mark all holts with an IXI after torquing	Refer to Flange				ney	Resp.	Sign/Date	
	Procedure from  E&H O&M manual				s	SV		
ables are in place and consistent with P&ID.	486/5/5-R7D185				w	PE	28315	
asten the cable ready for electrical installation	NA				s			
mage and leave area tidy and clean for next	NA				w	PE	JB 31/5	
		asten the cable ready for electrical installation NA mage and leave area tidy and clean for next NA	mage and leave area tidy and clean for next NA					

		APPROVAL	
	NAME	SIGNATURE	DATE
JН	JANG BEECHER	The Beedle	5/6/12

Revision: A

Approved By: Tate Brammer

Date c sue: 13.02.12 Page 1 of 2

IN	ISTRUMENT INSTALLATION	N CHECK SHEET	AREA:				DIGE	STER F	EED PUMP ST	ATION	
TP ref. No:	8543-001-HX	Project:	Oxley WRP Heat Ex Upgrade	changer	Inspec	tion Key: W	1-		Responsibility I	Key: SV- Supervisor, SV-	John Holland
hecksheet lo.:	8543-M-HX-202 Project Number:		8543	Witness, H - Hold, S - Surveillance				Surveyor, PE – Project Engineer Sup- Superintendent PM- Project Manager			
QUIPMENT D	DESCRIPTION:	DIGESTER FEED P	UMP 3 FLOWMETER						Tag Number:		FIT-625-410
			REFERENCE			Verify o	r Test	by			111-025-410
Item No.	Activi	ty Details	DOCUMENT/		S/C			J	1	Remarks/F	Records
			DRAWINGS	Key	Resp.	Sign/Date	Key	Resp.	Sign/Date		
1.00		record any variances to belo	W								
	Manufacturer: Endress & Ha	auser									
	Model: Promag P						1				
	Order Code: 50P65-EA1A1/				1		1		1		
	Serial No.: F 3012321	2000		_		-	1		40 2.4		
1.01	k-FACTOR:			1		<del>                                     </del>	w	PE	JB31/5-		_
	Size: DN65			+	+	<del>                                     </del>		1	l ⊢		
	Pressure rating: PN40			+-	+-	<del> </del>	1		-		
	Temperature rating:			+	+		1		.⊢		
	Protection: IP67			+-	+		1		1 <b>-</b>		
1.02	Instrument issued as per sp	ecifications/ purchase order					w	PE	JB 31/5		
2.00	Instrument Installation							alle	/		
2.01	1 Check internal pipework and	d clear any debris	NA	I	T	_ <del></del>	S	13 50/12			
2.02	Install the instrument upstre tees, elbows etc. and ensure run is maintained as follows Inlet run: ≥ 5xDN and Outle	e the correct inlet and outlet :	E&H Manual for Magflow Meter.				S	The same			
2.03	Confirm flange alignment an sure of correct bolting seque	nd install instrument making ence and torques (20-44Nm).	NA				s				
2.04	Ensure bolts are well lubrica						s	Wh.			
2.05	Install instruments with corre wound gaskets)	ect gaskets. (3mm spiral	NA				s		<u>'</u>		

Revision: A

Approved By: Tate Brammer

		REFERENCE			Verify o	r Test I	by		
Item No.	Activity Details	DOCUMENT/		S/C		JH		ACCUPATION OF THE PARTY OF THE	Remarks/Records
		DRAWINGS	Key	Resp.	Sign/Date	Key	Resp.	Sign/Date	
2.06	methodology and torque rating (Approx Torque per bolt 43 Nm for 8 bolts) Mark all bolts with an 'X' after torquing	Refer to Flange Tightenging Procedure from E&H O&M manual				s	Sy		
2.07	Equipment lables are in place and consistent with P&ID.	486/5/5-R7D185				w	PE	2831/5	
2.08	Roll up and fasten the cable ready for electrical installation	NA				s			
2.09	Check for damage and leave area tidy and clean for next discipline.	NA				w	PE	JB31/5	
		MECH INST	TALLA	TION	COMPLE	TE	100		

13		APPROVAL	
	NAME	SIGNATURE	DATE
JH	JANE BEECUBR	Jan Beedre	5/6/12

Date ( sue: 13.02.12

Page 1 of 2

Revision: A

Approved By: 1 ate Brammer

INSTRUMENT INSTALLATION CHECK SHEET AREA: DIGESTER FEED PUMP STATION Oxley WRP Heat Exchanger ITP ref. No: 8543-001-HX Project: Inspection Key: W -Upgrade Responsibility Key: SV- Supervisor, SV-Witness, H - Hold, S -Surveyor, PE - Project Engineer Sup-Checksheet 8543-M-HX-203 Surveillance Project Number: Superintendent PM- Project Manager **EQUIPMENT DESCRIPTION:** DIGESTER FEED PUMP 1 PRESSURE TRANSMITTER Tag Number: PIT-625-405 Verify or Test by REFERENCE Item No. **Activity Details** DOCUMENT/ S/C JH Remarks/Records DRAWINGS Resp. Sign/Date Key Resp. Sign/Date 1.00 Record nameplate data - record any variances to below Manufacturer: Endress & Hauser Model: Cerabar M Order Code: PMC51-V-JU2/0 Serial No.: ECQ 821128 JB 31/5 Size: DN50 Pressure rating: PN40 Process Connection: DN50 PN10-40 B1, 316L flange EN1092-1 J831/5 1.02 Instrument issued as per specifications/ purchase order 2.00 Instrument installation 2.01 Check internal pipework and clear any debris 2.02 Confirm flange alignment and install instrument making sure of correct bolting sequence. 2.03 Ensure bolts are well lubricated before torquing up. Install instruments with correct gaskets. (3mm spiral 2.04 wound gaskets) Ensure bolts are torqued up as per spiral wound gasket Refer to Flange 2.05 methodology and torque rating (Approx Torque per bolt Tightenging 160 Nm for 4 bolts) Mark all bolts with an 'X' after Procedure 2.06 Equipment lables are in place and consistent with P&ID. JB 31/5 486/5/5-R7D185 2.07 Roll up and fasten the cable ready for electrical installation NA

Revision: A

Approved By: Tate Brammer

		REFERENCE	1		Verify o	r Test	by		
Item No.	Activity Details	DOCUMENT/		S/C			JH		Remarks/Records
		DRAWINGS	Key	Resp.	Sign/Date	Key	Resp.	Sign/Date	
2.08	Check for damage and leave area tidy and clean for next discipline.	NA				w	PE	JB31/5	
	AND RESIDENCE OF THE RE	MECH INS	TALL	ATION	COMPLE	TE	-		

		APPROVAL	
	NAME	SIGNATURE	DATE
JH	JANE BEECHER	Jan Berolier	5/6/12

Revision: A

Approved By: 1 ate Brammer

Date c sue: 13.02.12 Page 1 of 2

11/	ISTRUMENT INSTALLATION	I CHECK SHEET	AREA:				DIGE	STER F	EED PUMP	STATION	WE TO SEE
TP ref. No:	8543-001-HX	Project:	Oxley WRP Heat Ex Upgrade	kchanger	Inspec	tion Key: W			Responsibili	ty Key: SV- Supervisor, SV-	<b>John</b>
Checksheet No.:	8543-M-HX-204	Project Number:	8543		Witness, H - Hold, S - Surveillance				Surveyor, PE – Project Engineer Sup- Superintendent PM- Project Manager		Holland
QUIPMENT D	DESCRIPTION:	DIGESTER FEED P	UMP 2 PRESSURE T	RANSM	TTER				Tag Numbe	ri e	PIT-625-41:
			REFERENCE			Verify o	r Test	by			111-023-41
Item No.	Activit	y Details	DOCUMENT/		S/C			Jŀ	1	Remarks/F	Records
			DRAWINGS	Key	Resp.	Sign/Date	Key	Resp.	Sign/Date		
1.00	Record nameplate data - r	COLD PARTITION OF THE P	ow .								
	Manufacturer: Endress & Ha	user									
	Model: Cerabar M										
	Order Code: PMC51-V-JU2/	0						1			
1.01	Serial No.: ECQ 921128			1			1		JB 31/5		
1.0	Size: DN50				1	<b>-</b>	-w	PE	1202/2		
	Pressure rating: PN40			1	<u> </u>	<del>                                     </del>	1	İ	1		
	Process Connection: DN50 I EN1092-1	PN10-40 B1, 316L flange									
1.02	Instrument issued as per spe	ecifications/ purchase order					w	PE	JB31/5		
	Instrument installation			-4			Tooli .	Rell	2		
2.01	Check internal pipework and	clear any debris	NA				s	The second			
2.02	Confirm flange alignment an sure of correct bolting seque		NA				S	Mh			
2.03	Ensure bolts are well lubrica						s	Mile			
2.04	wound gaskets)		NA				s	Alla			
2.05	Ensure bolts are torqued up methodology and torque ration 160 Nm for 4 bolts) Mark at	ng (Approx Torque per bolt	Refer to Flange Tightenging Procedure				s	The state of			
2.06	Equipment lables are in plac	e and consistent with P&ID.	486/5/5-R7D185				w	PE	JB31/5		
2.07	Roll up and fasten the cable	ready for electrical installation	NA NA				s				

Revision: A

Approved By: Tate Brammer

		REFERENCE			Verify o	r Test	by		
Item No.	Activity Details	DOCUMENT/		S/C			JH	1	Remarks/Records
		DRAWINGS	Key	Resp.	Sign/Date	Key	Resp.	Sign/Date	
2.08	Check for damage and leave area tidy and clean for next discipline.	NA				w	PE	DB 31/5	
		MECH INS	TALL	TION	COMPLE	ETE	The second		

		APPROVAL	
	NAME	SIGNATURE	DATE .
JH	JANE BEECHER	Lan Beecher	5/6/12

Revision: A

Approved By: Tate Brammer

INSTRUMENT INSTALLATION CHECK SHEET AREA: **DIGESTER FEED PUMP STATION** John Holland Oxley WRP Heat Exchanger ITP ref. No: 8543-001-HX Project: Inspection Key: W -Upgrade Responsibility Key: SV- Supervisor, SV-Witness, H - Hold, S -Surveyor, PE - Project Engineer Sup-Checksheet 8543-M-HX-205 Surveillance Project Number: Superintendent PM- Project Manager EQUIPMENT DESCRIPTION: DIGESTER FEED PUMP 3 PRESSURE TRANSMITTER Tag Number: PIT-625-419 Verify or Test by REFERENCE Item No. **Activity Details** S/C DOCUMENT/ Remarks/Records DRAWINGS Resp. Sign/Date Key Resp. Sign/Date 1.00 Record nameplate data - record any variances to below Manufacturer: Endress & Hauser Model: Cerabar M Order Code: PMC51-V-JU2/0 1.01 Serial No.: F3O02A21128 JB 31/5 Size: DN50 Pressure rating: PN40 Process Connection: DN50 PN10-40 B1, 316L flange EN1092-1 1.02 Instrument issued as per specifications/ purchase order JB 31/5 2.00 Instrument installation 2.01 Check internal pipework and clear any debris 2.02 Confirm flange alignment and install instrument making sure of correct bolting sequence. 2.03 Ensure bolts are well lubricated before torquing up. Install instruments with correct gaskets. (3mm spiral 2.04 wound gaskets) Ensure bolts are torqued up as per spiral wound gasket Refer to Flange 2.05 methodology and torque rating (Approx Torque per bolt Tightenging 160 Nm for 4 bolts) Mark all bolts with an 'X' after Procedure 2.06 Equipment lables are in place and consistent with P&ID. JB 31/5 486/5/5-R7D185 2.07 Roll up and fasten the cable ready for electrical installation NA

Date c sue: 13.02.12 Page 1 of 2

Revision: A Approved By: Tate Brammer

		REFERENCE			Verify o	r Test	by		
Item No.	Activity Details	DOCUMENT/		S/C			JI	1	Remarks/Records
		DRAWINGS	Key	Resp.	Sign/Date	Key	Resp.	Sign/Date	
2.08	Check for damage and leave area tidy and clean for next liscipline.	NA				w	PE	28 31/5	
		MECH INS	TALL	ATION	COMPLE	TE	70000		

100		APPROVAL	
	NAME	SIGNATURE	DATE
JH	JANE BEECUER	Fine Beecher	5/6/12

Revision: A Approved By: Tate Brammer

Date o. ue: 13.02.12 Page 1 of 1

IN	STRUMENT INSTALLATION	N CHECK SHEET	AREA:				DIGES	TER F	EED PUMP	STATION	THE RESERVE TO
ITP ref. No:	8543-001-HX	Project:	Oxley WRP Heat Ex Upgrade	changer	Inspection Key: W - Witness, H - Hold, S - Surveillance				Responsibil	ity Key: SV- Supervisor, SV-	John Holland
Checksheet No.:	8543-M-HX-206	Project Number:	8543						Surveyor, P Superintend	E – Project Engineer Sup- dent PM- Project Manager	Holiana
EQUIPMENT D	DESCRIPTION:	DIGESTER FEED P	UMP 1 TEMPERATUR	RE TRAN	SMITTE	R			Tag Numbe	or:	TIT-625-406
	THE RESERVE OF		REFERENCE	1	-	Verify o	r Test	by			
Item No.	Activit	by Details	DOCUMENT/		S/C	TERMAN		JH		Remarks/	Records
			DRAWINGS	Key	Resp.	Sign/Date	Key	Resp.	Sign/Date		
1.00		record any variances to belo	OW.								
1.01	Manufacturer: Endress & Ha	auser					l <sub>w</sub>	PE	40 2.1		
1.0	Model: TR10-AMA1CASJB3	3000	E&H O&M Manual		VV		PE O	JR 31/2	SN: EC0247 <u>1</u> 4:	152	
1.02	Instrument issued as per sporerify instrument is not da	ecifications/ purchase order -	Carr Oaw Wandar				w	PE	JB 31/5	010.	
2.00	Instrument Installation										
2.01	Connect TIT to measuring lo thread paste (PTFE) or yello	ocation using high temperature ow gas line teflon tape.	NA NA				s				
2.02	Ensure bolts are cleaned an torquing.	d well lubricated before	NA				s	The state of the s			
2.03	Equipment lables are in place	e and consistent with P&ID.	486/5/5-R7D177				W	PE	JB 31/5		
2.04		Roll up and fasten the cable ready for electrical installation					s				
2.05	Check for damage and leave discipline.	e area tidy and clean for next	NA				W				
	MECH INSTALLATION CO	MPLETE	NA				Н	4//			

	APPROVAL	A STATE OF THE PARTY OF THE PAR
NAME	SIGNATURE	DATE
Jane Beicher	JANE BEECHER	31/5/12

Revision: A Approved By: Tate Brammer

Date o. ....ue: 13.02.12 Page 1 of 1

IN	STRUMENT INSTALLATION CH	ECK SHEET	AREA:				DIGES	TER F	EED PUMP	STATION	
TP ref. No:	8543-001-HX	Project:	Oxley WRP Heat Ex Upgrade	changer						ity Key: SV- Supervisor, SV-	John Holland
Checksheet No.:	8543-M-HX-207	Project Number:	8543	8543			Witness, H - Hold, S - Surveillance			E – Project Engineer Sup- dent PM- Project Manager	DIDIOH
QUIPMENT D	DESCRIPTION:	DIGESTER FEED PU	JMP 2 TEMPERATUR	RE TRAN	SMITTER				Tag Numbe	ar:	TIT-625-412
and the same of		REFERENCE			Verify o	r Test I	ру			C 1 1 1 2 2 2 1 1	
Item No.	Activity De	etails	DOCUMENT/		S/C			Jŀ		Remarks/	Records
			DRAWINGS	Key	Resp. S	ign/Date	Key	Resp.	Sign/Date		
1.00	Record nameplate data - recor	The second section of the second section is a second section of the second section of the second section is a second section of the section of t	N				-				
1.01	Manufacturer: Endress & Hauser						w	PE	10216		
	Model: TR10-AMA1CASJB3000		E&H O&M Manual				]**	F-	70 21/2	SN: EC0249141	-52
1.02	Instrument issued as per specific verify instrument is not damage	cations/ purchase order -					w	PE	JB 31/5		
2.00	Instrument installation										
2.01	Connect TIT to measuring location thread paste (PTFE) or yellow ga	on using high temperature as line teflon tape.	NA				s	(Ille			
2.02	Ensure bolts are cleaned and we torquing.	ell lubricated before	NA				s	Oh.			
2.03	Equipment lables are in place an	d consistent with P&ID.	486/5/5-R7D177				w	PE	J831/5		
	Roll up and fasten the cable read	·	NA				S	EL.			
2.05	Check for damage and leave are discipline.	a tidy and clean for next	NA				w	The			
2.06	MECH INSTALLATION COMPL	ETE	NA				Н				

1		APPROVAL	
	NAME	SIGNATURE	DATE
JH	JANE BEECHER	Jone Seedier	31/5/12

Revision: A Approved By: Tate Brammer

Date o. ...ue: 13.02.12 Page 1 of 1

IN	STRUMENT INSTALLATION CH	ECK SHEET	AREA:				DIGES	STER FI	EED PUMP	STATION	V COLUMN	
TP ref. No:	8543-001-HX	643-001-HX Project:					Inspection Key; W -			ity Key: SV- Supervisor, SV-	John Holland	
Checksheet No.:	8543-M-HX-208	Project Number:	8543		Witness, H - Hold, S - Surveillance				Surveyor, P Superintend	E – Project Engineer Sup- lent PM- Project Manager	HOlland	
QUIPMENT D	ESCRIPTION:	DIGESTER FEED P	UMP 3 TEMPERATUR	RE TRAN	SMITTE	2			Tag Numbe	ar;	TIT-625-418	
			REFERENCE			Verify o	r Test I	by				
Item No.	Activity De	etails	DOCUMENT/		S/C			Jŀ		Remarks/	Records	
			DRAWINGS	Key	Resp.	Sign/Date	Key	Resp.	Sign/Date			
1.00	Record nameplate data - reco	CONTRACTOR OF THE PROPERTY OF THE PARTY OF T	W									
1.01	Manufacturer: Endress & Hause	r					w	PE	10006			
1.0	Model: TR10-AMA1CASJB3000		E&H O&M Manual						72 212	SN: F3042824	157	
1.02	Instrument issued as per specific verify instrument is not damage	cations/ purchase order -	Lai i Odivi ivialidai				w	PE	JB31/5			
2.60	Instrument Installation											
2.01	Connect TIT to measuring location thread paste (PTFE) or yellow gates	•	NA				S	Alla				
2.02	Ensure bolts are cleaned and we torquing.	ell lubricated before	NA				s	Alle				
2.03	Equipment lables are in place ar	nd consistent with P&ID.	486/5/5-R7D177				w	PE	JB 31/5			
2.04	Roll up and fasten the cable read	dy for electrical installation	NA				s	Alla.				
2.05	Check for damage and leave are discipline.	ea tidy and clean for next	NA				w	Alle		-		
	MECH INSTALLATION COMPL	ETE	NA				Н	All	1			

		APPROVAL	
	NAME	SIGNATURE	DATE
JH	JANE BEECHER	Jane Beecher	31/5/12

Revision: A Approved By: Tate Brammer

Date o. \_\_sue: 13.02.12 Page 1 of 1

IN	ISTRUMENT INSTALLATION C	CHECK SHEET	AREA:					HEAT	EXCHANGE	RS	
TP ref. No:	8543-001-HX	Project:	Oxley WRP Heat Ex Upgrade		Inspection Key: W -			Responsibil	ity Key: SV- Supervisor, SV-	John Holland	
hecksheet lo.:	8543-M-HX-209	Project Number:	8543		Surveil	s, H - Hold, lance	S-			E – Project Engineer Sup- lent PM- Project Manager	HOlidhd
QUIPMENT (	DESCRIPTION:	HEAT EXCHANGER TRANSMITTER	1 SERVICE WATER	DRAIN T	EMPER	ATURE			Tag Numbe	or:	TT-626-01
			REFERENCE		-	Verify o	r Test	by	0	Commence of the last of the la	Control of the
Item No.	Activity I	Details	DOCUMENT/		S/C			JH		Remarks/	Records
			DRAWINGS	Key	Resp.	Sign/Date	Key	Resp.	Sign/Date		
1.00	Record nameplate data - rec		V					4			
1.0	Manufacturer: Endress & Haus						w	PE	JB31/5		
	Model: TR10-AHB1CESFBC00		E&H O&M Manual				12 093/13		SN: ECO261141	52	
1.02	Instrument issued as per speci verify instrument is not dama	fications/ purchase order - aged.					w	PE	JB 31/5		
2.00	Instrument Installation										
2.0	Connect TIT to measuring loca thread paste (PTFE) or yellow	ntion using high temperature gas line teflon tape.	NA				s				
2.02	Ensure bolts are cleaned and v torquing.	well lubricated before	NA				s	della			
2.00	3 Equipment lables are in place a	and consistent with P&ID.	486/5/5-R7D177				w	PE	JB31/5		
2.04	4 Roll up and fasten the cable re	ady for electrical installation	NA				s				
2.05	Check for damage and leave a discipline.	rea tidy and clean for next	NA				w	M			
2.06	MECH INSTALLATION COMP	PLETE	NA		Î		Н	All o	Ï		

		APPROVAL	
	NAME	SIGNATURE	DATE
н	JANE SEECHER	Jane Seecher	31/5/12

Revision: A Approved By: Tate Brammer

Date o \_\_\_\_\_ue: 13.02.12 Page 1 of 1

IN	ISTRUMENT INSTALLATION	I CHECK SHEET	AREA:					HEAT E	EXCHANGE	RS	Marie Constitution	
TP ref. No:	8543-001-HX	Project:	Oxley WRP Heat Ex Upgrade	changer						ity Key: SV- Supervisor, SV-	<b>John</b>	
Checksheet No.:	8543-M-HX-210	Project Number:	8543	the second secon		Witness, H - Hold, S - Surveillance			Surveyor, P Superintend	E – Project Engineer Sup- dent PM- Project Manager	Publiche	
EQUIPMENT I	DESCRIPTION:	HEAT EXCHANGER TRANSMITTER	2 SERVICE WATER	DRAIN T	EMPER	ATURE			Tag Numbe	ar:	TT-626-02	
		REFERENCE			Verify o	r Test	by					
Item No.	Activit	y Details	DOCUMENT/		S/C			JH		Remarks/I	Records	
4.00	00 Record nameplate data - record any variances to belo		DRAWINGS	Key	Key Resp. Sign/Date Key		Key	Cey Resp. Sign.			Marie Control	
1.00			W				4-1					
1.0	Manufacturer: Endress & Ha						w	PE	TO 21/2			
	Model: TR10-AHB1CESFBC		E&H O&M Manual				l''		100012	SN: EC026214	152	
1.02	Instrument issued as per sper verify instrument is not da	ecifications/ purchase order - maged.					w	PE	JB 31/5			
2.00	Instrument Installation											
2.0	Connect TIT to measuring lo thread paste (PTFE) or yello	cation using high temperature w gas line teflon tape.	NA				s	Me				
2.02	Ensure bolts are cleaned and torquing.	d well lubricated before	NA				S	Alle .				
2.03	Equipment lables are in plac	e and consistent with P&ID.	486/5/5-R7D177				w	PE	JB 31/5			
2.04		ready for electrical installation	NA				S	Men				
2.05	Check for damage and leave discipline.	e area tidy and clean for next	NA				w	EK.	*			
2.06	MECH INSTALLATION CO	MPLETE	NA				Н		Ì			

APPROVAL			
	NAME	SIGNATURE	DATE
JН	JANE BEECHER	La Beecher	31/5/12

Revision: A Approved By: Tate Brammer

Date o ue: 13.02.12 Page 1 of 1

IN	STRUMENT INSTALLATION	CHECK SHEET	AREA:					HEAT E	XCHANGE	RS	
TP ref. No:	8543-001-HX	Project:	Oxley WRP Heat Ex Upgrade	changer	Inspection Key: W -		Responsibilit	y Key: SV- Supervisor, SV-			
hecksheet lo.:	8543-M-HX-211	Project Number:	8543		Witness, H - Hold, S - Surveillance				Surveyor, PE – Project Engineer Sup- Superintendent PM- Project Manager		Holland
QUIPMENT D	ESCRIPTION:	HEAT EXCHANGER	1 SLUDGE OUTLET	TEMPE	RATURE	TRANSMIT	TER		Tag Numbe	¢ .	TT-626-04
			REFERENCE		Verify or Test by						
Item No.	Activity	Details	DOCUMENT/		S/C			JH		Remarks/	Records
			DRAWINGS	Key	Resp.	Sign/Date	Key	Resp.	Sign/Date		
1.00	Record nameplate data - re		W								and the same
1.01	Manufacturer: Endress & Hau	user					w	PE	to dela		
	Model: TR10-AHB1CESFBC0	000	E&H O&M Manual				\'`	I'C	000/011/6	SN: EC026314	157
1.02	Instrument issued as per spe- verify instrument is not dan						w	PE	385/6/12		
2.00	Instrument installation										
2.01	Connect TIT to measuring loc thread paste (PTFE) or yellow	cation using high temperature v gas line teflon tape.	NA				s				
2.02	Ensure bolts are cleaned and torquing.	well lubricated before	NA				s	The state of the s			-
2.03	Equipment lables are in place	and consistent with P&ID.	486/5/5-R7D177				w	PE	38116		
2.04	Roll up and fasten the cable r		NA				s	18th			
2.05	Check for damage and leave discipline.	area tidy and clean for next	NA				W				
2.06	MECH INSTALLATION COM	IPLETE	NA				н				

		APPROVAL	
	NAME	SIGNATURE	DATE
JH	JANE BEECHER	Jan Beedres	5/6/12

Revision: A Approved By: Tate Brammer

Date o ue: 13.02.12 Page 1 of 1

DATE 5/6/12

IN	ISTRUMENT INSTALLATION CHE	CK SHEET	AREA:					HEAT I	EXCHANGE	RS	
TP ref. No:	8543-001-HX	Project:	Oxley WRP Heat Ex Upgrade	xchange	Inspec	tion Key: W				y Key: SV- Supervisor, SV-	John
Checksheet No.:	8543-M-HX-212	Project Number:	8543		Witness, H - Hold, S - Surveillance		1	Surveyor, PE – Project Engineer Sup- Superintendent PM- Project Manager		Holland	
EQUIPMENT D	DESCRIPTION:	HEAT EXCHANGER	2 SLUDGE OUTLET TEMPER		RATURE	RATURE TRANSMITTER			Tag Number:		TT-626-06
			REFERENCE		0.00	Verify or	Test I	by			5.75.76
Item No.	Activity Deta	alls	DOCUMENT/		S/C			JF	Tan 1	Remarks/I	Records
			DRAWINGS	Key	Resp.	Sign/Date	/Date Key Re		Sign/Date		
1.00	Record nameplate data - record	dany variances to belo	W						and the same of the		
1.01	Manufacturer: Endress & Hauser								70-11/2		
1.01	Model: TR10-AHB1CESFBC000		E&H O&M Manual				W	PE	18 3/6/12	5N: EC0264141	57
1.02	Instrument issued as per specifica verify instrument is not damage		Lai i Oaivi iviandai				w	PE	185/6/12	70. 00 00 14 12	
2.00	Instrument Installation						7				
2.01	Connect TIT to measuring location thread paste (PTFE) or yellow gas	n using high temperature s line teflon tape.	NA				s				
2.02	Ensure bolts are cleaned and well torquing.	lubricated before	NA				s				
2.03	Equipment lables are in place and	consistent with P&ID.	486/5/5-R7D177				W	PE	385/1/12		
2.04	Roll up and fasten the cable ready		NA NA				s				
2.05	Check for damage and leave area discipline.	tidy and clean for next	NA				W	ALL			
2.06	MECH INSTALLATION COMPLE	TE	NA				Н	MIL			
					ROVAL						
		NAME		SIGN	ATURE			,		DATE	, ,
IH	JANE BEECHER				ha -	R	010	hes	_	.5	16/12

Revision: A

Approved By: rate Brammer

Date c :ue: 13.02.12 Page 1 of 2

MANU	AL VALVE > DN80 INSTALLA	ATION CHECK SHEET	AREA:				DIGES	STER F	EED PUMP	STATION		
TP ref. No:	8543-001-HX	Project:	Oxley WRP Flood Re	ecovery	inspec	tion Key: W	1-		Responsibili	ity Key: SV- Supervisor, SV-	<b>John</b>	
Checksheet lo.:	8543-M-HX-300	Project Number:			Witness, H - Hold, S -				Surveyor, PE - Project Engineer Sup- Superintendent PM- Project Manager		John Holland	
EQUIPMENT I	DESCRIPTION:	DIGESTER FEED PI	PUMP 1 INLET ISOLATION VALVE						Tag Numbe	or:	HV-625-419	
			REFERENCE			Verify o	r Test l	by				
Item No.	Activit	ty Details	DOCUMENT/		S/C			JI	1	Remarks/	Records	
			DRAWINGS	Key	Resp.	Sign/Date	Key	Resp.	Sign/Date			
1.0		te data - record any variance	s to below						Partie de la constante de la c			
	Manufacturer: Erhard											
	Model: ERUK1 - Lugged Kni	ife Gate Valve							7026	tu		
1.0							w	PE	JB31/5			
	Material: SS/CI											
	Valve Class: GA21-H						1					
2.0	0 Valve installation			12270					1			
2.0	1 Check internal pipework and						s	MIL				
2.0	Confirm gasket type (SS316 DN150 PN10)	spiral wound gasket rating					s					
2.0	Check installation direction of per vendor manual or arrow						s					
2.0	Confirm flange alignment an correct bolting sequence and	d install valve making sure of d torques.					s					
2.0	5 Ensure bolts are well lubrica	ated before torquing up.					s					
2.0	Ensure bolts are torqued up methodology and torque ration 203 Nm for 8 bolts) Mark altorquing completed.	ng (Approx Torque per bolt	Refer to Flange Tightenging Procedure JHG-OXL 037.				S					
2.0	Check manual handles have restriction for operation	correct access and no	NA				s	PE	J831/5			
2.0	Stroke the valve manually, e easily.	ensure valve opens and closes	NA				w	PE	IB 31/5			
2.09	Check for damage and leave discipline.	e area tidy and clean for next	NA				w	PE	JB 31/5			

Revision: A

Approved By: Tate Brammer

Date of Issue: 13.02.12 Page 2 of 2

2.1 Equipment lables	are in place and consistent with P&ID.	486/5/5-R7W105		w	PE	JB11/6	
2.11 MECH INSTALL	ATION COMPLETE	NA		н	1/2	-	

		APPROVAL	
	NAME	SIGNATURE	DATE
JH	JANE BEECHER	Jan Beeche	11/6/12

· .

. .

Revision: A

Approved By: 1 ate Brammer

Date c sue: 13.02.12 Page 1 of 2

MANU	AL VALVE > DN80 INSTALL	ATION CHECK SHEET	AREA:				DIGES	STER F	EED PUMP S	TATION		
TP ref. No:	8543-001-HX	Project:	Oxley WRP Flood R	ecovery	Inspec	tion Key: W			Responsibility	Key: SV- Supervisor, SV-	John	
Checksheet No.:	8543-M-HX-301	Project Number:	8543		Witnes	Witness, H - Hold, S - Surveillance			Surveyor, PE – Project Engineer Sup- Superintendent PM- Project Manager		Holland	
QUIPMENT I	DESCRIPTION:	DIGESTER FEED P	PUMP 2 INLET ISOLATION VALVE						Tag Number:		HV-625-424	
	White the same of	Colonia de la co	REFERENCE			Verify o	r Test	by				
Item No.	Activ	vity Details	DOCUMENT/ DRAWINGS Key		S/C	Sign/Date	JH		Remark		s/Records	
1.0	0 Record Actuator nameple	ate data - record any variance	es to below		Intoop.	Joiginbato	ittey	ixesp.	Signibate			
	Manufacturer: Erhard			T	T		T	T	T			
	Model: ERUK1 - Lugged K	inife Gate Valve			1		1		<b>1</b> , ⊢			
1.0	1 DN: 200mm				1		l <sub>w</sub>	PE	JB31/5			
	Material: SS/CI			+-	+-	-	┤"	-	-			
	Valve Class: GA21-H			<del>                                     </del>	+		1		1 F			
2.0	0 Valve Installation						<u> </u>					
2.0	1 Check internal pipework ar	nd clear any debris	T	Ι	T	T	s	Mala	J			
2.0	Confirm gasket type (SS31 DN200 PN10)	l6 spiral wound gasket rating					s	Mala				
2.0	Check installation direction per vendor manual or arrow	n of valves and ensure it is as w on valve body.					s	All L				
2.0	Confirm flange alignment a correct bolting sequence a	and install valve making sure of and torques.					s	Sel.				
2.0	5 Ensure bolts are well lubric	cated before torquing up.					s	Alla				
2.00	mothodology and torque re	p as per spiral wound gasket ating ( <b>Approx Torque per bolt</b> all bolts with an 'X' after	Refer to Flange Tightenging Procedure JHG-OXL 037.				s	Ma				
2.07	Check manual handles have restriction for operation	ve correct access and no	NA				s	PE	J831/5			
2.08	Stroke the valve manually, easily.	ensure valve opens and closes	NA				w	PE	JB 31/5			
2.09	Check for damage and lead discipline.	ve area tidy and clean for next	NA				w	PE	JB 31/5			

Revision: A

Approved By: Tate Brammer

Date of Issue: 13.02.12 Page 2 of 2

2.1 Equipment lables are in place and consistent with P&ID.	486/5/5-R7W105		w	PE	JB 11/6	
2.11 MECH INSTALLATION COMPLETE	NA		н	8//		

		APPROVAL	
	NAME	SIGNATURE	DATE
JH	JANG BESCHEIR	Jan Beecher	11/6/12

.

Revision: A Approved By: 1 ate Brammer

Date o ue: 13.02.12 Page 1 of 2

MANUAL VALVE > DN80 INSTALLATION CHECK SHEET			AREA:				DIGES	STER FI	EED PUMP	STATION	
TP ref. No:	8543-001-HX	Project:	Oxley WRP Flood Re	ecovery	Inspec	tion Key: W			Responsibil	lity Key: SV- Supervisor, SV-	John
Checksheet No.:	8543-M-HX-302	Project Number:	8543		Witness, H - Hold, S - Surveillance				Surveyor, P Superintend	John Holland	
EQUIPMENT (	DESCRIPTION:	DIGESTER FEED P	UMP 3 INLET ISOLAT	.VE			Tag Numbe		er:	HV-625-427	
			REFERENCE		Verify or Test by						
Item No.	Activi	ty Details	DOCUMENT/ DRAWINGS	DOCUMENT/ S/C JH		7	Remarks/F	Records			
1.00	00 Record Actuator nameplate data - record any variances		s to below	1,	1.000	Joighinadto	itoy	Iresp.	Loidingare		
	Manufacturer: Erhard			T	T	1		T	T		
	Model: ERUK1 - Lugged Kr	nife Gate Valve		$\vdash$	_		1				
1.01	1 DN: 200mm			1	+		l <sub>w</sub>	PE	JB 31/5		
	Material: SS/CI			<del>                                     </del>	-		·"	-	05 5/5		
	Valve Class: GA21-H			1	1		i				
2.00	Valve Installation										
2.01	1 Check internal pipework and	d clear any debris		T	T		s	AND	L		
2.02	Confirm gasket type (SS310 DN200 PN10)	6 spiral wound gasket rating					S				
2.03	Check installation direction per vendor manual or arrow	of valves and ensure it is as on valve body.					s				
2.04	Confirm flange alignment ar correct bolting sequence an	nd install valve making sure of ad torques.					S				
2.05	Ensure bolts are well lubrica	ated before torquing up.					S	Alla.			
2.06	methodology and torque ret	as per spiral wound gasket ing ( <b>Approx Torque per bolt</b> ill bolts with an 'X' after	Refer to Flange Tightenging Procedure JHG-OXL 037.				s	Phe	7		
2.07	Check manual handles have restriction for operation	e correct access and no	NA				s	PE	JB31/5		
2.08	Stroke the valve manually, e easily.	ensure valve opens and closes	NA				w	PE	JB 31/5		
2.09	Check for damage and leave discipline.	e area tidy and clean for next	NA				w	PE	JB 31/5		

Revision: A

Approved By: Tate Brammer

Date of Issue: 13.02.12 Page 2 of 2

2.1	Equipment lables are in place and consistent with P&ID.	486/5/5-R7W105		w	PE	JB 11/6	
2.11	MECH INSTALLATION COMPLETE	NA		Н	sv	Mh	

		APPROVAL	
	NAME	SIGNATURE	DATE
JH	JANE BEECHER	Jan Beesher	11/6/12

-

٠.

Revision: A

Approved By: 1 ate Brammer

MANUAL VALVE > DN80 INSTALLATION CHECK SHEET AREA: **DIGESTER FEED PUMP STATION** John Holland ITP ref. No: 8543-001-HX Project: Oxley WRP Flood Recovery Inspection Key: W -Responsibility Key: SV- Supervisor, SV-Checksheet Witness, H - Hold, S -Surveyor, PE - Project Engineer Sup-8543-M-HX-303 Project Number: Surveillance Superintendent PM- Project Manager EQUIPMENT DESCRIPTION: DIGESTER FEED PUMP STATION DISCHARGE TO HX 2 VALVE Tag Number: HV-625-431 Verify or Test by REFERENCE Item No. **Activity Details** DOCUMENT/ Remarks/Records DRAWINGS Resp. Sign/Date Key Resp. Sign/Date 1.00 Record Actuator nameplate data - record any variances to below Manufacturer: (Existing) Model: Lugged Knife Gate Valve J831/5 PE DN: 100mm Material: SS/CI 2.00 Valve installation 2.01 Check internal pipework and clear any debris 2.02 Confirm gasket type (SS316 spiral wound gasket rating DN100 PN10) 2.03 Check installation direction of valves and ensure it is as per vendor manual or arrow on valve body. 2.04 Confirm flange alignment and install valve making sure of correct bolting sequence and torques. 2.05 Ensure bolts are well lubricated before torquing up. Ensure bolts are torqued up as per spiral wound gasket Refer to Flange 2.06 methodology and torque rating (Approx Torque per bolt 176 Nm for 8 bolts) Mark all bolts with an 'X' after Tightenging Procedure JHG-OXLtorquing completed. 037. 2.07 Check manual handles have correct access and no JB 31/5 NA PE restriction for operation Stroke the valve manually, ensure valve opens and closes JB31/5 PE 2.09 Check for damage and leave area tidy and clean for next discipline.

PE

Date o' ue: 13.02.12

Page 1 of 2

Revision: A

Approved By: Tate Brammer

Date of Issue: 13.02.12 Page 2 of 2

2.1 Equipment lables are in place and consistent with P&ID.	486/5/5-R7D177		w	PE	JB 11/6	
2.11 MECH INSTALLATION COMPLETE	NA		Н	Ale		

		APPROVAL.	
	NAME	SIGNATURE	DATE
ЈН	JANG BECCHER	Jane Beecher	11/6/12

1.

1.7

Revision: A Approved By: Tate Brammer

Date o' sue: 13.02.12 Page 1 of 2

MANUA	AL VALVE > DN80 INSTALLATION	CHECK SHEET	AREA:		li .		DIGE	STER FI	EED PUMP ST	ATION		
TP ref. No:	8543-001-HX	Project:	Oxley WRP Flood R	ecovery	Inspec	tion Key: W	-		Responsibility Key: SV- Supervisor, SV-		John	
hecksheet lo.:	8543-M-HX-304	Project Number:			Witness, H - Hold, S -				Surveyor, PE – Project Engineer Sup- Superintendent PM- Project Manager		John Holland	
QUIPMENT D	DESCRIPTION:	DIGESTER FEED PI	JMP STATION DISCHARGE TO HX 1 VALVE						Tag Number:		HV-625-432	
			REFERENCE		-	Verify o	r Test	by				
Item No.	Activity Det	tails	DOCUMENT/		S/C			JH		Remarks/R	ecords	
1 3 5 6 1			DRAWINGS	Key	Resp.	Sign/Date	Key	Resp.	Sign/Date			
1.00	Record Actuator nameplate dat	a - record any variance:	s to below									
	Manufacturer: (Existing)											
4.04	Model: Lugged Knife Gate Valve						1		400.1			
1.01	DN: 100mm						W	PE	JB 31/5-			
	Material: SS/CI			<del>                                     </del>			1		· · ·			
2.00	Valve Installation		1									
2.01	Check internal pipework and clear	r any debris	T T	T	T		s	AUST	i. T			
2.02	Confirm gasket type (SS316 spira	al wound gasket rating					s					
2.03	Check installation direction of valve per vendor manual or arrow on valve.						s	All				
2.04	Confirm flange alignment and inst correct bolting sequence and torq						s	Me		-		
2.05	Ensure bolts are well lubricated b	efore torquing up.					s	Mu				
2.06	Ensure bolts are torqued up as permethodology and torque rating (A 176 Nm for 8 bolts) Mark all bolts torquing completed.	pprox Torque per bolt	Refer to Flange Tightenging Procedure JHG-OXI 037.	-			S	Mile.				
2.07	Check manual handles have corrected restriction for operation	ect access and no	NA				s	PE	J8 31/5			
2.08	Stroke the valve manually, ensure easily.	valve opens and closes	NA				w	PE.	SB 31/5			
2.09	Check for damage and leave area discipline.	tidy and clean for next	NA		<u> </u>		w	PE	JB3/5			

Revision: A

Approved By: Tate Brammer

Date of Issue: 13.02.12 Page 2 of 2

2.1 Equipment lables are in place and consistent with P&ID.	486/5/5-R7D177		w	PE	J811/6	
2.11 MECH INSTALLATION COMPLETE	NA		Н	Alle		

		APPROVAL	
	NAME	SIGNATURE	DATE
JH	JANE BEECHER	Jan beecher	11/6/12

Revision: A

Approved By: Tate Brammer

Date c nue: 13.02.12 Page 1 of 2

MANU	AL VALVE >DN80 INSTALL	ATION CHECK SHEET	AREA:					HEAT E	EXCHANGE	RS		
TP ref. No:	8543-001-HX	Project:	Oxley WRP Flood Re	ecovery		tion Key: W			Responsibili	ty Key: SV- Supervisor, SV-	John Holland	
Checksheet No.:	8543-M-HX-305	Project Number:			Witness, H - Hold, S - Surveillance				Surveyor, PE – Project Engineer Sup- Superintendent PM- Project Manager		Holland	
EQUIPMENT (	DESCRIPTION:	HEAT EXCHANGER	1 SLUDGE INLET IS	DLATIO	N VALVE				Tag Numbe	r:	HV-626-11	
		Carried St.	REFERENCE		Verify or Test by					110		
Item No.	Activi	ity Details	DOCUMENT/ DRAWINGS	Key	S/C	Sign/Date	Kev	JH	Sign/Date	Remarks/F	Records	
1.00	Record Actuator namepla	ate data - record any variances	s to below	1,	The second		itoy	ittop.	olginbate			
	Manufacturer: (Existing)				T				T			
	Model: Lugged Knife Gate	Valve					1		10 2.4			
1.0	DN: 100mm					/	W	PE	JB 31/5			
	Material: SS/CI		<del>                                     </del>		+		1				· · · · · · · · · · · · · · · · · · ·	
2.00	Valve installation			1								
2.0	1 Check internal pipework an	nd clear any debris		T			s					
2.02	Confirm gasket type (SS31) DN100 PN10)	6 spiral wound gasket rating					s					
2.03	Check installation direction per vendor manual or arrow	of valves and ensure it is as v on valve body.					s					
2.04	Confirm flange alignment at correct bolting sequence ar	nd install valve making sure of nd torques.					s					
2.0	5 Ensure bolts are well lubric	ated before torquing up.					s	Alle				
2.06	methodology and torque rat	p as per spiral wound gasket ting ( <b>Approx Torque per bolt</b> all bolts with an 'X' after	Refer to Flange Tightenging Procedure JHG-OXL 037.				s	The same				
2.07	Check manual handles hav restriction for operation	re correct access and no	NA				s	PE	JB31/5			
2.08	Check installation of limit so to ensure that the valve flag proximity switch	witches and adjust accordingly g is in contact with each	NA				s	PE	JB 31/5			
2.09	Stroke the valve manually, easily. Check limits switche	ensure valve opens and closes	NA				w	PE	IB 31/5			

Revision: A

Approved By: Tate Brammer

Date of Issue: 13.02.12 Page 2 of 2

2.10	Check for damage and leave area tidy and clean for next discipline.	NA			v	v	PE	JB 31/5
2.11	Equipment lables are in place and consistent with P&ID.	486/5/5-R7D177			v	v	PE /	1811/6
2.12	MECH INSTALLATION COMPLETE	NA			-	+ /		
3.00	Pre-commissioning		ALC: UNKNOWN	THE PARTY		2		
3.01	Energise valve limits electrically following energisation procedure.	NA						265/6/g
3.02	Stroke the valve manually and ensure limit switches are communicating correctly	NA			v	v	PE	36 5/6/10
3.03	Check for damage and leave area tidy and clean for next discipline.	NA			v	٧	PE	JB 5/6/12

		APPROVAL	
	NAME	SIGNATURE	DATE
JH	JANE BEEDLE	Jan Beecher	11/6/12

Revision: A Approved By: Tate Brammer

Date c ue: 13.02.12 Page 1 of 1

DATE 11/6/12

MANU	AL VALVE >DN80 INSTALLATIO	ON CHECK SHEET	AREA:					HEAT I	EXCHANGERS		Marin auditu
TP ref. No:	8543-001-HX	Project:	Oxley WRP Flood F	Recovery	Inspec	tion Kev: W		POPE	Responsibility Key	SV- Supervisor, SV-	John Holland
hecksheet lo.:	8543-M-HX-306	Project Number:			Witness, H - Hold, S - Surveillance				Surveyor, PE – Project Engineer Sup- Superintendent PM- Project Manager		Holland
QUIPMENT D	DESCRIPTION:	HEAT EXCHANGER	1 SERVICE WATER	INLET	SOLATIC	N VALVE			Tag Number:		HV-626-16
	CONTRACTOR OF THE PARTY OF	/	REFERENCE		-	Verify or	Test				. 3-0
Item No.	Activity D	Details	DOCUMENT/ DRAWINGS	Key	S/C	Sign/Date	Kou	JH Resp.		Remarks/R	tecords
1.01	Valve issued as per specification	on/ purchase order		rtey	ivesh.	Sigilibate	W	PE	J8 31/5		
	Valve installation	perentage oraci				-	VV	ILC.	100 21/2		
2.01	Check internal pipework and cle	ear any debris	NA	T	T		s	A			
2.02	Confirm gasket type (3mm inse	ertion rubber)	NA	1	1		s				
2.03	Confirm flange alignment and ir correct bolting sequence and to		NA				s				
2.04	Check installation direction of v per vendor manual or arrow on		NA				s				
2.05	Check manual handles (if applied and no restriction for operation		NA				s				
2.06	Stroke valve manually.		NA				s				
2.07	Equipment lables are in place a		486/5/5-R7D177				w	PE	JB 11/6		
2.08	alscipline.		NA				w	PE	38316		
3.06	Ensure Limit Switches are insta (IF REQUIRED)	alled and ready for wiring.	NA				s				
				APP	ROVAL.			ACT IC		5-6-4-1-T-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1	
		NAME		SIGNA		- 0	_			DATE	
Н	JANG BEECHE	BR			Your	- Bec	Lin	-		11	16/11-

Revision: A

Approved By: Tate Brammer

Date o ue: 13.02.12 Page 1 of 1

DATE

11/6/12

MANUA	AL VALVE > DN80 INSTALLATIO	N CHECK SHEET	AREA:				RS	and the second of			
TP ref. No:	8543-001-HX	Project:	Oxley WRP Flood F	Recovery	Inspect	ion Key: W	-	l sen	Responsibilit	y Key: SV- Supervisor, SV-	John Holland
Checksheet No.:	8543-M-HX-307	Project Number:	8543			s, H - Hold,			Surveyor, PE	- Project Engineer Sup- ent PM- Project Manager	Holland
EQUIPMENT D	ESCRIPTION:	HEAT EXCHANGER	S CHLORINE DOSIN	NG BYPA	SS VALV	E			Tag Numbe	<b>a</b>	HV-626-20
			REFERENCE		HWAR	Verify or	Test	by			
Item No.	Activity De	tails	DOCUMENT/		S/C			JH		Remarks/F	Records
			DRAWINGS	Key	Resp.	Sign/Date	Key	Resp.	Sign/Date		
	Valve issued as per specification	/ purchase order					W	PE	JB 31/5		
	Valve Installation							A. F	100		
	Check internal pipework and clea		NA				S		2		
2.02	Confirm gasket type (3mm inser	tion rubber)	NA				s				
2.03	Confirm flange alignment and ins correct bolting sequence and tore	stall valve making sure of ques.	NA				s	SA			
2.04	Check installation direction of value per vendor manual or arrow on v		NA				s	1			
2.05	Check manual handles (if application and no restriction for operation	able) have correct access	NA				s				
2.06	Stroke valve manually.		NA				s	SE.			
2.07	Equipment lables are in place an	d consistent with P&ID.	486/5/5-R7D177				w	PE	JB 11/6		
2.08	Check for damage and leave are discipline.	a tidy and clean for next	NA				w	PE	JB31/5		
3.06	IEnsure Limit Switches are install	ed and ready for wiring.	NA				s	AL.	7		

NAME

JANE BEECHER

SIGNATURE
Jour Soleonor

Revision: A

Approved By: 1 ate Brammer

Date c' sue: 13.02.12 Page 1 of 2

MANUA	AL VALVE >DN80 INSTALL	ATION CHECK SHEET	AREA:					HEAT E	XCHANGE	RS		
TP ref. No:	8543-001-HX	Project:	Oxley WRP Flood R	ecovery	Inspec	tion Key: W	-		Responsibili	ity Key: SV- Supervisor, SV-	<u>John</u>	
Checksheet lo.:	8543-M-HX-308	Project Number:	8543			Witness, H - Hold, S -				E – Project Engineer Sup- lent PM- Project Manager	Holland	
QUIPMENT D	ESCRIPTION:	HEAT EXCHANGER	2 SLUDGE INLET ISOLATION VALVE						Tag Number:		HV-626-21	
			REFERENCE		3.88	Verify o	r Test I	by	1			
Item No.	Activ	rity Details	DOCUMENT/ DRAWINGS	S/C Key Resp. Sign/Date R		Kev	JH Key Resp. Sign/D		Remarks/F	Records		
1.00	Record Actuator namepla	ate data - record any variance	s to below						o igni o ato			
	Manufacturer: (Existing)											
	Model: Lugged Knife Gate	Valve				-	1		10 2/2			
1.01	DN: 100mm						W	PE	JB 31/5			
	Material: SS/CI			+	+		1					
2.00	Valve installation											
2.01	Check internal pipework ar	nd clear any debris	1-	T	T	T in the second	s		Ţ			
2.02	Confirm gasket type (SS31 DN100 PN10)	6 spiral wound gasket rating					s					
2.03	Check installation direction per vendor manual or arrow	n of valves and ensure it is as w on valve body.					s	11/				
2.04	Confirm flange alignment a correct bolting sequence as	and install valve making sure of nd torques.					s	1				
2.05	Ensure bolts are well lubric	cated before torquing up.					s	1				
2.06	methodology and torque ra	p as per spiral wound gasket ting ( <b>Approx Torque per bolt</b> all bolts with an 'X' after	Refer to Flange Tightenging Procedure JHG-OXI 037.	-			s					
2.07	Check manual handles hav restriction for operation	ve correct access and no	NA				s	PE	J831/5			
2.08	Check installation of limit so to ensure that the valve flag proximity switch	witches and adjust accordingly g is in contact with each	NA				s	PE	JBS/K/n			
2.09	Stroke the valve manually, easily. Check limits switch	ensure valve opens and closes es.	NA				w	PE	JB 5/6/n			

Revision: A

Approved By: Tate Brammer

Date of Issue: 13.02.12 Page 2 of 2

2.10	Check for damage and leave area tidy and clean for next discipline.	NA		w	PE	783/5
2.11	Equipment lables are in place and consistent with P&ID.	486/5/5-R7D177		w	PE	J811/6
2.12	MECH INSTALLATION COMPLETE	NA		н	11/2	
3.00	Pre-commissioning		THE RESERVE	31		
3.01	Energise valve limits electrically following energisation procedure.	NA				J85/6/12
3.02	Stroke the valve manually and ensure limit switches are communicating correctly	NA		 w	PE	385/6/n
	Check for damage and leave area tidy and clean for next discipline.				_	

		APPROVAL	
	NAME	SIGNATURE	DATE
JH	JANG BECUER	Far becohe	11/6/12

Revision: A Approved By: Tate Brammer

Date o Jue: 13.02.12 Page 1 of 1

MANUA	AL VALVE > DN80 INSTALLATION	CHECK SHEET	AREA:					HEAT E	XCHANGER	S	
TP ref. No:	8543-001-HX	Project:	Oxley WRP Flood Recovery 8543		Inspec	spection Key: W - Responsibility Key:		Key: SV- Supervisor, SV-	<b>John</b>		
Checksheet No.:	8543-M-HX-309	Project Number:			Witnes Surveil	s, H - Hold, lance	S-		Surveyor, PE	- Project Engineer Sup- nt PM- Project Manager	Holland Holland
EQUIPMENT DESCRIPTION: HEAT EXCHANGER 2		2 SERVICE WATER	RINLETIS	SOLATIC	N VALVE			Tag Number:		HV-626-26	
		10000	REFERENCE	100		Verify o	r Test	by	A DESCRIPTION OF THE PERSON OF		
Item No.	Activity Deta	ils	DOCUMENT/ DRAWINGS	1	S/C		100	JH		Remarks/F	Records
				Key	Resp.	Sign/Date	Key	Resp.	Sign/Date		
	Valve issued as per specification/	ourchase order					W	PE	3831/5		
	Valve installation				and the		-	11			
2.01	Check internal pipework and clear	any debris	NA				S		-		
2.02	2 Confirm gasket type (3mm insertion rubber)		NA				S	2 32	-		
2.03	Confirm flange alignment and insta correct bolting sequence and torqu	Il valve making sure of es.	NA				s		-		
	Check installation direction of valve per vendor manual or arrow on valve.		NA				s	MIL			
2.05	Check manual handles (if applicab and no restriction for operation	le) have correct access	NA				S	A SE			
2.06	Stroke valve manually.		NA				s	The second			·
2.07	Equipment lables are in place and	consistent with P&ID.	486/5/5-R7D177				w	PE	JBU6		
2.08	Check for damage and leave area discipline.	tidy and clean for next	NA				w	PE	J831/5		
3.06	Ensure Limit Switches are installed (IF REQUIRED)	and ready for wiring.	NA				s				

APPROVAL.								
	NAME	SIGNATURE	DATE .					
İH	JANE BEECHER	Jan Beeches	11/6/12					

Date c sue: 13.02.12

Page 1 of 2

Revision: A

Approved By: rate Brammer

MANUAL VALVE > DN80 INSTALLATION CHECK SHEET AREA: **HEAT EXCHANGERS** ITP ref. No: 8543-001-HX Oxley WRP Flood Recovery Project: Inspection Key: W -Responsibility Key: SV- Supervisor, SV-Witness, H - Hold, S -Surveyor, PE - Project Engineer Sup-Checksheet 8543-M-HX-310 Project Number: 8543 Surveillance Superintendent PM- Project Manager No.: EQUIPMENT DESCRIPTION: HEAT EXCHANGERS SLUDGE OUTLET DRAIN VALVE Tag Number: HV-626-15 Verify or Test by REFERENCE Item No. **Activity Details** DOCUMENT/ Remarks/Records DRAWINGS Resp. Sign/Date Key Resp. Sign/Date 1.00 Record Actuator nameplate data - record any variances to below Manufacturer: (Existing) Model: Lugged Knife Gate Valve JB 31/5 1.01 PE DN: 100mm Material: SS/CI 2.00 Valve installation 2.01 Check internal pipework and clear any debris 2.02 Confirm gasket type (SS316 spiral wound gasket rating DN100 PN10) 2.03 Check installation direction of valves and ensure it is as per vendor manual or arrow on valve body. 2.04 Confirm flange alignment and install valve making sure of correct bolting sequence and torques. 2.05 Ensure bolts are well lubricated before torquing up. Ensure bolts are torqued up as per spiral wound gasket Refer to Flange methodology and torque rating (Approx Torque per bolt Tightenging 2.06 176 Nm for 8 bolts) Mark all bolts with an 'X' after Procedure JHG-OXL torquing completed. 037. 2.07 Check manual handles have correct access and no restriction for operation JB315 NA 2.08 Stroke the valve manually, ensure valve opens and closes easily. J6 5/6/2 PE 2.09 Check for damage and leave area tidy and clean for next discipline. J831/5

Revision: A

Approved By: Tate Brammer

Date of Issue: 13.02.12 Page 2 of 2

2.1 Equipment lables are in place and consistent with P&ID.	486/5/5-R7D177		_	w	PE	JB 11/6	
2.11 MECH INSTALLATION COMPLETE	NA			Н	AL		

	APPROVAL	
NAME	SIGNATURE	DATE
JANE BEECHER	Ja Beechor	11/6/1
		NAME SIGNATURE

7. P.

S.A.

. . .

Revision: A

Approved By: Tate Brammer

Date ( sue: 13.02.12 Page 1 of 1

INSTRUMENT INSTALLATION CHECK SHEET		ECK SHEET	AREA:							
ITP ref. No:	8543-001-HX	Project:	Oxley WRP Heat Exchanger Upgrade			ev: W - Wit	ness, H - Hold, S -	Responsibility Key: S	Johr Holland	
Checksheet No.:	8543-M-HX-700	Project Number:	8543		Surveillance		ness, ri - riola, 3 -	Surveyor, PE – Proje Superintendent PM-	oct Engineer Sup-	Holland
EQUIPMENT D	ESCRIPTION:	INSTRUMENT INS	STALLATION CHECK	SHEET						
Tag Number	Description	Manufacturer	Model	Serial No.	Installed as per O&M	Set point	Additional Parameters Set & Attached	Test Operation	Remarks/F	Records
TI-62603	Heat Exchanger 1 Sludge Discharge Temperature Indicator	TEL-TRU	BC-350R	NA		NA	NA	V		
TI-62605	Heat Exchanger 2 Sludge Discharge Temperature Indicator	TEL-TRU	BC-350R	NA	~	NA	NA	~		
PI-62690	Heat Exchanger Chlorine dosing line pressure indicator	WIKA	NA	NA	~	NA	NA			

		APPROVAL	
	NAME	SIGNATURE	DATE
1	JANE BEECHER	Jone Beecher	11/6/12.

### 2.2.3. Electrical Checksheets



# **OXLEY WWTP**

# **FLOOD RECOVERY ZONE 3**

**Heat Exchanger** 

**Electrical Installation Test Sheet** 

### THE ENGINEERS, THE IDEAS, THE SOLUTIONS

www.mpaeng.com.au

**HEAD OFFICE IPSWICH TOWNSVILLE** SYDNEY MELBOURNE

Unit 3/22-24 Strathwyn St Brendale Qld 4500 117 Toongarra Rd Ipswich Qld 4305 14 Chaimberlane Crt Kirwan Qld 4817 8 Charles St St Marys NSW 2760 Unit 10/64 Oakover Rd Preston Vic 3072 QLD Electrical Contractor Licence No 10423

Tel: 07 3881 0722 Tel: 07 3813 7100 Tel: 07 4723 6882 Tel: 02 9623 7066

Tel: 03 9480 8006

Fax: 07 3881 0723 Fax: 07 3813 7199 Fax: 07 4723 6585 Fax: 02 9623 7166 Fax: 07 9416 8591



D	ocument Control								
Identification	Project Name	CAMBI HEAT EXCHANGE UPGRADE							
	Job No.	19216 & 19323							
	Document Title	Heat Exchanger Electrical Installation Test Sheet							
	Associated Documents								
	Document Number								
	Client Reference								
	Path\File Name								
Ą	Written by	M.G	Control Systems Engineer						
Authority	Authorised by	D.D	Project Manager						
٩	Client Authorisation								
ip	Copyright	Copyright ©	MPA Engineering Pty Ltd. ABN 77 011 069 533						
Ownership	Intellectual Property	MPA Engineering Pty Ltd asserts ownership of the intellectual property contained herein, and claims copyright and authorship.  MPA Engineering Pty Ltd has and retains all rights of ownership and use of the material herein in its on-going business.							

Revision History										
Checked	Remarks		Ву	Date	Rev					
		7 April 2012 MG First Issue	17 April 2012	00						
		First Issue	MG	17 April 2012	00					

- Rev 00

Page 2 of 9



## Contents

1.	Objectives	4
2.		
	Methodology	
	Tests Summary	
	Test Completion Acceptance	
	APPENDIXES	



### 4. Tests Summary

ELECTRICAL FITOUT	N/A	Pass	Comments
6mm SDI (Minimum)fitted to line side of	/		
control fuses for high fault level takeoffs	V		
Check surge arrestor line side cabling size			
Check cable size with cable schedule		V	
Check cable size with rating of CB			
All control wiring ferruled as required		~	
All control wiring numbers and colours as per drawings		V	
Wiring looms to doors incorporates suitable slack	1		
All terminal numbers fitted		/	
Terminals randomly checked for tightness		/	
Check contactors, O/L's and CB's are correct for particular operation	~		
Check fuses for continuity		/	
Check fuses for correct current rating		V	
All indicators correct colour and voltage	V		
All pushbuttons correct colour	V		
Labels correct sizes, colours and wording			
All labels secured with screws			
All internal equipment labelled		1	
Ammeters and CT's correct range	V		
CT test block fitted	V		
Voltmeters correct range	V		
Bolts fitted to incoming terminations	V		
Phase separators and shrouds provided			
Fit fuse cartridges		V	
Sample check tightness of connections		/	
All protective covers in place	~		
All duct lid fitted		~	
All pole fillers fitted	/	1 4 1	
ighting operation correct	v		
Door limit switches operational	1		
All doors are earthed		V	
All escutcheons are earthed		~	
C.T secondary's earthed			
All transformer secondaries are earthed	1		
All power supplies 0 Volts are earthed	/		
Check correct screen connections of analog and VSD cable	~		
Adjust O/L settings to motor current or minimum	~		
adjust timers to correct values	1		
djust CB settings	V		
djust RCD settings			
oint to point wiring check completed			
ont to point witing orlook completed			



		INSULATION R	ESISTA	NCE TESTS	S	
neutrals, surge ar the test instrumen	restors and an t on the 1000 V	y equipment that of old range.	could be	damaged b	ate the MEN link, F by the tests. Carry o CRITERIA IS > 1 MΩ	
Red – White	MC		102 120	ΜΩ	Red - Blue	Ι Δ ΜΩ
Red - Neutral	N/M MC	White - Neutral		DM NIA	Blue - Neutral	MA MO
Red - Earth	IVIT MC	White - Earth		IVIT MO	Blue - Earth	MΩ
Neutral - Earth	MC					
DIS	STRIBUTION IN	SULATION RESIST	ANCE TE	STS - PASS	CRITERIA IS > 1 MΩ	
Red - White	MΩ	White - Blue		Λ ΜΩ	Red - Blue	, ΜΩ
Red - Neutral	ND MO	White - Neutral		MM FILL	Blue - Neutral	AIN MO
Red - Earth	INC. WO	White - Earth		ΜΩ	Blue - Earth	ΙΟΙ ΜΩ
Neutral - Earth	MΩ					
N/A:	Pass:		Init:		Date:	
	Reconne	ct all equipment i	solated	for the insu	lation tests	

- Rev 00

Page 7 of 9



### 5. Test Completion Acceptance

NAME	COMPANY	LIC/REG NO	SIGNATURE	DATE
J. Jordan	MPA	PGE233425		05/06/2017
				( <sup>N</sup>
		1		



### 6. APPENDIXES

AREA	CABLE ID	CABLE RUN FROM	CABLE RUN TO	CABLE TEST DATE	RED/WHITE	RED/BLUE	WHITE/BLUE	RED/EARTH	WHITE/EARTH	BLUE/EARTH	CONTROL CABLE MULTI- CORE	ANALOG CABLE	TEST SUMMARY	COMMENT
HEAT	FCU(26 11-coi	School	JB626	4/6/12							V			
xheory	12651.cd	it	2B 626-21	4/6/12										
	FCU 62631-caj	i.		4/6/12							~			
	FCU 62641-6	,		4/6/12	Land of the second						V			
												4.0		

- Rev 00

Page 9 of 9

19323 - Oxley WRP CAMBI Heat Exchange Upgrade Amiad Strainers Electrical Installation Test Sheet Copyright © MPA Engineering Pty Ltd. All Rights Reserved.

#### Cable Schedule

Engineeri Seosfesis Bennes	PHASE TESTING TEST CABLES TO EARTH							Project: John Holland Oxley Zone 3 Cable Testing						
AREA	CABLERO	CABLE RUN FROM	CABLE RUN TO	CABLE TEST DATE	REDANNITE	RED/BLUE	MAINTENBLUE	REDREARTH	0000				JOB N	Project: John Holland Oxley Zone 3 Cable Testing o: 191216 — CAMBI
Sludge Room	MCC-023-01 -POI/POZ/PO3	MC-021-01	MCC-023-01	11/5/12	1000 NV	100010	The state of the s		WHITE/EARTH	BLUEZEARTH	CONTROL CABLE	ANALOG CABLE	TEST SUMMARY	COMMENT
		MS	Busbar		1 1	11	11	11	INOONT	ILMOOD				
		CO-625801 +VAI THP	compressor	11	1.1	11	11	1.1	1)	11				
		W-625802	11	(r	.1	1.1	1.	1,	10	1 f			V	
		PU-625001	Lirc. pump,	it	00	00	$\infty$	$\infty$					V	
		PU-62501	V5D	1,	-1	( *		,,	00	00				
		0-Q3+VAI	surge - protection	1.4	11	11	11	15	10	,(				
		0-03+VA1	power	1,	11	1.	1,	11	.5	11				
		PU-625002	Grc, pump 2	11	Tv	11	11	7.	11	11				
		PU-625003	reactor feed rump	11	11	( -	1,	11	11	11				
		PU-625004	teactor 2 digester [feet pump]	N	11	11	) (	11		11			/	
		PV-625401	diagratur feed pump						1 (	1 ,				
		PU-625402	digestor										V	
		PV-625601	ejector 1									•	/	
		PV-625602	ejektorzt water aumo											
		0 +UAG	tead pump 2 ligestor 1 Ligestor 1 water pump eyektor 2 water pump ewhi cond. element digester feed pump 3											
		90-625403	digester feet aumo 3											
			· recipes											
							1							

J. JORDAAN 11/5/2012

### 2.2.4. FAT Checksheets



# **OXLEY WRP**

# **FLOOD RECOVERY ZONE 3**

Factory Acceptance Test – PLC & SCADA
Heat Exchanger Modification

### THE ENGINEERS, THE IDEAS, THE SOLUTIONS

www.mpaeng.com.au

Fax: 07 3881 0723 Breakdown Service: 0411

HEAD OFFICE 221 446 IPSWICH TOWNSVILLE SYDNEY MELBOURNE Unit 3/22-24 Strathwyn St Brendale Qld 4500

117 Toongarra Rd Ipswich Qld 4305 14 Chaimberlane Crt Kirwan Qld 4817 8 Charles St St Marys NSW 2760 Unit 10/64 Oakover Rd Preston Vic 3072 Tel: 07 3813 7100 Tel: 07 4723 6882 Tel: 02 9623 7066 Tel: 03 9480 8006

Tel: 07 3881 0722

Fax: 07 3813 7199 Fax: 07 4723 6585 Fax: 02 9623 7166 Fax: 07 9416 8591



Do	cument Control							
	Document Title	Factory Acceptance Test- PLC & SCADA						
ation	Document Subtitle	Oxley WRP Zone3 - Heat Exchanger Modification Control System FAT						
Identification	Document Number	MPA-19323-FAT						
_	Client Reference							
	Path\File Name							
>	Written by	M Garrosi	Control Systems Engineer					
Authority	Authorised by							
Ā	Client Authorisation							
d	Copyright	Copyright © MPA	Engineering Pty Ltd. ABN 77 011 069 533					
Ownership	Intellectual Property	Pty Ltd asserts ownership of the intellectual d herein, and claims copyright and authorship. Pty Ltd has and retains all rights of ownership aterial herein in its on-going business.						

Revisi	Revision History							
Rev	Date	Ву	Remarks	Checked				
0.0	26 May 2012	MG						

19323 – Oxley Flood Recovery Zone 3

Page 2 of 24

Heat Exchanger Modification - Factory Acceptance Testing - Procedure and Results Rev 0.0 Copyright © MPA Engineering Pty Ltd. All Rights Reserved.



## **CONTENTS**

1.	Int	troduction	4
1.1	(	General	4
1.2	(	Objectives	4
1.3	9	Scope	4
1.4	ı	Reference Table	4
1.5	ı	Defect Notice	4
1.6	I	Defect Notice Template	5
2.	Te	st summary	6
2.1	-	Test Method Description	6
2.2	]	I/O Test:	6
2	.2.3	Digital Inputs:	6
2	.2.4	Digital Outputs:	7
2.3		Heat Exchanger 1 Sludge Outlet Auto Valve FCV-626-13	
2.4	- 1	Heat Exchanger 1 Auto Flush Drain Valve FCV-626-14	9
2.5	I	Heat Exchanger 1 Service Water Auto Flush Inlet Valve FCV-626-90	10
2.6	I	Heat Exchanger 2 Sludge Outlet Auto Valve FCV-626-23	11
2.7	ı	Heat Exchanger 2 Auto Flush Drain Valve FCV-626-24	12
2.8	- 1	Heat Exchanger 2 Service Water Auto Flush Inlet Valve FCV-626-94	13
2.9	-	Automatic Control	14
2	.9.1	Heat Exchanger 1 Normal Operation	
2	.9.2	Heat Exchanger 2 Normal Operation	
2	.9.3	Heat Exchanger 1 Flush Control	
2	.9.4	Heat Exchanger 2 Flush Control	
2	.9.5	SCADA Alarms	
	.9.6	SCADA Trends	23
3.	Te	st Completion Acceptance	24



### 1. INTRODUCTION

### 1.1 General

The tests described below are designed to test the control and indication of the PLC & SCADA (control system). As the test will be done with simulation, and also on the switchboard, all the conditions could not be achieved. Problems may arise while conducting the tests as described; which may necessitate conducting of further tests not described herein. Any subsequent tests or notes should be documented in the space provided.

Any abnormalities with the operation of function of any of the equipment being tested shall be noted, even if not specifically covered by the test procedure. All devices shall be checked thoroughly for correct installation. Any items that may warrant attention must be noted in the space provided on each item's test plan.

### 1.2 Objectives

The Objective of this document is to provide a structured and detailed methodology to allow the Testing Officer to fully and methodically test the functionality of the Oxley WRP – Sludge PLC – Heat Exchanger Units. In addition this document is used to record all the results that are observed during the execution of this protocol. Completion of these test sequences verifies the basic unit functionality of each inspected device as well as the higher level automation that ties together the devices as a collective as detailed.

### 1.3 Scope

The scope of this document is the testing of device standard operational/status aspects in the PLC/SCADA. Higher level automation of each plant module as required for the process control including process set-points and alarms will be tested on site and appropriate SAT document will be provided.

#### 1.4 Reference Table

Name	Details
Oxley WRP FDS	Functional Description

### 1.5 Defect Notice

Non-conforming items should be rectified immediately if possible. If the defect is not the responsibility of the tester, then a defect notice should be provided to the appropriate person(s). A defect notice template is supplied in the next section.

A copy of the defect report shall be given to the manufacturer, supplier or subcontractor and they shall take corrective action in time for the date of re-inspection or advise in writing that the defect report is disputed and include the reason(s).



#### 1.6 **Defect Notice Template**

PROJECT: Oxley WRP Flood Recovery Zone 3								
TNICDEC	TTONLLOC	ATTON:						
INSPEC	TION LOCATOR:	ATION:						
INSPLC	IUK.							
Sect.	Insp.	Date	Defect Description	Corrected Date				
No.	No.			& Signature				
DECOMI	I MENDATIC	NIC:						
ALCOM	LILIDAIL	,,,,,,						
RE-INSF	PECTION D	DATE:						

19323 – Oxley Flood Recovery Zone 3

Heat Exchanger Modification - Factory Acceptance Testing - Procedure and Results Rev 0.0 Copyright © MPA Engineering Pty Ltd. All Rights Reserved.

Page 5 of 24



### 2. TEST SUMMARY

### 2.1 Test Method Description

The following sections describe the method of testing the system. The tests procedures are described in a numerically logical order, but do not necessarily have to be performed in this order, and several testing points can be combined and conducted at the same time.

Prior to conducting the test, it's very important to check all Electrical and Mechanical test sheet(s) and/or check list(s) that should indicate the readiness of all installed equipment. (In case the test are for installed equipment)

During the test, it's a common practice to start looking for ways that the code could be improved, and for areas that could be a source of potential problems; in order to optimize the operation – as such cannot be achieved to fullest at design and programming stages.

### 2.2 I/O Test:

Devices should be activated/driven to give the corresponding I/O's. When it's not possible, it should be simulated. Either way, the PLC corresponding I/O should be noted for correct configuration, tagging and description.

Alarm and fault digital statuses are fail-safe wherever applicable. Hence, input should be ON to indicate healthy status. Analogue scaling values (minimum and maximum) should be logged in the PLC and recorded here.

#### 2.2.3 Digital Inputs:

Address	Symbol	Description	Test	comment
132.2	SLG01ZSC62613diClosed	Valve Closed		
132.3	SLG01ZSC62613diOpened	Valve Opened		
132.4	SLG01ZSC62614diClosed	Valve Closed		
132.5	SLG01ZSC62614diOpened	Valve Opened		
132.6	SLG01ZSC62623diClosed	Valve Closed		
132.7	SLG01ZSC62623diOpened	Valve Opened		
133.0	SLG01ZSC62624diClosed	Valve Closed		
133.1	SLG01ZSC62624diOpened	Valve Opened		
133.2	SLG01ZSC62690diClosed	Valve Closed		
133.3	SLG01ZSC62690diOpened	Valve Opened		
133.4	SLG01ZSC62694diClosed	Valve Closed		
133.5	SLG01ZSC62694diOpened	Valve Opened		

Page 6 of 24



# 2.2.4 Digital Outputs:

Address	Symbol	Description	Test	comment
Q9.0	SLG01FCV62613doOpen	Open Valve		
Q9.1	SLG01FCV62614doOpen	Open Valve		
Q9.2	SLG01FCV62623doOpen	Open Valve		
Q9.3	SLG01FCV62624doOpen	Open Valve		
Q9.4	SLG01FCV62690doOpen	Open Valve		
Q9.5	SLG01FCV62694doOpen	Open Valve		



# 2.3 Heat Exchanger 1 Sludge Outlet Auto Valve FCV-626-13

No.	Pre-condition	Action	Response	PLC Check	SCADA Check	Client Check	Comment
1	Device Available	Simulate a Fault	Device Unavailable				
2	In Remote Manual Mode, No Fault Condition	Manual Open Command	Valve Opened				
3	In Remote Manual Mode, No Fault Condition	Manual Close Command	Valve Closed				
4	In Remote Manual Mode, No Fault Condition Set fail 2 Open Timer (10s)	Manual Open Command Open Feedback Inactive	Failed to Open Alarm after delay time				
5	In Remote Manual Mode, No Fault Condition Set fail 2 Open Timer (10s)	Manual Close Command Close Feedback Inactive	Failed to Close Alarm after delay time				
6	No Fault Condition	Simulate Both Open and Close feedbacks inactive	Fail to close or Fail to open Alarm shall raise after Delay time				
7	No Fault Condition	Simulate Both Open and Close feedbacks active	Fail to close or Fail to open Alarm shall raise after Delay time				Valve Control Standard Function needs to be modified
8							
9							
10							

N I	_ 1		_
IN	O	гe	:

19323 – Oxley Flood Recovery Zone 3

Page 8 of 24



# 2.4 Heat Exchanger 1 Auto Flush Drain Valve FCV-626-14

No.	Pre-condition	Action	Response	PLC Check	SCADA Check	Client Check	Comment
1	Device Available	Simulate a Fault	Device Unavailable				
2	In Remote Manual Mode, No Fault Condition	Manual Open Command	Valve Opened				
3	In Remote Manual Mode, No Fault Condition	Manual Close Command	Valve Closed				
4	In Remote Manual Mode, No Fault Condition Set fail 2 Open Timer (10s)	Manual Open Command Open Feedback Inactive	Failed to Open Alarm after delay time				
5	In Remote Manual Mode, No Fault Condition Set fail 2 Open Timer (10s)	Manual Close Command Close Feedback Inactive	Failed to Close Alarm after delay time				
6	No Fault Condition	Simulate Both Open and Close feedbacks inactive	Fail to close or Fail to open Alarm shall raise after Delay time				
7	No Fault Condition	Simulate Both Open and Close feedbacks active	Fail to close or Fail to open Alarm shall raise after Delay time				Valve Control Standard Function needs to be modified
8							
9							
10							

Note:

19323 – Oxley Flood Recovery Zone 3

Page 9 of 24



# 2.5 Heat Exchanger 1 Service Water Auto Flush Inlet Valve FCV-626-90

No.	Pre-condition	Action	Response	PLC Check	SCADA Check	Client Check	Comment
1	Device Available	Simulate a Fault	Device Unavailable				
2	In Remote Manual Mode, No Fault Condition	Manual Open Command	Valve Opened				
3	In Remote Manual Mode, No Fault Condition	Manual Close Command	Valve Closed				
4	In Remote Manual Mode, No Fault Condition Set fail 2 Open Timer (10s)	Manual Open Command Open Feedback Inactive	Failed to Open Alarm after delay time				
5	In Remote Manual Mode, No Fault Condition Set fail 2 Open Timer (10s)	Manual Close Command Close Feedback Inactive	Failed to Close Alarm after delay time				
6	No Fault Condition	Simulate Both Open and Close feedbacks inactive	Fail to close or Fail to open Alarm shall raise after Delay time				
7	No Fault Condition	Simulate Both Open and Close feedbacks active	Fail to close or Fail to open Alarm shall raise after Delay time				Valve Control Standard Function needs to be modified
8							
9							
10							

Note:

19323 – Oxley Flood Recovery Zone 3

Page 10 of 24



# 2.6 Heat Exchanger 2 Sludge Outlet Auto Valve FCV-626-23

No.	Pre-condition	Action	Response	PLC Check	SCADA Check	Client Check	Comment
1	Device Available	Simulate a Fault	Device Unavailable				
2	In Remote Manual Mode, No Fault Condition	Manual Open Command	Valve Opened				
3	In Remote Manual Mode, No Fault Condition	Manual Close Command	Valve Closed				
4	In Remote Manual Mode, No Fault Condition Set fail 2 Open Timer (10s)	Manual Open Command Open Feedback Inactive	Failed to Open Alarm after delay time				
5	In Remote Manual Mode, No Fault Condition Set fail 2 Open Timer (10s)	Manual Close Command Close Feedback Inactive	Failed to Close Alarm after delay time				
6	No Fault Condition	Simulate Both Open and Close feedbacks inactive	Fail to close or Fail to open Alarm shall raise after Delay time				
7	No Fault Condition	Simulate Both Open and Close feedbacks active	Fail to close or Fail to open Alarm shall raise after Delay time				Valve Control Standard Function needs to be modified
8							
9							
10							

N I	_ 1		_
IN	O	гe	:

19323 – Oxley Flood Recovery Zone 3

Page 11 of 24



# 2.7 Heat Exchanger 2 Auto Flush Drain Valve FCV-626-24

No.	Pre-condition	Action	Response	PLC Check	SCADA Check	Client Check	Comment
1	Device Available	Simulate a Fault	Device Unavailable				
2	In Remote Manual Mode, No Fault Condition	Manual Open Command	Valve Opened				
3	In Remote Manual Mode, No Fault Condition	Manual Close Command	Valve Closed				
4	In Remote Manual Mode, No Fault Condition Set fail 2 Open Timer (10s)	Manual Open Command Open Feedback Inactive	Failed to Open Alarm after delay time				
5	In Remote Manual Mode, No Fault Condition Set fail 2 Open Timer (10s)	Manual Close Command Close Feedback Inactive	Failed to Close Alarm after delay time				
6	No Fault Condition	Simulate Both Open and Close feedbacks inactive	Fail to close or Fail to open Alarm shall raise after Delay time				
7	No Fault Condition	Simulate Both Open and Close feedbacks active	Fail to close or Fail to open Alarm shall raise after Delay time				Valve Control Standard Function needs to be modified
8							
9							
10							

Note:

19323 – Oxley Flood Recovery Zone 3

Page 12 of 24

Heat Exchanger Modification - Factory Acceptance Testing - Procedure and Results Rev 0.0 Copyright © MPA Engineering Pty Ltd. All Rights Reserved.

Q-Pulse Id: TMS217 05/03/2013 152 of 661



# 2.8 Heat Exchanger 2 Service Water Auto Flush Inlet Valve FCV-626-94

No.	Pre-condition	Action	Response	PLC Check	SCADA Check	Client Check	Comment
1	Device Available	Simulate a Fault	Device Unavailable				
2	In Remote Manual Mode, No Fault Condition	Manual Open Command	Valve Opened				
3	In Remote Manual Mode, No Fault Condition	Manual Close Command	Valve Closed				
4	In Remote Manual Mode, No Fault Condition Set fail 2 Open Timer (10s)	Manual Open Command Open Feedback Inactive	Failed to Open Alarm after delay time				
5	In Remote Manual Mode, No Fault Condition Set fail 2 Open Timer (10s)	Manual Close Command Close Feedback Inactive	Failed to Close Alarm after delay time				
6	No Fault Condition	Simulate Both Open and Close feedbacks inactive	Fail to close or Fail to open Alarm shall raise after Delay time				
7	No Fault Condition	Simulate Both Open and Close feedbacks active	Fail to close or Fail to open Alarm shall raise after Delay time				Valve Control Standard Function needs to be modified
8							
9							
10							

Note:

19323 – Oxley Flood Recovery Zone 3

Page 13 of 24



#### 2.9 Automatic Control

The purpose of this section is to verify that correct function is given by all equipment in accordance with the control philosophy. It involves testing/running the equipment in Automatic Mode.

### 2.9.1 Heat Exchanger 1 Normal Operation

No.	Pre-condition	Action	Response	PLC Check	SCADA Check	Client	Comment
1	- All associated devices are available in Remote Auto: FCV62613 FCV62614 FCV62690 FCV62604 - The Inlet Hand Valve set to Open - The associated Instruments are available: TT62601 TT62604 - The Auto Flush Valves in closed position	-	Heat Exchanger Available				
2	Heat Exchanger Available	- Set Heat Exchanger Online	- Heat Exchanger Online - Sludge Outlet Valve Shall be opened				
3	Heat Exchanger is Online	- Set Heat Exchanger Offline	- Sludge Outlet Valve Shall be Closed				
4	Heat Exchanger is Online	Simulate one of following items: - FCV62613 in Manual or Faulty - FCV62614 in Manual or Faulty - FCV62690 in Manual or Faulty - FCV62604 in Manual or Faulty - The Inlet Hand Valve set to closed - TT62601 Faulty - TT62604 Faulty - FCV62614 Open - FCV62690 Open	- Heat Exchanger Offline - Heat Exchanger Unavailable				

19323 - Oxley Flood Recovery Zone 3

Page 14 of 24



No.	Pre-condition	Action	Response	PLC Check	SCADA Check	Comment
5	- Heat Exchanger Unavailable	-Set Heat Exchanger Online	- Heat Exchanger Offline			
6	- Heat Exchanger Online - TT62601 not in High Level - TT62604 not in High Level - At least one of the digester inlet control valves is open - FCV62613 is open	-	- Digester feed pump 1 Interlock is healthy - Digester feed pump 2 Interlock is healthy			
7	- Digester feed pump 1 Interlock is healthy - Digester feed pump 2 Interlock is healthy	Simulate one of following items: - Heat Exchanger Offline - TT62601 High Level Alarm - TT62604 High Level Alarm - Close all the digester inlet control valves - Close FCV62613	- Digester feed pump 1 Interlock is not healthy - Digester feed pump 2 Interlock is not healthy			
8	- Heat Exchanger Online - Feed Pump 1 or 2 Interlock is Healthy - Pump 1 or 2 is Running	- Simulate the Sludge Outlet Temperature (Process Variable) higher than Setpoint	- Heat Exchanger Cooling Water Flow Control Valve Shall attempt to touch the setpoint			
9						
10						
11						
12						
13						
14						
15						
Note	:			•	•	

19323 – Oxley Flood Recovery Zone 3

Page 15 of 24



# 2.9.2 Heat Exchanger 2 Normal Operation

No.	Pre-condition	Action	Response	PLC Check	SCADA Check	Client	Comment
1	- All associated devices are available in Remote Auto: FCV62623 FCV62624 FCV62694 FCV62606 - The Inlet Hand Valve set to Open - The associated Instruments are available: TT62602 TT62606 - The Auto Flush Valves in closed position	-	Heat Exchanger Available				
2	Heat Exchanger Available	- Set Heat Exchanger Online	- Heat Exchanger Online - Sludge Outlet Valve Shall be opened				
3	Heat Exchanger is Online	- Set Heat Exchanger Offline	- Sludge Outlet Valve Shall be Closed				
4	Heat Exchanger is Online	Simulate one of following items: - FCV62623 in Manual or Faulty - FCV62624 in Manual or Faulty - FCV62694 in Manual or Faulty - FCV62606 in Manual or Faulty - The Inlet Hand Valve set to closed - TT62602 Faulty - TT62606 Faulty - FCV62624 Open - FCV62694 Open	- Heat Exchanger Offline - Heat Exchanger Unavailable				
5	- Heat Exchanger Unavailable	-Set Heat Exchanger Online	- Heat Exchanger Offline				
6	- Heat Exchanger Online - TT62602 not in High Level - TT62606 not in High Level - At least one of the digester inlet control valves is open - FCV62623 is open	-	- Digester feed pump 2 Interlock is healthy - Digester feed pump 3 Interlock is healthy				

19323 – Oxley Flood Recovery Zone 3

Page 16 of 24



No.	Pre-condition	Action	Response	PLC Check	SCADA Check	Client Check	Comment
7	- Digester feed pump 2 Interlock is healthy - Digester feed pump 3 Interlock is healthy	Simulate one of following items: - Heat Exchanger Offline - TT62602 High Level Alarm - TT62606 High Level Alarm - Close all the digester inlet control valves - Close FCV62623	- Digester feed pump 2 Interlock is not healthy - Digester feed pump 3 Interlock is not healthy				
8	- Heat Exchanger Online - Feed Pump 2 or 3 Interlock is Healthy - Pump 2 or 3 is Running	- Simulate the Sludge Outlet Temperature (Process Variable) higher than Setpoint	- Heat Exchanger Cooling Water Flow Control Valve Shall attempt to touch the setpoint				
9							
10							
11							
12							
13							
14							
15							
Note	<u>.</u>		•			•	

Note:

19323 – Oxley Flood Recovery Zone 3

Page 17 of 24



# 2.9.3 Heat Exchanger 1 Flush Control

No.	Pre-condition	Action	Response	PLC Check	SCADA Check	Client	Comment
1	- All associated devices are available in Remote Auto: FCV62613 FCV62614 FCV62690 FCV62604 - Heat Exchanger Offline	-	Heat Exchanger Flush Available				
2	- Heat Exchanger Flush Available	- Set Heat Exchanger Flush to Manual Mode - Set Flush Time Setpoint to 1 Min - Start Flush Sequence Manually	- Flush Sequence Starts and goes to step 1				
3	- Flush Sequence in Step 1	Simulate Digester Pump Permissive: - Digester Feed Pump 1 not Running - Digester Feed Pump 2 not Running - FCV62523 is Closed - FCV62533 is Closed	- Flush Sequence goes to Step 2				
4	- Flush Sequence in Step 2	- Sim Digester Outlet Valve Closed	- Flush Sequence goes to Step 3				
5	- Flush Sequence in Step 3	- Sim Flush Drain Valve Opened	- Flush Sequence goes to Step 4				
6	- Flush Sequence goes to Step 4	- Sim Flush Inlet Valve Opened	- Flush Sequence goes to Step 5				
7	- Flush Sequence goes to Step 5	- Wait for 1 Min (Flush Time Setpoint)	- Flush Sequence goes to Step 6				
8	- Flush Sequence goes to Step 6	- Sim Flush Inlet Valve Closed	- Flush Sequence goes to Step 7				
9	- Flush Sequence goes to Step 7	- Sim Flush Drain Valve Closed	- Flush Sequence goes to Step 8				
10	- Flush Sequence goes to Step 8	-	- Flush Sequence Completed				
11	- Heat Exchanger Online - Heat Exchanger Flush Available - Heat Exchanger Flush On Remote/Auto Mode	- Set the Heat Exchanger to Offline Mode	- Flush Sequence Starts and goes to step 1				

19323 – Oxley Flood Recovery Zone 3

Page 18 of 24



No.	Pre-condition	Action	Response	PLC Check	SCADA Check	Client Check	Comment
12	- Flush Sequence in Step 1	Simulate Digester Pump Permissive: - Digester Feed Pump 1 not Running - Digester Feed Pump 2 not Running - FCV62523 is Closed - FCV62533 is Closed	- Flush Sequence goes to Step 2				
13	- Flush Sequence in Step 2	- Sim Digester Outlet Valve Closed	- Flush Sequence goes to Step 3				
14	- Flush Sequence in Step 3	- Sim Flush Drain Valve Opened	- Flush Sequence goes to Step 4				
15	- Flush Sequence goes to Step 4	- Sim Flush Inlet Valve Opened	- Flush Sequence goes to Step 5				
16	- Flush Sequence goes to Step 5	- Wait for 1 Min (Flush Time Setpoint)	- Flush Sequence goes to Step 6				
17	- Flush Sequence goes to Step 6	- Sim Flush Inlet Valve Closed	- Flush Sequence goes to Step 7				
18	- Flush Sequence goes to Step 7	- Sim Flush Drain Valve Closed	- Flush Sequence goes to Step 8				
19	- Flush Sequence goes to Step 8	-	- Flush Sequence Completed				
20							
21							
22							
23							
24							
25							
26							
Note	ינ	•		•	•		

Note:

19323 – Oxley Flood Recovery Zone 3

Page 19 of 24



# 2.9.4 Heat Exchanger 2 Flush Control

No.	Pre-condition	Action	Response	PLC Check	SCADA Check	Client	Comment
1	- All associated devices are available in Remote Auto: FCV62613 FCV62614 FCV62690 FCV62604 - Heat Exchanger Offline	-	Heat Exchanger Flush Available				
2	- Heat Exchanger Flush Available	- Set Heat Exchanger Flush to Manual Mode - Set Flush Time Setpoint to 1 Min - Start Flush Sequence Manually	- Flush Sequence Starts and goes to step 1				
3	- Flush Sequence in Step 1	Simulate Digester Pump Permissive: - Digester Feed Pump 1 not Running - Digester Feed Pump 2 not Running - FCV62523 is Closed - FCV62533 is Closed	- Flush Sequence goes to Step 2				
4	- Flush Sequence in Step 2	- Sim Digester Outlet Valve Closed	- Flush Sequence goes to Step 3				
5	- Flush Sequence in Step 3	- Sim Flush Drain Valve Opened	- Flush Sequence goes to Step 4				
6	- Flush Sequence goes to Step 4	- Sim Flush Inlet Valve Opened	- Flush Sequence goes to Step 5				
7	- Flush Sequence goes to Step 5	- Wait for 1 Min (Flush Time Setpoint)	- Flush Sequence goes to Step 6				
8	- Flush Sequence goes to Step 6	- Sim Flush Inlet Valve Closed	- Flush Sequence goes to Step 7				
9	- Flush Sequence goes to Step 7	- Sim Flush Drain Valve Closed	- Flush Sequence goes to Step 8				
10	- Flush Sequence goes to Step 8	-	- Flush Sequence Completed				
11	- Heat Exchanger Online - Heat Exchanger Flush Available - Heat Exchanger Flush On Remote/Auto Mode	- Set the Heat Exchanger to Offline Mode	- Flush Sequence Starts and goes to step 1				

19323 – Oxley Flood Recovery Zone 3

Page 20 of 24



No.	Pre-condition	Action	Response	PLC Check	SCADA Check	Client Check	Comment
12	- Flush Sequence in Step 1	Simulate Digester Pump Permissive: - Digester Feed Pump 1 not Running - Digester Feed Pump 2 not Running - FCV62523 is Closed - FCV62533 is Closed	- Flush Sequence goes to Step 2				
13	- Flush Sequence in Step 2	- Sim Digester Outlet Valve Closed	- Flush Sequence goes to Step 3				
14	- Flush Sequence in Step 3	- Sim Flush Drain Valve Opened	- Flush Sequence goes to Step 4				
15	- Flush Sequence goes to Step 4	- Sim Flush Inlet Valve Opened	- Flush Sequence goes to Step 5				
16	- Flush Sequence goes to Step 5	- Wait for 1 Min (Flush Time Setpoint)	- Flush Sequence goes to Step 6				
17	- Flush Sequence goes to Step 6	- Sim Flush Inlet Valve Closed	- Flush Sequence goes to Step 7				
18	- Flush Sequence goes to Step 7	- Sim Flush Drain Valve Closed	- Flush Sequence goes to Step 8				
19	- Flush Sequence goes to Step 8	-	- Flush Sequence Completed				
20							
21							
22							
23							
24							
25							
26							
Note	ינ	•		•	•		

Note:

19323 – Oxley Flood Recovery Zone 3

Page 21 of 24



#### 2.9.5 SCADA Alarms

No.	Description	SCADA Tag	PLC Check	SCADA Check	Client Check	Comment
1	Heat Exchanger 1 Sludge Outlet Auto Valve Fail to Close	ST022HYD01FCV62613dsF2Close				
2	Heat Exchanger 1 Sludge Outlet Auto Valve Fail to Open	ST022HYD01FCV62613dsF2Open				
3	Heat Exchanger 1 Auto Flush Drain Valve Fail to Close	ST022HYD01FCV62614dsF2Close				
4	Heat Exchanger 1 Auto Flush Drain Valve Fail to Open	ST022HYD01FCV62614dsF2Open				
5	Heat Exchanger 2 Sludge Outlet Auto Valve Fail to Close	ST022HYD01FCV62623dsF2Close				
6	Heat Exchanger 2 Sludge Outlet Auto Valve Fail to Open	ST022HYD01FCV62623dsF2Open				
7	Heat Exchanger 2 Auto Flush Drain Valve Fail to Close	ST022HYD01FCV62624dsF2Close				
8	Heat Exchanger 2 Auto Flush Drain Valve Fail to Open	ST022HYD01FCV62624dsF2Open				
9	Heat Exchanger 1 SW Auto Flush Inlet Valve Fail to Close	ST022HYD01FCV62690dsF2Close				
10	Heat Exchanger 1 SW Auto Flush Inlet Valve Fail to Open	ST022HYD01FCV62690dsF2Open				
11	Heat Exchanger 2 SW Auto Flush Inlet Valve Fail to Close	ST022HYD01FCV62694dsF2Close				
12	Heat Exchanger 2 SW Auto Flush Inlet Valve Fail to Open	ST022HYD01FCV62694dsF2Open				
13						
14						
15						
Note:	1	<b>'</b>				

Note:

19323 – Oxley Flood Recovery Zone 3

Page 22 of 24



#### 2.9.6 SCADA Trends

19323 – Oxley Flood Recovery Zone 3 Heat Exchanger Modification - Factory Acceptance Testing - Procedure and Results Rev 0.0

Copyright © MPA Engineering Pty Ltd. All Rights Reserved.

Page 23 of 24



# 3. TEST COMPLETION ACCEPTANCE

NAME	POSITION	COMPANY	SIGNATURE	DATE

19323 – Oxley Flood Recovery Zone 3

Page 24 of 24



# **OXLEY WRP**

# **FLOOD RECOVERY ZONE 3**

Factory Acceptance Test – PLC & SCADA Heat Exchanger Modification

### THE ENGINEERS, THE IDEAS, THE SOLUTIONS

#### www.mpaeng.com.au

HEAD OFFICE 221 446 IPSWICH TOWNSVILLE SYDNEY MELBOURNE Unit 3/22-24 Strathwyn St Brendale Qld 4500

117 Toongarra Rd Ipswich Qld 4305 14 Chaimberlane Crt Kirwan Qld 4817 8 Charles St St Marys NSW 2760 Unit 10/64 Oakover Rd Preston Vic 3072 Tel: 07 3881 0722 Tel: 07 3813 7100

Tel: 07 3813 7100 Fax: 07 3813 7199
Tel: 07 4723 6882 Fax: 07 4723 6585
Tel: 02 9623 7066 Fax: 02 9623 7166
Tel: 03 9480 8006 Fax: 07 9416 8591

Fax: 07 3881 0723 Breakdown Service: 0411 Fax: 07 3813 7199



Do	ocument Control								
	Document Title	Factory Accep	Factory Acceptance Test- PLC & SCADA						
ation	Document Subtitle		Oxley WRP Zone3 - Heat Exchanger Modification  Control System FAT						
Identification	Document Number	MPA-19323-FA	AT						
Ē	Client Reference								
	Path\File Name								
Y.	Written by	M Garrosi	Control Systems Engineer						
Authority	Authorised by								
V	Client Authorisation								
lp	Copyright	Copyright © MPA Engineering Pty Ltd. ABN 77 011 069 533							
Ownership	Intellectual Property	property conta MPA Engineer	ring Pty Ltd asserts ownership of the intellectual ained herein, and claims copyright and authorship ing Pty Ltd has and retains all rights of ownership material herein in its on-going business.						

Revision History					
Rev	Date	Ву	Remarks	Checked	
0.0	26 May 2012	MG			

19323 - Oxley Flood Recovery Zone 3

Page 2 of 24

 $\label{thm:condition} \mbox{ - Factory Acceptance Testing - Procedure and Results Rev 0.0} \\ \mbox{ Copyright } \mbox{$ 



### **CONTENTS**

1.	Introduction	4
1.1	General	4
1.2	Objectives	4
1.3	Scope	4
1.4	Reference Table	4
1.5	Defect Notice	4
1.6	Defect Notice Template	5
2.	Test summary	6
2.1	Test Method Description	6
2.2	I/O Test:	
2.	.3 Digital Inputs:	6
2.	.4 Digital Outputs:	
2.3	Heat Exchanger 1 Sludge Outlet Auto Valve FCV-626-13	8
2.4	Heat Exchanger 1 Auto Flush Drain Valve FCV-626-14	9
2.5	Heat Exchanger 1 Service Water Auto Flush Inlet Valve FCV-626-90	10
2.6	Heat Exchanger 2 Sludge Outlet Auto Valve FCV-626-23	11
2.7	Heat Exchanger 2 Auto Flush Drain Valve FCV-626-24	12
2.8	Heat Exchanger 2 Service Water Auto Flush Inlet Valve FCV-626-94	
2.9	Automatic Control	
2.		
2.	7	
2.	.3 Heat Exchanger 1 Flush Control	
2.	. Treat and let get a treat control in in in in in in in in in in in in in	
2.		
2.	.6 SCADA Trends	23
3.	Test Completion Acceptance	24



#### 1. INTRODUCTION

#### 1.1 General

The tests described below are designed to test the control and indication of the PLC & SCADA (control system). As the test will be done with simulation, and also on the switchboard, all the conditions could not be achieved. Problems may arise while conducting the tests as described; which may necessitate conducting of further tests not described herein. Any subsequent tests or notes should be documented in the space provided.

Any abnormalities with the operation of function of any of the equipment being tested shall be noted, even if not specifically covered by the test procedure. All devices shall be checked thoroughly for correct installation. Any items that may warrant attention must be noted in the space provided on each item's test plan.

#### 1.2 Objectives

The Objective of this document is to provide a structured and detailed methodology to allow the Testing Officer to fully and methodically test the functionality of the Oxley WRP – Sludge PLC – Heat Exchanger Units. In addition this document is used to record all the results that are observed during the execution of this protocol. Completion of these test sequences verifies the basic unit functionality of each inspected device as well as the higher level automation that ties together the devices as a collective as detailed.

#### 1.3 Scope

The scope of this document is the testing of device standard operational/status aspects in the PLC/SCADA. Higher level automation of each plant module as required for the process control including process set-points and alarms will be tested on site and appropriate SAT document will be provided.

#### 1.4 Reference Table

Name	Details
Oxley WRP FDS	Functional Description

#### 1.5 Defect Notice

Non-conforming items should be rectified immediately if possible. If the defect is not the responsibility of the tester, then a defect notice should be provided to the appropriate person(s). A defect notice template is supplied in the next section.

A copy of the defect report shall be given to the manufacturer, supplier or subcontractor and they shall take corrective action in time for the date of re-inspection or advise in writing that the defect report is disputed and include the reason(s).

Page 4 of 24

 $\label{thm:condition} \begin{tabular}{ll} Heat Exchanger Modification - Factory Acceptance Testing - Procedure and Results Rev 0.0 \\ Copyright © MPA Engineering Pty Ltd. All Rights Reserved. \\ \end{tabular}$ 



# 1.6 Defect Notice Template

ect.	Insp.	Date	Defect Description	Corrected Date
0.	No.			O. Cianahuma
	N T	30/5/12	TTG2GO4 + TTG2GOG TO HIGH HIGH ALARY ACTIVATES DIG FEED PUMP INTERLOCK. BRAPHIC COMMON BOX TO INCLUDE PUMP 3. FLUSH CYCLE TIME EXCEEDED ALARM FLUSHING TIME SP + SET PERIOD.	
		12-10/10	ACTIVIATES DIG. FEED PUMP INTERLOCK.	
-		30/5/12	EXAMPLE COMMON BOX TO INCLUDE PUMP 3.	
-		30/5/12	FLUSH CYCLE TIME EXCEEDED HLHRIM	
-			FLUSHING TIME ST + SET PERIOD.	
-	-			
LOM	MENDATIO	JNS:		

19323 – Oxley Flood Recovery Zone 3 Heat Exchanger Modification - Factory Acceptance Testing - Procedure and Result

Page 5 of 24



#### 2. TEST SUMMARY

#### 2.1 Test Method Description

The following sections describe the method of testing the system. The tests procedures are described in a numerically logical order, but do not necessarily have to be performed in this order, and several testing points can be combined and conducted at the same time.

Prior to conducting the test, it's very important to check all Electrical and Mechanical test sheet(s) and/or check list(s) that should indicate the readiness of all installed equipment. (In case the test are for installed equipment)

During the test, it's a common practice to start looking for ways that the code could be improved, and for areas that could be a source of potential problems; in order to optimize the operation – as such cannot be achieved to fullest at design and programming stages.

#### 2.2 I/O Test:

Devices should be activated/driven to give the corresponding I/O's. When it's not possible, it should be simulated. Either way, the PLC corresponding I/O should be noted for correct configuration, tagging and description.

Alarm and fault digital statuses are fail-safe wherever applicable. Hence, input should be ON to indicate healthy status. Analogue scaling values (minimum and maximum) should be logged in the PLC and recorded here.

#### 2.2.3 Digital Inputs:

Address	Symbol	Description	Test	comment
132.2	SLG01ZSC62613diClosed	Valve Closed		
132.3	SLG01ZSC62613diOpened	Valve Opened		
132.4	SLG01ZSC62614diClosed	Valve Closed		
132.5	SLG01ZSC62614diOpened	Valve Opened		
132.6	SLG01ZSC62623diClosed	Valve Closed		
132.7	SLG01ZSC62623diOpened	Valve Opened		
133.0	SLG01ZSC62624diClosed	Valve Closed		
133.1	SLG01ZSC62624diOpened	Valve Opened		
133.2	SLG01ZSC62690diClosed	Valve Closed		
133.3	SLG01ZSC62690diOpened	Valve Opened		
133.4	SLG01ZSC62694diClosed	Valve Closed		
133.5	SLG01ZSC62694diOpened	Valve Opened		

19323 - Oxley Flood Recovery Zone 3

Page 6 of 24

 $\label{thm:condition} \mbox{ - Factory Acceptance Testing - Procedure and Results Rev 0.0} \mbox{ Copyright } \mbox{ } \mbox{ MPA Engineering Pty Ltd. } \mbox{ All Rights Reserved.}$ 



# 2.2.4 Digital Outputs:

	Symbol	Description	Test	comment
Q9.0	SLG01FCV62613doOpen	Open Valve		
Q9.1	SLG01FCV62614doOpen	Open Valve		
Q9.2	SLG01FCV62623doOpen	Open Valve		
Q9.3	SLG01FCV62624doOpen	Open Valve		
Q9.4	SLG01FCV62690doOpen	Open Valve		
Q9.5	SLG01FCV62694doOpen	Open Valve		



# 2.3 Heat Exchanger 1 Sludge Outlet Auto Valve FCV-626-13

1 Device Available Simulate a Fault Device Unavailable	Comment
Condition	
Condition  In Remote Manual Mode, No Fault Condition Set fail 2 Open Timer (10s)  Manual Close Command Open Feedback Inactive  Manual Close Command Open Feedback Inactive  Manual Close Command Close Feedback Inactive  Manual Close Command Close Feedback Inactive  Failed to Close Alarm after delay time  Failed to Close Alarm after Delay time  Failed to Close or Fail to open Alarm shall raise after Delay time  No Fault Condition  Simulate Both Open and Close feedbacks inactive  Fail to close or Fail to open Alarm shall raise after Delay time  Valve Control time  Valve Control time	
4 Condition Set fail 2 Open Timer (10s)  In Remote Manual Mode, No Fault Condition Set fail 2 Open Timer (10s)  Manual Close Command Close Feedback Inactive  Failed to Close Alarm after delay time	
In Remote Manual Mode, No Fault Condition Set fail 2 Open Timer (10s)  Manual Close Command Close Feedback Inactive  Failed to Close Alarm after delay time  Failed to Close Alarm after Delay time  Fail to close or Fail to open Alarm shall raise after Delay time  Valve Control feedbacks active  No Fault Condition  Fail to close or Fail to open Alarm shall raise after Delay time  Valve Control fineeds to be meds to be meds to be meds active.	
7 No Fault Condition Simulate Both Open and Close feedbacks active Fail to close or Fail to open Alarm shall raise after Delay time Valve Control needs to be m	
feedbacks active time needs to be m	
	Standard Function nodified
9	
10	
Note:	

19323 - Oxley Flood Recovery Zone 3

Page 8 of 24



# 2.4 Heat Exchanger 1 Auto Flush Drain Valve FCV-626-14

No.	Pre-condition	Action	Response	PLC Check	SCADA Check	Client	Comment
1	Device Available	Simulate a Fault	Device Unavailable	V	V	- COL	
2	In Remote Manual Mode, No Fault Condition	Manual Open Command	Valve Opened	1	/		
3	In Remote Manual Mode, No Fault Condition	Manual Close Command	Valve Closed	V	~		
4	In Remote Manual Mode, No Fault Condition Set fail 2 Open Timer (10s)	Manual Open Command Open Feedback Inactive	Failed to Open Alarm after delay time	~	~		
5	In Remote Manual Mode, No Fault Condition Set fail 2 Open Timer (10s)	Manual Close Command Close Feedback Inactive	Failed to Close Alarm after delay time	1	/		
6	No Fault Condition	Simulate Both Open and Close feedbacks inactive	Fail to close or Fail to open Alarm shall raise after Delay time	/	/		
7	No Fault Condition	Simulate Both Open and Close feedbacks active	Fail to close or Fail to open Alarm shall raise after Delay time	/	/		Valve Control Standard Function needs to be modified
8					1-1		
9							
10							

Note: VALVE LIMIT FAULT RESULTS IN UNDEFINED STATUS. (OVERWRITING TEXTS)

19323 - Oxley Flood Recovery Zone 3

Page 9 of 24



# 2.5 Heat Exchanger 1 Service Water Auto Flush Inlet Valve FCV-626-90

Pre-condition	Action	Response	PLC Check	SCADA Check	Client Check	Comment
Device Available	Simulate a Fault	Device Unavailable	/	/		
In Remote Manual Mode, No Fault Condition	Manual Open Command	Valve Opened	/	/		
In Remote Manual Mode, No Fault Condition	Manual Close Command	Valve Closed	V	~		
In Remote Manual Mode, No Fault Condition Set fail 2 Open Timer (10s)	Manual Open Command Open Feedback Inactive	Failed to Open Alarm after delay time	/	/		
In Remote Manual Mode, No Fault Condition Set fail 2 Open Timer (10s)	Manual Close Command Close Feedback Inactive	Failed to Close Alarm after delay time	V	/		
No Fault Condition	Simulate Both Open and Close feedbacks inactive	Fail to close or Fail to open Alarm shall raise after Delay time	V	/		
No Fault Condition	Simulate Both Open and Close feedbacks active	Fail to close or Fail to open Alarm shall raise after Delay time	V	1		Valve Control Standard Function needs to be modified
	In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  Set fail 2 Open Timer (10s)  In Remote Manual Mode, No Fault Condition  Set fail 2 Open Timer (10s)  No Fault Condition	In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  Set fail 2 Open Timer (10s)  In Remote Manual Mode, No Fault Condition Set fail 2 Open Timer (10s)  In Remote Manual Mode, No Fault Condition Set fail 2 Open Timer (10s)  No Fault Condition  No Fault Condition  Simulate Both Open and Close feedbacks inactive  Simulate Both Open and Close Simulate Both Open and Close	Device Available  In Remote Manual Mode, No Fault Condition  et fail 2 Open Timer (10s)  In Remote Manual Mode, No Fault Condition Set fail 2 Open Timer (10s)  In Remote Manual Mode, No Fault Condition Set fail 2 Open Timer (10s)  Manual Close Command Close Feedback Inactive  Failed to Close Alarm after delay time  Failed to Close Alarm after delay time  Failed to Close or Fail to open Alarm shall raise after Delay time  No Fault Condition  Simulate Both Open and Close Fail to close or Fail to open Alarm shall raise after Delay Fail to close or Fail to open Alarm shall raise after Delay  Fail to close or Fail to open Alarm shall raise after Delay	Device Available  Simulate a Fault  Device Unavailable  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  Manual Close Command  Valve Opened  Valve Closed  Valve Closed  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  Set fail 2 Open Timer (10s)  In Remote Manual Mode, No Fault Condition Set fail 2 Open Timer (10s)  Manual Close Command Open Feedback Inactive  Manual Close Command Close Feedback Inactive  Failed to Close Alarm after delay time  Failed to Close Alarm after delay time  Failed to Close Alarm shall raise after Delay time  Simulate Both Open and Close feedbacks inactive  Simulate Both Open and Close Fail to close or Fail to open Alarm shall raise after Delay feedbacks inactive  Fail to close or Fail to open Alarm shall raise after Delay feedbacks inactive  Fail to close or Fail to open Alarm shall raise after Delay feedbacks inactive  Fail to close or Fail to open Alarm shall raise after Delay feedbacks inactive  Fail to close or Fail to open Alarm shall raise after Delay feedbacks inactive  Fail to close or Fail to open Alarm shall raise after Delay	Device Available  Simulate a Fault  Device Unavailable  Valve Opened  Valve Opened  Valve Closed  In Remote Manual Mode, No Fault Condition  Manual Close Command  Valve Closed  Valve Closed  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  Set fail 2 Open Timer (10s)  In Remote Manual Mode, No Fault Condition  Set fail 2 Open Timer (10s)  Manual Close Command Close Feedback Inactive  Manual Close Command Close Feedback Inactive  Failed to Close Alarm after delay time  Failed to Close Alarm after delay time  Failed to Close Alarm after delay time  Simulate Both Open and Close feedbacks inactive  Fail to close or Fail to open Alarm shall raise after Delay time  No Fault Condition  Simulate Both Open and Close Fail to close or Fail to open Alarm shall raise after Delay Fail to close or Fail to open Alarm shall raise after Delay Fail to close or Fail to open Alarm shall raise after Delay	Device Available  Simulate a Fault  Device Unavailable  In Remote Manual Mode, No Fault Condition  Manual Open Command  Valve Opened  Valve Opened  Valve Closed  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  Set fail 2 Open Timer (10s)  In Remote Manual Mode, No Fault Condition  Set fail 2 Open Timer (10s)  Manual Close Command Close Feedback Inactive  Manual Close Command Close Feedback Inactive  Failed to Open Alarm after delay time  Failed to Close Alarm after delay time  Failed to Close Alarm after delay time  Simulate Both Open and Close feedbacks inactive  Fail to close or Fail to open Alarm shall raise after Delay time  Simulate Both Open and Close Fail to close or Fail to open Alarm shall raise after Delay time  Fail to close or Fail to open Alarm shall raise after Delay time

19323 - Oxley Flood Recovery Zone 3

Page 10 of 24



# 2.6 Heat Exchanger 2 Sludge Outlet Auto Valve FCV-626-23

Device Available			Check	Check	Check	Comment
	Simulate a Fault	Device Unavailable	V	1		
In Remote Manual Mode, No Fault Condition	Manual Open Command	Valve Opened	L-	V		
	Manual Close Command	Valve Closed	V	/		
Condition	Manual Open Command Open Feedback Inactive	Failed to Open Alarm after delay time	/	/		
In Remote Manual Mode, No Fault Condition	Manual Close Command Close Feedback Inactive	Failed to Close Alarm after delay time	V	1		
No Fault Condition	Simulate Both Open and Close feedbacks inactive	Fail to close or Fail to open Alarm shall raise after Delay time	V	v		
No Fault Condition	Simulate Both Open and Close feedbacks active	Fail to close or Fail to open Alarm shall raise after Delay time	V	/		Valve Control Standard Function needs to be modified
	In Remote Manual Mode, No Fault Condition In Remote Manual Mode, No Fault Condition Set fail 2 Open Timer (10s) In Remote Manual Mode, No Fault Condition Set fail 2 Open Timer (10s) No Fault Condition No Fault Condition	In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition Set fail 2 Open Timer (10s)  In Remote Manual Mode, No Fault Condition Set fail 2 Open Timer (10s)  No Fault Condition  Manual Close Command Close Feedback Inactive  Manual Close Command Close Feedback Inactive  Simulate Both Open and Close feedbacks inactive  Simulate Both Open and Close	In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  Set fail 2 Open Timer (10s)  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  Manual Close Command Open Feedback Inactive  Manual Close Command Close Feedback Inactive  Manual Close Command Close Feedback Inactive  Failed to Close Alarm after delay time  Failed to Close Alarm after delay time  Failed to Close or Fail to open Alarm shall raise after Delay feedbacks inactive  Simulate Both Open and Close Fail to close or Fail to open Alarm shall raise after Delay Fail to close or Fail to open Alarm shall raise after Delay	In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  Set fail 2 Open Timer (10s)  In Remote Manual Mode, No Fault Condition  Set fail 2 Open Timer (10s)  Manual Close Command Open Feedback Inactive  Manual Close Command Close Feedback Inactive  Manual Close Command Close Feedback Inactive  Failed to Close Alarm after delay time  Failed to Close Alarm after delay time  Fail to close or Fail to open Alarm shall raise after Delay time  No Fault Condition  Simulate Both Open and Close Fail to close or Fail to open Alarm shall raise after Delay Fail to close or Fail to open Alarm shall raise after Delay Fail to close or Fail to open Alarm shall raise after Delay	In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  Set fail 2 Open Timer (10s)  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  Manual Close Command Open Feedback Inactive  Manual Close Command Close Feedback Inactive  Manual Close Command Close Feedback Inactive  Failed to Close Alarm after delay time  Failed to Close Alarm after delay time  Fail to close or Fail to open Alarm shall raise after Delay  No Fault Condition  Simulate Both Open and Close Feedbacks inactive  Fail to close or Fail to open Alarm shall raise after Delay  Fail to close or Fail to open Alarm shall raise after Delay	In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  Set fail 2 Open Timer (10s)  In Remote Manual Mode, No Fault Condition  Set fail 2 Open Timer (10s)  Manual Close Command Open Feedback Inactive  Manual Close Command Close Feedback Inactive  Failed to Open Alarm after delay time  Failed to Close Alarm after delay time  Failed to Close Alarm after delay time  Simulate Both Open and Close feedbacks inactive  Fail to close or Fail to open Alarm shall raise after Delay time  No Fault Condition  Simulate Both Open and Close Fail to close or Fail to open Alarm shall raise after Delay feedbacks inactive  Fail to close or Fail to open Alarm shall raise after Delay

19323 - Oxley Flood Recovery Zone 3

Page 11 of 24



# 2.7 Heat Exchanger 2 Auto Flush Drain Valve FCV-626-24

Pre-condition	Action	Response	PLC Check	SCADA Check	Client	Comment
Device Available	Simulate a Fault	Device Unavailable	/	~	CHICOR	
In Remote Manual Mode, No Fault Condition	Manual Open Command	Valve Opened	/	V		
In Remote Manual Mode, No Fault Condition	Manual Close Command	Valve Closed	/	1		
In Remote Manual Mode, No Fault Condition Set fail 2 Open Timer (10s)	Manual Open Command Open Feedback Inactive	Failed to Open Alarm after delay time	1	/		
In Remote Manual Mode, No Fault Condition	Manual Close Command Close Feedback Inactive	Failed to Close Alarm after delay time	1	V		
No Fault Condition	Simulate Both Open and Close feedbacks inactive	Fail to close or Fail to open Alarm shall raise after Delay time	V	/		
No Fault Condition	Simulate Both Open and Close feedbacks active	Fail to close or Fail to open Alarm shall raise after Delay time	/	/		Valve Control Standard Function needs to be modified
	Device Available  In Remote Manual Mode, No Fault Condition  et fail 2 Open Timer (10s)  In Remote Manual Mode, No Fault Condition Set fail 2 Open Timer (10s)  No Fault Condition	Device Available  In Remote Manual Mode, No Fault Condition  et fail 2 Open Timer (10s)  In Remote Manual Mode, No Fault Condition Set fail 2 Open Timer (10s)  In Remote Manual Mode, No Fault Condition Set fail 2 Open Timer (10s)  No Fault Condition  Simulate Both Open and Close feedbacks inactive  Simulate Both Open and Close Simulate Both Open and Close	Device Available  In Remote Manual Mode, No Fault Condition  Set fail 2 Open Timer (10s)  In Remote Manual Mode, No Fault Condition  Set fail 2 Open Timer (10s)  In Remote Manual Mode, No Fault Condition  Set fail 2 Open Timer (10s)  In Remote Manual Mode, No Fault Condition  Set fail 2 Open Timer (10s)  Failed to Close Alarm after delay time  Failed to Close Alarm after delay time  Fail to close or Fail to open Alarm shall raise after Delay time  No Fault Condition  Simulate Both Open and Close  Fail to close or Fail to open Alarm shall raise after Delay  Fail to close or Fail to open Alarm shall raise after Delay	Device Available  In Remote Manual Mode, No Fault Condition  Set fail 2 Open Timer (10s)  In Remote Manual Mode, No Fault Condition  Set fail 2 Open Timer (10s)  In Remote Manual Mode, No Fault Condition  Set fail 2 Open Timer (10s)  In Remote Manual Mode, No Fault Condition  Set fail 2 Open Timer (10s)  Manual Close Command Close Feedback Inactive  Failed to Close Alarm after delay time  Failed to Close Alarm after delay time  Failed to Close Alarm shall raise after Delay time  No Fault Condition  Simulate Both Open and Close Feedback inactive  No Fault Condition  Simulate Both Open and Close  Fail to close or Fail to open Alarm shall raise after Delay  Fail to close or Fail to open Alarm shall raise after Delay  Fail to close or Fail to open Alarm shall raise after Delay  Fail to close or Fail to open Alarm shall raise after Delay  Fail to close or Fail to open Alarm shall raise after Delay	Device Available  In Remote Manual Mode, No Fault Condition  Set fail 2 Open Timer (10s)  In Remote Manual Mode, No Fault Condition  Set fail 2 Open Timer (10s)  Manual Close Command Close Feedback Inactive  Manual Close Command Close Feedback Inactive  Manual Close Command Close Failed to Close Alarm after delay time  Failed to Close Alarm after delay time  No Fault Condition  Simulate Both Open and Close feedbacks inactive  No Fault Condition  Simulate Both Open and Close  Fail to close or Fail to open Alarm shall raise after Delay time  No Fault Condition  Simulate Both Open and Close  Fail to close or Fail to open Alarm shall raise after Delay  Fail to close or Fail to open Alarm shall raise after Delay  Fail to close or Fail to open Alarm shall raise after Delay	Device Available  In Remote Manual Mode, No Fault Condition  Set fail 2 Open Timer (10s)  In Remote Manual Mode, No Fault Condition  Set fail 2 Open Timer (10s)  Manual Close Command Open Feedback Inactive  Manual Close Command Close Feedback Inactive  Manual Close Command Failed to Open Alarm after delay time  Failed to Close Alarm after delay time  Fail to close or Fail to open Alarm shall raise after Delay time  No Fault Condition  Simulate Both Open and Close Fail to open Alarm shall raise after Delay  Simulate Both Open and Close Fail to close or Fail to open Alarm shall raise after Delay  Fail to close or Fail to open Alarm shall raise after Delay  Fail to close or Fail to open Alarm shall raise after Delay  Fail to close or Fail to open Alarm shall raise after Delay  Fail to close or Fail to open Alarm shall raise after Delay

Note:

19323 - Oxley Flood Recovery Zone 3

Page 12 of 24



# 2.8 Heat Exchanger 2 Service Water Auto Flush Inlet Valve FCV-626-94

Pre-condition	Action	Response	PLC Check	SCADA Check	Client Check	Comment
Device Available	Simulate a Fault	Device Unavailable	/	/		
In Remote Manual Mode, No Fault Condition	Manual Open Command	Valve Opened		V		
In Remote Manual Mode, No Fault Condition	Manual Close Command	Valve Closed	V	/		
In Remote Manual Mode, No Fault Condition Set fail 2 Open Timer (10s)	Manual Open Command Open Feedback Inactive	Failed to Open Alarm after delay time	~	/		
In Remote Manual Mode, No Fault Condition Set fail 2 Open Timer (10s)	Manual Close Command Close Feedback Inactive	Failed to Close Alarm after delay time	V	~	İ	
No Fault Condition	Simulate Both Open and Close feedbacks inactive	Fail to close or Fail to open Alarm shall raise after Delay time	~	~		
No Fault Condition	Simulate Both Open and Close feedbacks active	Fail to close or Fail to open Alarm shall raise after Delay time	/	/		Valve Control Standard Function needs to be modified
	Device Available  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition Set fail 2 Open Timer (10s)  In Remote Manual Mode, No Fault Condition Set fail 2 Open Timer (10s)  No Fault Condition	Device Available  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  Set fail 2 Open Timer (10s)  In Remote Manual Mode, No Fault Condition  Set fail 2 Open Timer (10s)  No Fault Condition  No Fault Condition  Simulate a Fault  Manual Open Command Open Feedback Inactive  Manual Close Command Close Feedback Inactive  Simulate Both Open and Close feedbacks inactive  Simulate Both Open and Close	Device Available  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  Set fail 2 Open Timer (10s)  In Remote Manual Mode, No Fault Condition  Set fail 2 Open Timer (10s)  In Remote Manual Mode, No Fault Condition  Set fail 2 Open Timer (10s)  In Remote Manual Mode, No Fault Condition  Set fail 2 Open Timer (10s)  No Fault Condition  Simulate Both Open and Close feedbacks inactive  No Fault Condition  Simulate Both Open and Close  Fail to close or Fail to open Alarm shall raise after Delay time  Fail to close or Fail to open Alarm shall raise after Delay  Fail to close or Fail to open Alarm shall raise after Delay	Device Available  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  Set fail 2 Open Timer (10s)  In Remote Manual Mode, No Fault Condition  Set fail 2 Open Timer (10s)  In Remote Manual Mode, No Fault Condition  Set fail 2 Open Timer (10s)  Manual Close Command Close Feedback Inactive  Failed to Close Alarm after delay time  Failed to Close Alarm after delay time  Failed to Close or Fail to open Alarm shall raise after Delay time  No Fault Condition  Simulate Both Open and Close  Fail to close or Fail to open Alarm shall raise after Delay  Fail to close or Fail to open Alarm shall raise after Delay  Simulate Both Open and Close  Fail to close or Fail to open Alarm shall raise after Delay  Fail to close or Fail to open Alarm shall raise after Delay	Device Available  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  Set fail 2 Open Timer (10s)  In Remote Manual Mode, No Fault Condition  Set fail 2 Open Timer (10s)  Manual Close Command Close Feedback Inactive  Manual Close Command Close Feedback Inactive  Failed to Close Alarm after delay time  Failed to Close Alarm after delay time  No Fault Condition  Simulate Both Open and Close feedbacks inactive  No Fault Condition  Simulate Both Open and Close  Fail to close or Fail to open Alarm shall raise after Delay time  No Fault Condition  Simulate Both Open and Close  Fail to close or Fail to open Alarm shall raise after Delay  Fail to close or Fail to open Alarm shall raise after Delay  Fail to close or Fail to open Alarm shall raise after Delay	Device Available  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  In Remote Manual Mode, No Fault Condition  Set fail 2 Open Timer (10s)  In Remote Manual Mode, No Fault Condition  Set fail 2 Open Timer (10s)  Manual Close Command Open Feedback Inactive  Manual Close Command Close Feedback Inactive  Manual Close Command Failed to Open Alarm after delay time  Failed to Close Alarm after delay time  No Fault Condition  Simulate Both Open and Close Feedback Inactive  Simulate Both Open and Close Fail to open Alarm shall raise after Delay time  Fail to close or Fail to open Alarm shall raise after Delay  Simulate Both Open and Close  Fail to close or Fail to open Alarm shall raise after Delay  Fail to close or Fail to open Alarm shall raise after Delay  Fail to close or Fail to open Alarm shall raise after Delay  Fail to close or Fail to open Alarm shall raise after Delay  Fail to close or Fail to open Alarm shall raise after Delay  Fail to close or Fail to open Alarm shall raise after Delay

Note:

19323 - Oxley Flood Recovery Zone 3

Page 13 of 24



#### 2.9 Automatic Control

The purpose of this section is to verify that correct function is given by all equipment in accordance with the control philosophy. It involves testing/running the equipment in Automatic Mode.

### 2.9.1 Heat Exchanger 1 Normal Operation

No.	Pre-condition	Action	Response	PLC Check	SCADA Check	Client Check	Comment
1	- All associated devices are available in Remote Auto: FCV62613 FCV62614 FCV62690 FCV62604 - The Inlet Hand Valve set to Open - The associated Instruments are available: TT62601 TT62604 - The Auto Flush Valves in closed position	-	Heat Exchanger Available	CHECK	U PECK	CHECK	
2	Heat Exchanger Available	- Set Heat Exchanger Online	- Heat Exchanger Online - Sludge Outlet Valve Shall be opened	V	/		
3	Heat Exchanger is Online	- Set Heat Exchanger Offline	- Sludge Outlet Valve Shall be Closed	V	/		
4	Heat Exchanger is Online	Simulate one of following items: - FCV62613 in Manual or Faulty - FCV62614 in Manual or Faulty - FCV62690 in Manual or Faulty - FCV62604 in Manual or Faulty - The Inlet Hand Valve set to closed - TT62601 Faulty - TT62604 Faulty - FCV62614 Open - FCV62690 Open	- Heat Exchanger Offline - Heat Exchanger Unavailable		/		



19323 - Oxley Flood Recovery Zone 3

Page 14 of 24



No.	Pre-condition	Action	Response	PLC Check	SCADA Check	Client	Comment
5	- Heat Exchanger Unavailable	-Set Heat Exchanger Online	- Heat Exchanger Offline	1	CHECK	CHECK	
6	- Heat Exchanger Online - TT62601 not in High Level - TT62604 not in High Level - At least one of the digester inlet control valves is open - FCV62613 is open		- Digester feed pump 1 Interlock is healthy - Digester feed pump 2 Interlock is healthy	~	~		
7	- Digester feed pump 1 Interlock is healthy - Digester feed pump 2 Interlock is healthy	Simulate one of following items: - Heat Exchanger Offline - TT62601 High Level Alarm - TT62604 High Level Alarm - Close all the digester inlet control valves - Close FCV62613	- Digester feed pump 1 Interlock is not healthy - Digester feed pump 2 Interlock is not healthy	~			TTGZEOG HIGH HIGH TO ACTIVATE PUMP INTERLECK. JB 30/5/12
8	- Heat Exchanger Online - Feed Pump 1 or 2 Interlock is Healthy - Pump 1 or 2 is Running	- Simulate the Sludge Outlet Temperature (Process Variable) higher than Setpoint	- Heat Exchanger Cooling Water Flow Control Valve Shall attempt to touch the setpoint	/	1		
9							
10							
11							
12							
13							
14							
15							
Note							

19323 - Oxley Flood Recovery Zone 3

Page 15 of 24





# 2.9.2 Heat Exchanger 2 Normal Operation

No.	Pre-condition	Action	Response	PLC Check	SCADA Check	Client Check	Comment
1	- All associated devices are available in Remote Auto: FCV62623 FCV62624 FCV62694 FCV62606 - The Inlet Hand Valve set to Open - The associated Instruments are available: TT62602 TT62606 - The Auto Flush Valves in closed position	-	Heat Exchanger Available	Check	Check	шеск	
2	Heat Exchanger Available	- Set Heat Exchanger Online	- Heat Exchanger Online - Sludge Outlet Valve Shall be opened	V	/		
3	Heat Exchanger is Online	- Set Heat Exchanger Offline	- Sludge Outlet Valve Shall be Closed	/	/		
4	Heat Exchanger is Online	Simulate one of following items: - FCV62623 in Manual or Faulty - FCV62624 in Manual or Faulty - FCV62694 in Manual or Faulty - FCV62606 in Manual or Faulty - The Inlet Hand Valve set to closed - TT62602 Faulty - TT62606 Faulty - FCV62624 Open - FCV62694 Open	- Heat Exchanger Offline - Heat Exchanger Unavailable		/		
5	- Heat Exchanger Unavailable	-Set Heat Exchanger Online	- Heat Exchanger Offline	V	~		
6	- Heat Exchanger Online - TT62602 not in High Level - TT62606 not in High Level - At least one of the digester inlet control valves is open - FCV62623 is open		- Digester feed pump 2 Interlock is healthy - Digester feed pump 3 Interlock is healthy	V	/		

茶

19323 - Oxley Flood Recovery Zone 3

Page 16 of 24





No.	Pre-condition	Action	Response	PLC	SCADA	Client	Comment
7	- Digester feed pump 2 Interlock is healthy - Digester feed pump 3 Interlock is healthy - Digester feed pump 3 Interlock is healthy - TT62602 High Level Alarm - TT62606 High Level Alarm - Close all the digester inlet or		- Digester feed pump 2 Interlock is not healthy - Digester feed pump 3 Interlock is not healthy	Check	Check	Check	SAME AS SECT 2.9.1 LINE ITEM 7. 16 30/5/19
8	- Heat Exchanger Online - Feed Pump 2 or 3 Interlock is Healthy - Pump 2 or 3 is Running	- Simulate the Sludge Outlet Temperature (Process Variable) higher than Setpoint	- Heat Exchanger Cooling Water Flow Control Valve Shall attempt to touch the setpoint	1			
9							
10							
11							
12							
13							
14							
15							
Note							

19323 - Oxley Flood Recovery Zone 3

Page 17 of 24



### 2.9.3 Heat Exchanger 1 Flush Control

No.	Pre-condition	Action	Response	PLC Check	SCADA Check	Client	Comment
1	- All associated devices are available in Remote Auto: FCV62613 FCV62614 FCV62690 FCV62604 - Heat Exchanger Offline		Heat Exchanger Flush Available	Crieda	Crieck	Uleck	
2	- Heat Exchanger Flush Available	- Set Heat Exchanger Flush to Manual Mode - Set Flush Time Setpoint to 1 Min - Start Flush Sequence Manually	- Flush Sequence Starts and goes to step 1	V	/		
3	- Flush Sequence in Step 1	Simulate Digester Pump Permissive: - Digester Feed Pump 1 not Running - Digester Feed Pump 2 not Running - FCV62523 is Closed — - FCV62533 is Closed —	- Flush Sequence goes to Step 2	V	V		
4	- Flush Sequence in Step 2	- Sim Digester Outlet Valve Closed	- Flush Sequence goes to Step 3	1			
5	- Flush Sequence in Step 3	- Sim Flush Drain Valve Opened ,	- Flush Sequence goes to Step 4	~	~		
6	- Flush Sequence goes to Step 4	- Sim Flush Inlet Valve Opened	- Flush Sequence goes to Step 5	/	/		
7	- Flush Sequence goes to Step 5	- Wait for 1 Min (Flush Time Setpoint)	- Flush Sequence goes to Step 6	1	~		
8	- Flush Sequence goes to Step 6	- Sim Flush Inlet Valve Closed	- Flush Sequence goes to Step 7	V	/		
9	- Flush Sequence goes to Step 7	- Sim Flush Drain Valve Closed	- Flush Sequence goes to Step 8	V	/		
10	- Flush Sequence goes to Step 8		- Flush Sequence Completed	L	/		
11	- Heat Exchanger Online - Heat Exchanger Flush Available - Heat Exchanger Flush On Remote/Auto Mode	- Set the Heat Exchanger to Offline Mode	- Flush Sequence Starts and goes to step 1	/	/		

19323 - Oxley Flood Recovery Zone 3

Page 18 of 24



No.	Pre-condition	Action	Response	PLC	SCADA	Client	Comment
12	- Flush Sequence in Step 1	Simulate Digester Pump Permissive: - Digester Feed Pump 1 not Running - Digester Feed Pump 2 not Running - FCV62523 is Closed - FCV62533 is Closed	- Flush Sequence goes to Step 2	Check	Check	Check	Comment
13	- Flush Sequence in Step 2	- Sim Digester Outlet Valve Closed	- Flush Sequence goes to Step 3	V	1		
14	- Flush Sequence in Step 3	- Sim Flush Drain Valve Opened	- Flush Sequence goes to Step 4	V	V		
15	- Flush Sequence goes to Step 4	- Sim Flush Inlet Valve Opened	- Flush Sequence goes to Step 5	V	V		
16	- Flush Sequence goes to Step 5	- Wait for 1 Min (Flush Time Setpoint)	- Flush Sequence goes to Step 6	V	/		
17	- Flush Sequence goes to Step 6	- Sim Flush Inlet Valve Closed	- Flush Sequence goes to Step 7	V	V		
18	- Flush Sequence goes to Step 7	- Sim Flush Drain Valve Closed	- Flush Sequence goes to Step 8	V	V		
19	- Flush Sequence goes to Step 8		- Flush Sequence Completed	1	/		
20							
21							
22							
23							
24		No. 7 Property					
25							
26							
Note							

19323 - Oxley Flood Recovery Zone 3

Page 19 of 24



### 2.9.4 Heat Exchanger 2 Flush Control

No.	Pre-condition	Action	Response	PLC Check	SCADA Check	Client	Comment
1	- All associated devices are available in Remote Auto: FCV62613 FCV62614 FCV62690 FCV62604 - Heat Exchanger Offline		Heat Exchanger Flush Available	Check		Check	
2	- Heat Exchanger Flush Available	- Set Heat Exchanger Flush to Manual Mode - Set Flush Time Setpoint to 1 Min - Start Flush Sequence Manually	- Flush Sequence Starts and goes to step 1	V	V		
3	- Flush Sequence in Step 1	Simulate Digester Pump Permissive: - Digester Feed Pump 1 not Running - Digester Feed Pump 2 not Running - FCV62523 is Closed - FCV62533 is Closed	ly ssive:		/		
4	- Flush Sequence in Step 2	- Sim Digester Outlet Valve Closed	- Flush Sequence goes to Step 3	V	~		
5	- Flush Sequence in Step 3	- Sim Flush Drain Valve Opened	- Flush Sequence goes to Step 4	V	V	THE	
6	- Flush Sequence goes to Step 4	- Sim Flush Inlet Valve Opened	- Flush Sequence goes to Step 5	V	1		
7	- Flush Sequence goes to Step 5	- Wait for 1 Min (Flush Time Setpoint)	- Flush Sequence goes to Step 6	V	1		
8	- Flush Sequence goes to Step 6	- Sim Flush Inlet Valve Closed	- Flush Sequence goes to Step 7	V	/		
9	- Flush Sequence goes to Step 7	- Sim Flush Drain Valve Closed	- Flush Sequence goes to Step 8		1		
10	- Flush Sequence goes to Step 8		- Flush Sequence Completed	V	V		
11	- Heat Exchanger Online - Heat Exchanger Flush Available - Heat Exchanger Flush On Remote/Auto Mode	- Set the Heat Exchanger to Offline Mode	- Flush Sequence Starts and goes to step 1	~			

19323 - Oxley Flood Recovery Zone 3

Page 20 of 24







No.	Pre-condition	Action	Response	PLC Check	SCADA Check	Client Check	Comment
12	- Flush Sequence in Step 1	Simulate Digester Pump Permissive: - Digester Feed Pump 1 not Running - Digester Feed Pump 2 not Running - FCV62523 is Closed - FCV62533 is Closed	- Flush Sequence goes to Step 2	<u> </u>	Creck	Uneck	
13	- Flush Sequence in Step 2	- Sim Digester Outlet Valve Closed	- Flush Sequence goes to Step 3	1	/		
14	- Flush Sequence in Step 3	- Sim Flush Drain Valve Opened	- Flush Sequence goes to Step 4		/		
15	- Flush Sequence goes to Step 4	- Sim Flush Inlet Valve Opened	- Flush Sequence goes to Step 5	V		7 7	
16	- Flush Sequence goes to Step 5	- Wait for 1 Min (Flush Time Setpoint)	- Flush Sequence goes to Step 6	V	~		
17	- Flush Sequence goes to Step 6	- Sim Flush Inlet Valve Closed	- Flush Sequence goes to Step 7		/		
18	- Flush Sequence goes to Step 7	- Sim Flush Drain Valve Closed	- Flush Sequence goes to Step 8	V	V		
19	- Flush Sequence goes to Step 8		- Flush Sequence Completed	V	/		
20							
21							
22							
23							
24							
25							
26							

19323 - Oxley Flood Recovery Zone 3

Page 21 of 24



### 2.9.5 SCADA Alarms

No.	Description	SCADA Tag	PLC Check	SCADA Check	Client   Check	Comment
1	Heat Exchanger 1 Sludge Outlet Auto Valve Fail to Close	ST022HYD01FCV62613dsF2Close	1/	-	O I CCK	
2	Heat Exchanger 1 Sludge Outlet Auto Valve Fail to Open	ST022HYD01FCV62613dsF2Open	V	/		
3	Heat Exchanger 1 Auto Flush Drain Valve Fail to Close	ST022HYD01FCV62614dsF2Close	1	V		
4	Heat Exchanger 1 Auto Flush Drain Valve Fail to Open	ST022HYD01FCV62614dsF2Open		V		
5	Heat Exchanger 2 Sludge Outlet Auto Valve Fail to Close	ST022HYD01FCV62623dsF2Close	V	/		
6	Heat Exchanger 2 Sludge Outlet Auto Valve Fail to Open	ST022HYD01FCV62623dsF2Open	/	/		
7	Heat Exchanger 2 Auto Flush Drain Valve Fail to Close	ST022HYD01FCV62624dsF2Close				
8	Heat Exchanger 2 Auto Flush Drain Valve Fail to Open	ST022HYD01FCV62624dsF2Open	V	~		
9	Heat Exchanger 1 SW Auto Flush Inlet Valve Fail to Close	ST022HYD01FCV62690dsF2Close				
10	Heat Exchanger 1 SW Auto Flush Inlet Valve Fail to Open	ST022HYD01FCV62690dsF2Open	1	/		
11	Heat Exchanger 2 SW Auto Flush Inlet Valve Fail to Close	ST022HYD01FCV62694dsF2Close	V	~		
12	Heat Exchanger 2 SW Auto Flush Inlet Valve Fail to Open	ST022HYD01FCV62694dsF2Open		/		
13						
14						
15						
Note:				/	1	

\* TO INCLUDE AUTOFLUSH SEQUENCE TIME EXCEEDED ALARM. JB 30/5/12:

19323 - Oxley Flood Recovery Zone 3

Page 22 of 24



### 2.9.6 SCADA Trends

SCADA Tag	PLC Check	SCADA Check	Client	Comment
	- Circuit	Criccit	SHOOK	
	SCADA Tag	SCADA Tag PLC Check	SCADA Tag PLC SCADA Check Check	SCADA Tag  PLC Check Check Check Check Check

19323 – Oxley Flood Recovery Zone 3

Heat Exchanger Modification - Factory Acceptance Testing - Procedure and Results Rev 0.0

Copyright © MPA Engineering Pty Ltd. All Rights Reserved.

Page 23 of 24



# 3. TEST COMPLETION ACCEPTANCE

NAME	POSITION	COMPANY	SIGNATURE	DATE
JANE BEECHER	COMMISSIONING ENGINEER	JHG	Tour Boscher	30/5/12
Scott ADMS	CONTROL SISTEMS	Que	Ster	31-5-12

19323 - Oxley Flood Recovery Zone 3

Page 24 of 24

### 2.2.5. SAT Checksheets

### ALARM, TRIP AND SETTINGS LIST Doc.no.1035-PRG-003, rev.D04 Thermal hydrolysis plant

P&ID	Loop number	Description	1 "	Adjustable	Set point	Unit	Action	SAT
				range				Date/sign.
General	N/A	Time delay for pump discharge alarms	Timer	0-60		sec.	Delays monitoring on pump discharges after starting pump.	24/10/3
General	N/A	Time delay for rupture disk alarm	Timer	No	8	hours	allows THP operation for 8 hours after reset of rupture disk alarm. Not possible to reset during count down.	19/0/3
486/5/5-R7W101	LS-625002	Level switch in pulper	High high	N/A	N/A		Stop pulper feed system, close dilution water system, stop flashing from reactors, stop reactor blowdown, stop circulation pumps, stop THP, stop foul gas system.	13/10/3
	LIT-625001	1 Level transmitter in pulper	High	50-100	65	%	Close dilution water system, prevent flashing from reactor and reactor blowdown.	24/10/2
			High fill	50-100		%	Stop pulper feed.	
1			Set point	25-75		%	Control set point for speed of pulper feed.	10
			Low fill	0-50	.40	%	Prevent start of reactor fill.	BY 13/6
			Low	0-50	30	%	Stop reactor fill, prevent flashing from reactors and reactor blowdown.	BA 13/6
			Low low	0-50	20	%	Stop circulation pumps and pulper feed, stop flashing from reactors and reactor blowdown, stop circulation pumps, close dilution water control valve.	24/10/5
	PIT-625006	Pulper pressure	High high	0-3	3	barg	Stop THP.	X8/10/3
	High 0-3 2 barg High pres				High pressure. Stop foul gas compressor, start standby.	24/10 AM		
			Set point	0-2	0.1	barg	Control set point for foul gas ejector water pump.	BX 15/10
			Low	-0.2-0	-0.05	barg	Low pressure.	24/10/3
	,		Low low	-0.2-0	-0.1	barg	Stop reactor feed pump and foul gas compressors, vacuum in pulper. DO NOT start standby equipment. Stop THP.	20/0/3
	PIT-625008	Circulation pump 01 discharge pressure	High high	0-10	4	barg	Stop duty and start standby circulation pump.	23/10/3
	PIT-625009	Circulation pump 02 discharge pressure	High	0-8	3	barg	High pressure.	17/10 AM
	111 02000		Set point	0-5	2	barg	Control set point for speed of circulation pumps or the flow of dilution water.	25/10/3
			Low	0-5	1	barg	Low pressure.	23/10/3
		·	Low low	0-5		barg	Stop duty and start standby circulation pump.	23/6/3
	PIT-625007	Reactor feed pumps discharge pressure		0-20		barg	Shut down pump without delay. Start standby pump.	33/h/3
	111-020001	Todata loog kampo albana. 35 kilongala	High high	0-15		barg	Shut down pump. Start standby pump.	23/10/3
			High	0-15		barg	High pressure.	23/10/3
			Low	0-5	-	barg	Low pressure.	23/10/3
			Low low	0-5		barg	Shut down pump. Start standby pump.	23/10/3
	FIT-625005	Dilution water upstream pulper circulation	High	0-10	7	m3/h	High flow alarm only when flow is required.	25/10/5
	1, 11-02-0000	pumps	Low	0-10	0.	m3/h	Low flow alarm only when flow is required.	117/12/3

### ALARM, TRIP AND SETTINGS LIST Doc.no.1035-PRG-003, rev.D04 Thermal hydrolysis plant

P&ID	Loop number	Description	Туре	Adjustable	Set point	Unit	Action	SAT
1 0.15				range				Date/sign.
			Zero	0-1	0.1	m3/h	Zero flow when flow is required, start standby circulation pump.	17/10/B
			Not zero	0-1	0.1	m3/h	Flow not zero alarm only when flow is not required (leaking valve).	25/0/3
			Reverse	-1-0	-0.1	m3/h	Stop circulation system. Start standby.	15/10/5
			Mode	See below	Pressure	Var.	Type of dilution water control.	25/10/3,
			Position	0-100		%	Set point when position controlled.	23/10/3
			Flow	0-10	0	m3/h	Set point when flow controlled.	25/10/3
			Pressure	0-5	2	barg	Set point when pressure controlled.	25/10/3
	TIT-625003 TIT-625004	Circulation pump 01 discharge temperature Circulation pump 02 discharge temperature	High	0-150	110	°C	Prevent/stop flashing from reactors, continue flashing when condition has cleared. Prevent blowdown, but continue blowdown if high temperature is reached during blowdown time	25/10
								1 /4// 1
	FCV-625019 FCV-625020	Reactor feed pump 01 discharge valve Reactor feed pump 02 discharge valve	Not opened	0-60	30	sec.	Valve failed to open within the set time. Make equipment unavailable.	25/10 NOK
			Not closed	0-60	_	sec.	Valve failed to close within the set time. Make equipment unavailable.	25/10 AM
	FCV-625008	Dilution water control valve	Opening time	0-600		sec.	Dilution water control valve opening time (0-100%)	23/10/3
			Closing time	0-600		sec.	Dilution water control valve closing time (0-100%)	25/10/5
	FCV-625031 FCV-625032	Seal water	Timer	0-60	10	sec.		24/10/13
	PU-625001 PU-625002	Circulation pump 01 Circulation pump 02	Set speed	0-100	100	%	Sets pump speed.	884 1%o
	PU-625003 PU-625004	Reactor feed pump 01 Reactor feed pump 02	Set speed	0-100	100	%	Sets reactor feed pump speed.	88x 12%
	RD-625036	Rupture disk on pulper	Fault	N/A	N/A		Makes pulper unavailable.	AM 20/10
	Time monitoring	Reactor sludge filling time	Timer	15-30	20	min.	Long filling time.	BX "No
486/5/5-R7W102 to 486/5/5-R7W104	PIT-625105	Steam pressure from boiler	Low low	4-8	5	barg	Close steam filling valves until pressure is above low. Then resume operation.	BX136
		Steam pressure from boiler	Low	6-10	6	barg	Prevent opening of steam filling valves.	26/10/B
		Pressure difference between main steam pressure and reactor pressure.	Low	0-2	0.5	barg	Close relevant steam injection valve. Resume operation when pressure is above pressure difference + deadband (below).	12/10/3
		Dead band on pressure difference	Set	0-2	0.5	barg		36/10/03
	PIT-625101 √	Reactor pressure	High high	10-15		barg	Close steam filling valve, make reactor unavailable.	15/10/15
	PIT-625201	•	High	5-15	10	barg	High pressure.	16/10/35
	PIT-625301 <b>√</b>		Retention pressure	4-8	(	barg	Control set point for steam filling valves.	12/10/3

| V

20.09.2006

Q-Pulse Id: TMS217

### ALARM, TRIP AND SETTINGS LIST Doc.no.1035-PRG-003, rev.D04 Thermal hydrolysis plant

P&ID	Loop number	Description	Туре	Adjustable	Set point	Unit	Action	SAT
				range				Date/sign.
			Flash pressure	1-4	2	barg	Set point for closing flashing valves.	B841/10
			Low	3-8	5	barg	Only during retention time, alarm low pressure if pressure is below set point.	20/10/3
			Low low	-1-0	-0.1	barg	Stop emptying reactor (close blowdown valve), reset reactor cycle. Make reactor unavailable.	10/3
			Increase	0-60	20	min.	Long steam filling time, blocked steam injection system.	26/10/15
			Decrease	0-60	25	min.	Long pressure reduction time, blocked flash steam system.	26/10 AM
			% of pressure start timer	75-100	95	%	Set % point of required hydrolysis pressure, i.e. retention time starts.	881.1/2°
	LS-625102 <b>V</b> LS-625202 √ LS-625302 <b>√</b>	Reactor level	High high	N/A	N/A		Stop reactor filling (both sludge and steam), make reactor unavailable.	9/10/3
	LS-625103 V LS-625203 V LS-625303 V	Reactor level	High fill	N/A	N/A		Stop reactor sludge filling, no alarm. Proceede to next cycle step if allowed by the control system.	12/10/3
	FCV-625101 <b>√</b> FCV-625201 <b>√</b>	Reactor sludge filling valve	Not opened	0-60	30	sec.	Valve failed to open within the set time. Make reactor unavailable.	15/0 M
	FCV-625301 <b>V</b>		Not closed	0-60	30	sec.	Valve failed to close within the set time. Make reactor unavailable.	25/10 AM
	FCV-625102 <b>v</b>	Reactor steam filling valves	Not closed	0-60	30	sec.	Valve failed to close. Make reactor unavailable.	25/10 MM
	FCV-625202 <b>V</b>	Reactor steam ming valves	Max open	0-100		%	Maximum open position on valve.	25/10 MM
	FCV-625302 V		Min open	0-100		%	Minimum open position on valve.	12×12/16
			Opening time	0-600		sec.	0-100% opening time	13/12/10
			Closing time	0-600		sec.	0-100% closing time	CX 12/1
	FCV-625104 v	Reactor flash steam valves	Not closed	0-60	30	sec.	Valve failed to close. Make reactor unavailable.	25/10 AVM
	FCV-625204 V	readior hash steam valves	Max open	0-100	80	) %	Maximum open position on valve.	BA 12/10
	FCV-625304 <b>V</b>		Min open	0-100	20	) %	Minimum open position on valve.	(\$A12/10
	10002000		Opening time	0-600	60	sec.	0-100% opening time	24 12/10
			Closing time	0-600	10	sec.	0-100% closing time	12/12/10
	FCV-625103 <b>V</b> FCV-625203 <b>V</b>	Reactor blowdown valve	Not opened	0-60	30	sec.	Valve failed to open within the set time. Close valve and make reactor unavailable.	26/10/3
	FCV-625303 V		Not closed	0-60	30	sec.	Valve failed to close within the set time. Make reactor unavailable.	26/10/3

20.09.2006 Q-Pulse ld: TMS217

### ALARM, TRIP AND SETTINGS LIST Doc.no.1035-PRG-003, rev.D04 Thermal hydrolysis plant

P&ID	Loop number	Description	Туре	Adjustable range	Set point	Unit	Action	SAT Date/sign.
			Blowdown time		5	min.	Time for blowdown valve to remain open during emptying of reactor.	3/10/3
	FCV-625102	Reactor steam filling valves during shot of	Opening time	0-600	0	sec.	0-100% opening time	RA 12/16
	FCV-625202	steam	Closing time	0-600	0	sec.	0-100% closing time	PSA 12/18
	FCV-625302		Open time	0-600	0	sec.	The opening time during shot of steam before blowdown	13/0
			Open position	0-100	0	%	The opening % during shot of steam before blowdown	BA 12/16
	PIT-625101 PIT-625201 PIT-625301	Reactor pressure increase after shot of steam	Increase	0-1	0,3	barg	Repeat flashdown if pressure has increased set value above flashdown pressure.	8412/13
	RD-625118 RD-625214 RD-625314	Rupture disk on reactor	Fault	N/A	N/A		Makes reactor unavailable.	M 20/10 AM 20/10 AM 20/10
	Time monitoring	Retention time	Timer	15-45	30	min.	Reactor retention timer.	13/1A B
		Delay to start a new cycle	Timer	0-100	0	min.	Time delay between between the end of a cycle (confirmed closed blowdown valve) and a start of a new cycle.	13/10/3
486/5/5-R7W105	LS-625401	Level switch in flashtank	High high high	N/A	N/A		High high level (level switch), close all blowdown valves, close dilution water system, foul gas condensate and stop water flow from compressed foul gas drum. Stop digester feed pumps.	24/10/2
1	LIT-625402	Level transmitter in flashtank	High high	50-100	80	%	High high level, stop digester feed pumps.	24/10/3
	211 323 132		High	50-100		%	High level, prevent opening of blowdown valves, close dilution water system, foul gas condensate and stop water flow from compressed foul gas drum.	13/10/2
	ł	i	High fill	25-75	50	%	Prevent start of new reactor cycle.	13/10/3
			Low fill	0-50	40	%	Prevent start of digester feed pumps.	13/10/0
			Low	0-50		%	Stop digester feed pumps. Restart when above low fill level.	13/10/3
1			Low low	0-50	10	%	Stop digester feed pumps.	13/10/3
	PIT-625404	Flashtank pressure	High high	0-3	2.5	barg	Close blowdown valves, stop THP.	20/10/3
			High	0-3	2	barg	High pressure.	20/10/3
,			Low low	-0.2-0	-0.1	barg	Vacuum in flashtank, stop digester feed pumps. Make flashtan unavailable.	10/3
	1	Time delay for high pressure	Timer	0-30	10	min.	Warning of blockage of flash steam line (high pressure).	ab/10/3
	PIT-625405 PIT-625413	Digester feed pumps discharge pressure	High high high	0-20	12	barg	Shut down digester feed system without delay. Start standby system.	24/10/3
			High high	0-15	10	barg	Shut down digester feed system. Start standby system.	24/10/3
1	1		High	0-15	1 5	barg	High pressure.	24/0/3

20.09.2006

Q-Pulse Id: TMS217 05/03/2013 193 of 661

### ALARM, TRIP AND SETTINGS LIST Doc.no.1035-PRG-003, rev.D04 Thermal hydrolysis plant

P&ID	Loop number	Description	Туре	Adjustable	Set point	Unit	Action	SAT Date/sign.
				range	1 4	<u> </u>	I	14/10/35
			Low	0-5			Low pressure.	
			Low low	0-5		barg	Shut down pump. Start standby system.	24/10/3
	PIT-625410	Final effluent water pressure	High high	0-10		barg	Suspend THP until pressure is below high.	26/0/2
			High	0-8		barg	High pressure, prevent start of THP.	10/2
			Low	0-5		barg	Low pressure, prevent start of THP.	26/0/3
			Low low	0-5		barg	Suspend THP until pressure is above low.	26/10/3
	FIT-625407	Dilution water upstream digester feed pumps	High	0-10			High flow alarm only when flow is higher than required.	24/6/3
			Low	0-10	1	m3/h	Low flow alarm only when flow is lower than required.	24/10/5
			Zero	0-1	0.1	m3/h	Zero flow when flow is required, stop associated digester feed pump system and start standby.	26/10/3
			Not zero	0-1	0.1	m3/h	Flow not zero alarm only when flow is not required (leaking valve).	26/10/3
			Reverse	-1-0	-0.1	m3/h	Stop digester feed system. Start standby.	10/0/3
			Mode	See below	% of flow	Var.	Type of dilution water control.	24/10/5
			Position	0-100	0	%	Set point when position controlled.	24/10/25
	·		Flow	0-30	0	m3/h	Set point when flow controlled.	24/10/3
			% of flow	0-100	20	%	Set point when % of flow controlled. Flow is calculated from the total flow on the discharge of the digester feed pumps	24/10/3
	FIT-625408	Sludge flow after digester feed pumps	High	5-15			High flow.	24/10/5
	FIT-625409		Mode	See below		Var.	Type of sludge flow control.	24/1013
			Flow	0-30			Set point when flow controlled.	24/10/3
			Pump speed	0-100		) %	Set point when pump speed controlled.	24/10/3
			Low	0-5		m3/h	Low flow.	24/10/3
			Discrepancy	0-1	. 0.5	m3/h	Alarm if there is a deviation between the sludge flow to the digesters and the rate of fall in the flashtank level.	
			Reverse	-1-0	-0.1	m3/h	Negative flow of sludge, stop digester feed pump and cooler, start standby system. If system is already stopped and the associated digested recycled sludge control valve is open, close the digested sludge control valve. Make system unavailable. Reverse flow is registered by a digital contact on the flowmeter.	24/0/3
			Zero	0-1	0.1	1 m3/h	Stop associated digester feed pump system, start standby system.	24/10/3
			Deviation	0-1		5 m3/h	point, a low sludge flow warning is displayed.	3/0/3
	TIT-625403	Sludge temperature downstream flashtank		N/A	N/A		Temperature monitoring.	12/10/3
	TIT-625406	Sludge temperature to coolers	High	0-100	95	5 °C	High temperature.	RIBIS
1	F1762541		Not Zero			•	Alarm	24/6/3

20.09.2006

Q-Pulse Id: TMS217

# ALARM, TRIP AND SETTINGS LIST Doc.no.1035-PRG-003, rev.D04 Thermal hydrolysis plant

P&ID	Loop number	Description	Туре	Adjustable range	Set point	Unit	Action	SAT Date/sign.
	TIT-625412		Low	0-100	70	°C	Low temperature.	2/1/2/2
	FCV-625408	Dilution water control valves	Opening time	0-600	60	sec.	Dilution water control valve opening time (0-100%)	25/10/3
	100-020-00	Blidden Water Control Valves	Closing time	0-600	60	sec.	Dilution water control valve closing time (0-100%)	25/10/3
	FCV-625423	Digester feed pump discharge valves	Not opened	0-60	30	sec.	Valve failed to open within the set time.	25/10 AM
	FCV-625428		Not closed	0-60	30	sec.	Valve failed to close within the set time. Stop digester feed, do not promote standby system.	AM
	RD-625118	Rupture disk on flashtank	Fault	N/A	N/A		Makes flashtank unavailable.	20/10 M
486/5/5-R7W106	TIT-625501	Temperature downstream foul gas cooler	High	0-50	40	°C	High temperature.	16/19 141.
400/0/0 10/11/100	, 02000		Mode	See below	Temperature	Var.	Type of cooling water control.	26/10/3
			Position	0-100	0	%	Set point on valve when position controlled.	26/1013
			Temperature	0-50	35	°C	Set point when temperature controlled.	12/10/3
	TIT-625502	Temperature downstream foul gas cooler		N/A	N/A		Temperature monitoring.	2/10/3
	FCV-625503	Cooling water control valve	Opening time	0-600	60	sec.	Cooling water control valve opening time (0-100%)	20/10/3
			Closing time	0-600	60	sec.	Cooling water control valve closing time (0-100%)	26/6/3
486/5/5-R7W107	LS-625601	Level swith in compressed foul gas drum	Low low	N/A	N/A	1	Stop foul gas ejectors, stop THP.	16/10 06 AM
400/0/0 10/ 10/	LIT-625602	Level in compressed foul gas drum	High high	50-100	70	%	Stop foul gas ejectors, stop THP.	16/10 MM
	211 020002	3	High	50-100	60	%	High level.	16/10 /1
			Set point	0-100	50	%	Set point for water in and out valves.	13/10/13
			Low	0-70	40	%	Low level.	16/10 AM
			Low low	0-70	40	%	Stop foul gas ejectors, stop THP.	16/10 AM.
			Dead band	0-10	5	%	Dead band for adding and removing water.	13/10/3
	PIT-625603	Pressure in compressed foul gas drum	High high	0-10	4	barg	High high pressure, stop THP.	16/10 AM
			High	0-10	3	barg	High pressure, close V-625618.	16/10 M
			Set point	0-5	2	barg	Set pressure for compressed foul gas drum, controls foul gas flow from drum using control valve V-625618.	16/10 AM.
			Low	0-10	C	barg	Low pressure, close V-625618.	14/10 +M
			Low low	-0.2-0	-0.1	barg	Low low pressure (vacuum), stop THP.	16/10-41
	FIT-625605	Flow of industrial water from compressed foul	High	0-10	7	m3/h	High flow alarm only when flow is required.	16/10 +1
	111 020000	gas drum	Low	0-10	0.2	m3/h	Low flow alarm only when flow is required.	1121019
			Zero	0-1	0.1	m3/h	Zero flow when flow is required, start standby pump set.	id10/3
			Not zero	0-1	0.1	m3/h	Flow not zero alarm only when flow is not required (leaking valve).	26/0/3
			Reverse	-1-0	-0.1	m3/h	Stop duty ejector system. Start standby.	26/6/3
			Mode	See below	Pressure	Var.	Type of <del>dilution</del> water control.	
			Position	0-100		0 %	Set point when position controlled.	

20.09.2006

Q-Pulse Id: TMS217

#### ALARM, TRIP AND SETTINGS LIST Doc.no.1035-PRG-003, rev.D04 Thermal hydrolysis plant

P&ID	Loop number	Description	Туре	Adjustable range	Set point	Unit	Action	SAT
								Date/sign.
			Flow	0-10		m3/h	Set point when flow controlled.	
		LEVEL	Procesure	0-10 🐧	70 €	bard /	Set point when pessare controlled.	6/10/3
	TIT-625604	Temperature in compressed foul gas drum	High high	50	0-100	°C	Stop foul gas ejectors, stop THP.	16/10 AM
			High	45	0-100	°C	High temperature.	16/10 ty
			Set point	20-60		°C	Set point for water in valves.	12/10/3
			Dead band	0-20	5	°C	Dead band for adding and removing water.	N/A
	PU-625601	Foul gas ejector water pumps	Speed	0-100	100	%	Set speed of foul gas ejector water pumps.	KX 13/10
	PU-625602		Dead band	0-1	0.1	barg	Dead band for starting and stopping foul gas ejector water pumps.	ELIC/5
			Mode	See below	Pressure	Var.	Type of foul gas ejector control. Pressure set point is taken from PIT-625006, pulper pressure.	83412/10
			Pressure	N/A	N/A		Pressure set point is taken from PIT-625006, pulper pressure. Ejector pump speed is controlled to achieve pressure.	12/10/3
			On/off	N/A	N/A		Pressure set point is taken from PIT-625006, pulper pressure. Ejector pumps start and stop based on pressure and dead band.	BX 12/10
	FVC-625621	Water to compressed foul gas drum control	Opening time	0-600	60	sec.	Water control valve opening time (0-100%)	RX 13/16
	1 10 020021	valve	Closing time	0-600	60	sec.	Water control valve closing time (0-100%)	83/10
	FCV-625612	Water from compressed foul gas drum control	Opening time	0-600	60	sec.	Water control valve opening time (0-100%)	BA 13/16
	FCV-625613	valve	Closing time	0-600	60	sec.	Water control valve closing time (0-100%)	BA13/10
	FCV-625618	Foul gas from compressed foul gas drum	Opening time	0-600	60	sec.	Foul gas control valve opening time (0-100%)	13/16
:	00-020010	control valve	Closing time	0-600	60	sec.	Foul gas control valve closing time (0-100%)	BAISA
486/5/5-R7W108	PIT-625701	Compressed air pressure	High high	5-15	1	Bbarg	Suspend THP until pressure below high.	26/10/2
400/3/3-K/ W 100	11-02-57-01	Compressed an pressure	High	5-15		7 barg	Prevent start of THP.	86 als
			Low	0-10	1 .	barg	Prevent start of THP.	26/6/2
			Low low	0-10	1	1 barq	Suspend THP until pressure above low.	Rellas

20.09.2006 Q-Pulse Id: TMS217

05/03/2013